

Asbestos Survey Inventory – Pembroke

Ver. 2007-05-07/06c056

Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Total
PB100A	Office	110-14a	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14b	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14c	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14d	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		110-14e	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
PB100B	Maintenance Shop	110-14a	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14b	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14c	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14d	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		110-14e	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
PB100C	Maintenance Shop	110-14a	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14b	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14c	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14d	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		110-14e	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
PB101	Storage	110-14a	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14b	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14c	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14d	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		110-14e	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
PB102	Computer Lab	102-15a	baseboard	Negative	na	1
			mastic	Negative	na	1
		102-15b	baseboard	Negative	na	1
			mastic	Negative	na	1
		102-15c	baseboard	Negative	na	1
			mastic	Negative	na	1
110-14a	floor tile	Negative	na	1		

			mastic	Negative	na	1
		110-14b	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14c	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14d	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		110-14e	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
PB103	Storage	110-14a	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14b	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14c	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14d	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		110-14e	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
PB105	Office	110-14a	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14b	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14c	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14d	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		110-14e	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
PB108	Office	110-14a	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14b	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14c	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14d	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		110-14e	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
PB109	Storage	110-14a	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14b	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14c	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14d	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		110-14e	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
PB110A -	Offices / IT Room	110-14a	floor tile	Negative	na	1

PB110E						
			mastic	Negative	na	1
		110-14b	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14c	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14d	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		110-14e	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
PB110cc	Main hall - South Wing	110-14a	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14b	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14c	floor tile	Negative	na	1
			mastic	Negative	na	1
		110-14d	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		110-14e	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
PB110Ccc	Corridor between PB110C & lounge	1	ceiling tile	Negative	na	1
		2	ceiling tile	Negative	na	1
		3	ceiling tile	Negative	na	1
		4	ceiling tile	Negative	na	1
		5	ceiling tile	Negative	na	1
		6	ceiling tile	Negative	na	1
		7	ceiling tile	Negative	na	1
		8	ceiling tile	Negative	na	1
		9	ceiling tile	Negative	na	1
		10	ceiling tile	Negative	na	1
		11	ceiling tile	Negative	na	1
		12	ceiling tile	Negative	na	1
		13	ceiling tile	Negative	na	1
		14	ceiling tile	Negative	na	1
PB111	Boardroom	102-15a	baseboard	Negative	na	1
			mastic	Negative	na	1
		102-15b	baseboard	Negative	na	1
			mastic	Negative	na	1
		102-15c	baseboard	Negative	na	1
			mastic	Negative	na	1
PB202A - PB202D	(blank)	202-12a	grey plaster	Negative	na	1
			white plaster	Negative	na	1
		202-12b	grey plaster	Negative	na	1
			white plaster	Negative	na	1
		202-12c	grey plaster	Negative	na	1
			white plaster	Negative	na	1
PB205	Classroom	206-13a	ceiling transite board	Positive	Chrysotile	1
		206-13b	ceiling transite board	STOP	na	1
		206-13c	ceiling transite board	STOP	na	1

		211-11a	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		211-11b	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		211-11c	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		211-9a	silver paint	Negative	na	1
			tar	Positive	Chrysotile	1
		211-9b	silver paint	Negative	na	1
		211-9c	silver paint	Negative	na	1
PB205A	Women's Washroom	211-11a	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		211-11b	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		211-11c	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		211-9a	silver paint	Negative	na	1
			tar	Positive	Chrysotile	1
		211-9b	silver paint	Negative	na	1
		211-9c	silver paint	Negative	na	1
PB206	Office	206-13a	ceiling transite board	Positive	Chrysotile	1
		206-13b	ceiling transite board	STOP	na	1
		206-13c	ceiling transite board	STOP	na	1
PB207 - PB207A	(blank)	211-11a	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		211-11b	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		211-11c	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
PB211	Classroom	211-11a	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		211-11b	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		211-11c	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		211-9a	silver paint	Negative	na	1
			tar	Positive	Chrysotile	1
		211-9b	silver paint	Negative	na	1
		211-9c	silver paint	Negative	na	1
PB211cc	Hall main south bldg.	211-11a	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		211-11b	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		211-11c	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		211-9a	tar	Positive	Chrysotile	1
		211-9b	silver paint	Negative	na	1
		211-9c	silver paint	Negative	na	1
PB212	Office	211-11a	floor tile	Positive	Chrysotile	1

			mastic	Negative	na	1
		211-11b	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		211-11c	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		211-9a	silver paint	Negative	na	2
			tar	Positive	Chrysotile	1
		211-9b	silver paint	Negative	na	1
		211-9c	silver paint	Negative	na	1
PB213cc	main hall from 213 to 227	215-8a	baseboard	Negative	na	1
			mastic	Negative	na	1
		215-8b	baseboard	Negative	na	1
			mastic	Negative	na	1
		215-8c	baseboard	Negative	na	1
			mastic	Negative	na	1
PB214A - PB214C	Office	215-8a	baseboard	Negative	na	1
			mastic	Negative	na	1
		215-8b	baseboard	Negative	na	1
			mastic	Negative	na	1
		215-8c	baseboard	Negative	na	1
			mastic	Negative	na	1
PB215	Classroom	215-8a	baseboard	Negative	na	1
			mastic	Negative	na	1
		215-8b	baseboard	Negative	na	1
			mastic	Negative	na	1
		215-8c	baseboard	Negative	na	1
			mastic	Negative	na	1
PB220	(blank)	15	floor tile	Negative	na	1
			mastic	Negative	na	1
		16	floor tile	Negative	na	1
			mastic	Negative	na	1
		17	floor tile	Negative	na	1
			mastic	Negative	na	1
		18	baseboard	Negative	na	1
			mastic	Negative	na	1
		19	baseboard	Negative	na	1
			mastic	Negative	na	1
		20	baseboard	Negative	na	1
			mastic	Negative	na	1
PB300	Staff Room	300-3a	ceiling tile	Negative	na	1
		300-3b	ceiling tile	Negative	na	1
		300-3c	ceiling tile	Negative	na	1
		300-4a	carpet mastic	Negative	na	1
		300-4b	carpet mastic	Negative	na	1
		300-4c	carpet mastic	Negative	na	1
		323a-1a	wall - drywall joint compound	Negative	na	1
		323a-1b	wall - drywall joint compound	Negative	na	1
		323a-1c	wall - drywall joint compound	Negative	na	1
PB301A	Office	300-4a	carpet mastic	Negative	na	1

		300-4b	carpet mastic	Negative	na	1
		300-4c	carpet mastic	Negative	na	1
		323a-1a	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		323a-1b	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		323a-1c	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
PB301B	Office	300-4a	carpet mastic	Negative	na	1
		300-4b	carpet mastic	Negative	na	1
		300-4c	carpet mastic	Negative	na	1
		323a-1a	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		323a-1b	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		323a-1c	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
PB302	Office	300-4a	carpet mastic	Negative	na	1
		300-4b	carpet mastic	Negative	na	1
		300-4c	carpet mastic	Negative	na	1
		323a-1a	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		323a-1b	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		323a-1c	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
PB303	Office	303-5a	wall - drywall joint compound	Negative	na	1
		303-5b	wall - drywall joint compound	Negative	na	1
		303-5c	wall - drywall joint compound	Negative	na	1
		323a-2a	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2b	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2c	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
PB304	Office	303-5a	wall - drywall joint compound	Negative	na	1
		303-5b	wall - drywall joint compound	Negative	na	1
		303-5c	wall - drywall joint compound	Negative	na	1
		323a-2a	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2b	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2c	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
PB305	Office	303-5a	wall - drywall joint compound	Negative	na	1
		303-5b	wall - drywall joint compound	Negative	na	1
		303-5c	wall - drywall joint compound	Negative	na	1
		323a-2a	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2b	black baseboard	Negative	na	1

			yellow mastic	Negative	na	1
		323a-2c	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
PB306A	Office	300-4a	carpet mastic	Negative	na	1
		300-4b	carpet mastic	Negative	na	1
		300-4c	carpet mastic	Negative	na	1
		303-5a	wall - drywall joint compound	Negative	na	1
		303-5b	wall - drywall joint compound	Negative	na	1
		303-5c	wall - drywall joint compound	Negative	na	1
		323a-2a	black baseboard	Negative	na	1
			yellow mastic	Negative	na	2
		323a-2b	black baseboard	Negative	na	2
			yellow mastic	Negative	na	1
PB307A	Office	300-4a	carpet mastic	Negative	na	1
		300-4b	carpet mastic	Negative	na	1
		300-4c	carpet mastic	Negative	na	1
		303-5a	wall - drywall joint compound	Negative	na	1
		303-5b	wall - drywall joint compound	Negative	na	1
		303-5c	wall - drywall joint compound	Negative	na	1
		323a-2a	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2b	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2c	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
	(blank)	41	ceiling tile	Negative	na	1
		42	ceiling tile	Negative	na	1
		43	ceiling tile	Negative	na	1
		44	baseboard	Negative	na	1
			mastic	Negative	na	1
		45	baseboard	Negative	na	1
			mastic	Negative	na	1
		46	baseboard	Negative	na	1
			mastic	Negative	na	1
PB308	Office	300-4a	carpet mastic	Negative	na	1
		300-4b	carpet mastic	Negative	na	1
		300-4c	carpet mastic	Negative	na	1
		303-5a	wall - drywall joint compound	Negative	na	1
		303-5b	wall - drywall joint compound	Negative	na	1
		303-5c	wall - drywall joint compound	Negative	na	1
PB309	Office	300-4a	carpet mastic	Negative	na	1
		300-4b	carpet mastic	Negative	na	1
		300-4c	carpet mastic	Negative	na	1
		303-5a	wall - drywall joint compound	Negative	na	1
		303-5b	wall - drywall joint compound	Negative	na	1
		303-5c	wall - drywall joint compound	Negative	na	1
PB310	Office	303-5a	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		303-5b	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1

		303-5c	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		323a-2a	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2b	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2c	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
PB311	Office	300-4a	carpet mastic	Negative	na	1
		300-4b	carpet mastic	Negative	na	1
		300-4c	carpet mastic	Negative	na	1
		303-5a	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		303-5b	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		303-5c	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		323a-2a	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2b	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2c	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
PB312	Office	300-4a	carpet mastic	Negative	na	1
		300-4b	carpet mastic	Negative	na	1
		300-4c	carpet mastic	Negative	na	1
PB313	Office	300-4a	carpet mastic	Negative	na	1
		300-4b	carpet mastic	Negative	na	1
		300-4c	carpet mastic	Negative	na	1
PB314	Copier Room	303-5a	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		303-5b	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		303-5c	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		314-6a	black mastic	Negative	na	1
			brown floor tile	Positive	Chrysotile	1
		314-6b	black mastic	Negative	na	1
			brown floor tile	Positive	Chrysotile	1
		314-6c	black mastic	Negative	na	1
			brown floor tile	Positive	Chrysotile	1
		323a-2a	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2b	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2c	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
PB315	Electrical Room	303-5a	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		303-5b	ceiling - drywall joint compound	Negative	na	1

			wall - drywall joint compound	Negative	na	1
		303-5c	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		314-6a	black mastic	Negative	na	1
			brown floor tile	Positive	Chrysotile	1
		314-6b	black mastic	Negative	na	1
			brown floor tile	Positive	Chrysotile	1
		314-6c	black mastic	Negative	na	1
			brown floor tile	Positive	Chrysotile	1
		323a-2a	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2b	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2c	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
PB316	Office	300-4a	carpet mastic	Negative	na	1
		300-4b	carpet mastic	Negative	na	1
		300-4c	carpet mastic	Negative	na	1
		303-5a	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		303-5b	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		303-5c	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
PB317	Office	300-4a	carpet mastic	Negative	na	1
		300-4b	carpet mastic	Negative	na	1
		300-4c	carpet mastic	Negative	na	1
		303-5a	wall - drywall joint compound	Negative	na	1
		303-5b	wall - drywall joint compound	Negative	na	1
		303-5c	wall - drywall joint compound	Negative	na	1
PB318	Office	300-4a	carpet mastic	Negative	na	1
		300-4b	carpet mastic	Negative	na	1
		300-4c	carpet mastic	Negative	na	1
		303-5a	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		303-5b	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		303-5c	ceiling - drywall joint compound	Negative	na	1
			wall - drywall joint compound	Negative	na	1
PB321	Classroom	303-5a	wall - drywall joint compound	Negative	na	1
		303-5b	wall - drywall joint compound	Negative	na	1
		303-5c	wall - drywall joint compound	Negative	na	1
		323a-2a	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2b	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2c	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
PB322cc	hallway from 322 to 323A	303-5a	wall - drywall joint compound	Negative	na	1
		303-5b	wall - drywall joint compound	Negative	na	1

		303-5c	wall - drywall joint compound	Negative	na	1
PB323A	(blank)	323a-1a	wall - drywall joint compound	Negative	na	1
		323a-1b	wall - drywall joint compound	Negative	na	1
		323a-1c	wall - drywall joint compound	Negative	na	1
		323a-2a	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2b	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2c	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
PB323B	Boardroom	300-4a	carpet mastic	Negative	na	1
		300-4b	carpet mastic	Negative	na	1
		300-4c	carpet mastic	Negative	na	1
		323a-2a	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2b	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2c	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
	(blank)	38	plaster	Negative	na	1
		39	plaster	Negative	na	1
		40	plaster	Negative	na	1
PB324	(blank)	24	ceiling tile	Negative	na	1
		25	ceiling tile	Negative	na	1
		26	ceiling tile	Negative	na	1
		27	floor tile	Positive	Chrysotile	1
			mastic	Negative	na	1
		28	mastic	Negative	na	1
		29	mastic	Negative	na	1
		30	baseboard	Negative	na	1
			mastic	Negative	na	1
		31	baseboard	Negative	na	1
			mastic	Negative	na	1
		32	baseboard	Negative	na	1
			mastic	Negative	na	1
PB324cc	Corridor	21	ceiling tile	Negative	na	1
		22	ceiling tile	Negative	na	1
		23	ceiling tile	Negative	na	1
PB329	Women's Washroom	329WW-7a	mastic	Negative	na	1
			red-brown floor tile	Negative	na	1
		329WW-7b	mastic	Negative	na	1
			red-brown floor tile	Negative	na	1
		329WW-7c	mastic	Negative	na	1
			red-brown floor tile	Negative	na	1
PB331	Men's Washroom	329WW-7a	mastic	Negative	na	1
			red-brown floor tile	Negative	na	1
		329WW-7b	mastic	Negative	na	1

			red-brown floor tile	Negative	na	1
		329WW-7c	mastic	Negative	na	1
			red-brown floor tile	Negative	na	1
PB335	Ceiling Plenum to PB335	35	ceiling tile	Negative	na	1
		36	ceiling tile	Negative	na	1
		37	ceiling tile	Negative	na	1
	(blank)	21	ceiling tile	Negative	na	1
		22	ceiling tile	Negative	na	1
		23	ceiling tile	Negative	na	1
		33	ceiling tile	Negative	na	1
		34	ceiling tile	Negative	na	1
PB335cc	Corridor	21	ceiling tile	Negative	na	1
		22	ceiling tile	Negative	na	1
		23	ceiling tile	Negative	na	1
		33	ceiling tile	Negative	na	1
		34	ceiling tile	Negative	na	1
PB-hallway - old south bldg	(blank)	303-5a	wall - drywall joint compound	Negative	na	1
		303-5b	wall - drywall joint compound	Negative	na	1
		303-5c	wall - drywall joint compound	Negative	na	1
PB-Men's washroom	Men's Washroom	215-8a	baseboard	Negative	na	1
			mastic	Negative	na	1
		215-8b	baseboard	Negative	na	1
			mastic	Negative	na	1
		215-8c	baseboard	Negative	na	1
			mastic	Negative	na	1
PB-Women's washroom	Women's Washroom	215-8a	baseboard	Negative	na	1
			mastic	Negative	na	1
		215-8b	baseboard	Negative	na	1
			mastic	Negative	na	1
		215-8c	baseboard	Negative	na	1
			mastic	Negative	na	1
		329WW-7a	mastic	Negative	na	1
			red-brown floor tile	Negative	na	1
		329WW-7b	mastic	Negative	na	1
			red-brown floor tile	Negative	na	1
		329WW-7c	mastic	Negative	na	1
			red-brown floor tile	Negative	na	1
Campus Total:						530