

Asbestos Survey Inventory - Pembroke Campus

Date: March 14th, 2008

Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Total
PB100A	Office	110-14a	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14b	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14c	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14d	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
		110-14e	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
na	ceiling	na	na	1		
	wall	na	na	1		
PB100B	Maintenance Shop	110-14a	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14b	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14c	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14d	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
		110-14e	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
na	ceiling	na	na	1		
	wall	na	na	1		
PB100C	Maintenance Shop	110-14a	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14b	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14c	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14d	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
		110-14e	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
na	ceiling	na	na	1		
	wall	na	na	1		
PB101	Storage	110-14a	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14b	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14c	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14d	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
		110-14e	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
na	ceiling	na	na	1		
	wall	na	na	1		
PB102	Computer Lab	102-15a	brown baseboard	Negative	na	1
			mastic	Negative	na	1
		102-15b	brown baseboard	Negative	na	1
			mastic	Negative	na	1
		102-15c	brown baseboard	Negative	na	1
			mastic	Negative	na	1
		110-14a	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14b	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
110-14c	black mastic	Negative	na	1		
	grey floor tile	Negative	na	1		
110-14d	black mastic	Negative	na	1		
	grey floor tile	Positive	Chrysotile	1		
110-14e	black mastic	Negative	na	1		
	grey floor tile	Positive	Chrysotile	1		

		na	ceiling	na	na	1
			wall	na	na	1
PB103	Storage	110-14a	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14b	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14c	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14d	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
		110-14e	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
na	ceiling	na	na	1		
	wall	na	na	1		
PB105	Office	110-14a	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14b	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14c	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14d	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
		110-14e	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
na	ceiling	na	na	1		
	wall	na	na	1		
PB108	Office	110-14a	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14b	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14c	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14d	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
		110-14e	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
na	ceiling	na	na	1		
	wall	na	na	1		
PB109	Storage	110-14a	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14b	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14c	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14d	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
		110-14e	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
na	ceiling	na	na	1		
	wall	na	na	1		
PB110A-PB110B	Offices / IT Room	110-14a	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14b	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14c	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14d	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
		110-14e	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
na	ceiling	na	na	1		
	wall	na	na	1		
PB110cc	Main hall - South Wing	110-14a	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14b	black mastic	Negative	na	1
			grey floor tile	Negative	na	1
		110-14c	black mastic	Negative	na	1
			grey floor tile	Negative	na	1

		110-14d	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
		110-14e	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
		na	wall	na	na	1
PB110Ccc	Corridor between PB110C & l		1 ceiling tile	Negative	na	1
			2 ceiling tile	Negative	na	1
			3 ceiling tile	Negative	na	1
			4 ceiling tile	Negative	na	1
			5 ceiling tile	Negative	na	1
			6 ceiling tile	Negative	na	1
PB111	Boardroom	na	ceiling	na	na	1
			floor	na	na	1
			wall	na	na	1
PB111	Boardroom	102-15a	brown baseboard	Negative	na	1
			mastic	Negative	na	1
		102-15b	brown baseboard	Negative	na	1
			mastic	Negative	na	1
		102-15c	brown baseboard	Negative	na	1
			mastic	Negative	na	1
PB112	Cafeteria	na	ceiling	na	na	1
			floor	na	na	1
			wall	na	na	1
PB112A	Bar	na	no acm	na	na	1
	Kitchen	na	ceiling	na	na	1
			floor	na	na	1
			wall	na	na	1
PB113	Classroom	na	ceiling	na	na	1
			floor	na	na	1
			wall	na	na	1
PB115	Classroom	na	ceiling	na	na	1
			floor	na	na	1
			wall	na	na	1
PB116	Men's Washroom		27 black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
			28 black mastic	Negative	na	1
			29 black mastic	Negative	na	1
		215-8a	baseboard	Negative	na	1
			mastic	Negative	na	1
		215-8b	baseboard	Negative	na	1
			mastic	Negative	na	1
		215-8c	baseboard	Negative	na	1
			mastic	Negative	na	1
		na	ceiling	na	na	1
			wall	na	na	1
PB117	Student Association Office	na	ceiling	na	na	1
			floor	na	na	1
			wall	na	na	1
PB118	Women's Washroom	215-8a	baseboard	Negative	na	1
			mastic	Negative	na	1
		215-8b	baseboard	Negative	na	1
			mastic	Negative	na	1
		215-8c	baseboard	Negative	na	1
			mastic	Negative	na	1
		na	ceiling	na	na	1
			floor	na	na	1
			wall	na	na	1
PB120	Motive Power Shop	na	ceiling - sprayed on fire proof	na	na	1
			floor	na	na	1
			wall	na	na	1
PB122	Motive Power Shop	na	ceiling tile	na	na	1
			floor	na	na	1
			wall	na	na	1
PB201	Classroom	na	ceiling	na	na	1
			floor	na	na	1
			wall	na	na	1
PB202A	Office	202-12a	ceiling grey plaster	Negative	na	1
			ceiling white plaster	Negative	na	1

		202-12b	ceiling grey plaster	Negative	na	1
			ceiling white plaster	Negative	na	1
		202-12c	ceiling grey plaster	Negative	na	1
			ceiling white plaster	Negative	na	1
		na	ceiling tile	na	na	1
			drywall/batten	na	na	1
			new floor carpet	na	na	1
PB202B	Office	202-12a	ceiling grey plaster	Negative	na	1
			ceiling white plaster	Negative	na	1
		202-12b	ceiling grey plaster	Negative	na	1
			ceiling white plaster	Negative	na	1
		202-12c	ceiling grey plaster	Negative	na	1
			ceiling white plaster	Negative	na	1
		na	ceiling tile	na	na	1
			drywall/batten	na	na	1
			new floor carpet	na	na	1
PB202C	Office	202-12a	ceiling grey plaster	Negative	na	1
			ceiling white plaster	Negative	na	1
		202-12b	ceiling grey plaster	Negative	na	1
			ceiling white plaster	Negative	na	1
		202-12c	ceiling grey plaster	Negative	na	1
			ceiling white plaster	Negative	na	1
		na	ceiling tile	na	na	1
			drywall/batten	na	na	1
			new floor carpet	na	na	1
PB202D	Office	202-12a	ceiling grey plaster	Negative	na	1
			ceiling white plaster	Negative	na	1
		202-12b	ceiling grey plaster	Negative	na	1
			ceiling white plaster	Negative	na	1
		202-12c	ceiling grey plaster	Negative	na	1
			ceiling white plaster	Negative	na	1
		na	ceiling tile	na	na	1
			drywall/batten	na	na	1
			new floor carpet	na	na	1
PB205	Classroom	206-13a	grey ceiling transite board	Positive	Chrysotile	1
		206-13b	grey ceiling transite board	STOP	na	1
		206-13c	grey ceiling transite board	STOP	na	1
		211-11a	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		211-11b	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		211-11c	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		211-9a	ceiling tar board - silver paint	Negative	na	1
				Positive	Chrysotile	1
		211-9b	ceiling tar board - silver paint	Negative	na	1
		211-9c	ceiling tar board - silver paint	Negative	na	1
		na	ceiling tile	na	na	1
			drywall	na	na	1
PB205A	Women's Washroom	211-11a	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		211-11b	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		211-11c	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		211-9a	ceiling tar board - silver paint	Negative	na	1
				Positive	Chrysotile	1
		211-9b	ceiling tar board - silver paint	Negative	na	1
		211-9c	ceiling tar board - silver paint	Negative	na	1
		na	wall	na	na	1
PB205B	Men's Washroom	211-11a	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		211-11b	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		211-11c	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		211-9a	ceiling tar board - silver paint	Negative	na	1
				Positive	Chrysotile	1

		211-9b	ceiling tar board - silver paint	Negative	na	1
		211-9c	ceiling tar board - silver paint	Negative	na	1
		na	wall	na	na	1
PB206	Office	206-13a	grey ceiling transite board	Positive	Chrysotile	1
		206-13b	grey ceiling transite board	STOP	na	1
		206-13c	grey ceiling transite board	STOP	na	1
		na	drywall	na	na	1
			new floor tile	na	na	1
PB207	Bookstore	211-11a	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		211-11b	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		211-11c	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		na	ceiling	na	na	1
			wall	na	na	1
PB207A	Bookstore	211-11a	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		211-11b	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		211-11c	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		na	ceiling	na	na	1
			wall	na	na	1
PB208	Classroom	na	ceiling	na	na	1
			floor	na	na	1
			wall	na	na	1
PB209	Office	206-13a	grey ceiling transite board	Positive	Chrysotile	1
		206-13b	grey ceiling transite board	STOP	na	1
		206-13c	grey ceiling transite board	STOP	na	1
		na	drywall	na	na	1
			new floor tile	na	na	1
PB210	Office	206-13a	grey ceiling transite board	Positive	Chrysotile	1
		206-13b	grey ceiling transite board	STOP	na	1
		206-13c	grey ceiling transite board	STOP	na	1
		na	drywall	na	na	1
			new floor tile	na	na	1
PB211	Classroom	211-11a	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		211-11b	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		211-11c	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		211-9a	ceiling tar board - silver paint	Negative	na	1
				Positive	Chrysotile	1
211-9b	ceiling tar board - silver paint	Negative	na	1		
211-9c	ceiling tar board - silver paint	Negative	na	1		
na	ceiling tile	na	na	1		
		wall	na	na	1	
PB211cc	Corridor - main south bldg.	211-11a	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		211-11b	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		211-11c	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		211-9a	ceiling tar board - silver paint	Positive	Chrysotile	1
211-9b	ceiling tar board - silver paint	Negative	na	1		
211-9c	ceiling tar board - silver paint	Negative	na	1		
na	wall	na	na	1		
	Hall main south bldg.	na	grey vinyl floor tile	Positive	Chrysotile	1
PB212	Office	211-11a	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		211-11b	black mastic	Negative	na	1
			grey vinyl floor tile	Positive	Chrysotile	1
		211-11c	black mastic	Negative	na	1
	grey vinyl floor tile	Positive	Chrysotile	1		
211-9a	ceiling tar board - silver paint	Negative	na	2		
		Positive	Chrysotile	1		

		211-9b	ceiling tar board - silver paint	Negative	na	1
		211-9c	ceiling tar board - silver paint	Negative	na	1
		na	wall	na	na	1
PB213 (A&B)	Offices	na	ceiling	na	na	1
			floor	na	na	1
			wall	na	na	1
PB213cc	Main Corridor from 213 to 227	27	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
			black mastic	Negative	na	1
		28	black mastic	Negative	na	1
			black mastic	Negative	na	1
		215-8a	baseboard	Negative	na	1
			mastic	Negative	na	1
		215-8b	baseboard	Negative	na	1
			mastic	Negative	na	1
		215-8c	baseboard	Negative	na	1
			mastic	Negative	na	1
		na	ceiling	na	na	1
wall	na		na	1		
PB214 (A, B, C)	Offices	27	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
			black mastic	Negative	na	1
		28	black mastic	Negative	na	1
			black mastic	Negative	na	1
		215-8a	baseboard	Negative	na	1
			mastic	Negative	na	1
		215-8b	baseboard	Negative	na	1
			mastic	Negative	na	1
		215-8c	baseboard	Negative	na	1
			mastic	Negative	na	1
		na	ceiling	na	na	1
wall	na		na	1		
PB215	Classroom	27	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
			black mastic	Negative	na	1
		28	black mastic	Negative	na	1
			black mastic	Negative	na	1
		215-8a	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		215-8b	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		215-8c	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		na	ceiling	na	na	1
wall	na		na	1		
PB216 (A, B, C)	Office	na	ceiling	na	na	1
			floor	na	na	1
			wall	na	na	1
PB217	Office	27	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
			black mastic	Negative	na	1
		28	black mastic	Negative	na	1
			black mastic	Negative	na	1
na	ceiling	na	na	1		
	wall	na	na	1		
PB219	Classroom	na	ceiling	na	na	1
			floor	na	na	1
			wall	na	na	1
PB220	Classroom	15	black mastic	Negative	na	1
			grey vinyl floor tile	Negative	na	1
		16	black mastic	Negative	na	1
			grey vinyl floor tile	Negative	na	1
		17	black mastic	Negative	na	1
			grey vinyl floor tile	Negative	na	1
		18	black mastic	Negative	na	1
			brown baseboard	Negative	na	1
		19	black mastic	Negative	na	1
			brown baseboard	Negative	na	1
		20	black mastic	Negative	na	1
			brown baseboard	Negative	na	1
na	ceiling	na	na	1		
	wall	na	na	1		

PB220cc	Corridor between Conduits &2	7	ceiling tile	Negative	na	1	
		8	ceiling tile	Negative	na	1	
		9	ceiling tile	Negative	na	1	
		10	ceiling tile	Negative	na	1	
		11	ceiling tile	Negative	na	1	
		12	ceiling tile	Negative	na	1	
		13	ceiling tile	Negative	na	1	
		14	ceiling tile	Negative	na	1	
na		floor	na	na	1		
		wall	na	na	1		
PB222	Women's Washroom	215-8a	black baseboard	Negative	na	1	
			yellow mastic	Negative	na	1	
		215-8b	black baseboard	Negative	na	1	
			yellow mastic	Negative	na	1	
		215-8c	black baseboard	Negative	na	1	
			yellow mastic	Negative	na	1	
		329WW-7a	mastic	Negative	na	1	
			red-brown floor tile	Negative	na	1	
		329WW-7b	mastic	Negative	na	1	
			red-brown floor tile	Negative	na	1	
		329WW-7c	mastic	Negative	na	1	
			red-brown floor tile	Negative	na	1	
na		ceiling	na	na	1		
		wall	na	na	1		
PB223	Men's Washroom	27	black mastic	Negative	na	1	
			grey floor tile	Positive	Chrysotile	1	
		28	black mastic	Negative	na	1	
			29	black mastic	Negative	na	1
		215-8a	black baseboard	Negative	na	1	
			yellow mastic	Negative	na	1	
		215-8b	black baseboard	Negative	na	1	
			yellow mastic	Negative	na	1	
		215-8c	black baseboard	Negative	na	1	
			yellow mastic	Negative	na	1	
		na		ceiling	na	na	1
				wall	na	na	1
PB226	Classroom	na	ceiling	na	na	1	
			floor	na	na	1	
			wall	na	na	1	
PB227	Study Lounge	na	ceiling	na	na	1	
			floor	na	na	1	
			wall	na	na	1	
PB300	Staff Room	300-3a	grey/white ceiling tile	Negative	na	1	
		300-3b	grey/white ceiling tile	Negative	na	1	
		300-3c	grey/white ceiling tile	Negative	na	1	
		300-4a	yellow carpet mastic	Negative	na	1	
		300-4b	yellow carpet mastic	Negative	na	1	
		300-4c	yellow carpet mastic	Negative	na	1	
		323a-1a	grey drywall wall joint compo	Negative	na	1	
		323a-1b	grey drywall wall joint compo	Negative	na	1	
		323a-1c	grey drywall wall joint compo	Negative	na	1	
PB301A	Office	300-4a	yellow carpet mastic	Negative	na	1	
		300-4b	yellow carpet mastic	Negative	na	1	
		300-4c	yellow carpet mastic	Negative	na	1	
		323a-1a	ceiling - drywall joint compou	Negative	na	1	
			wall - drywall joint compound	Negative	na	1	
		323a-1b	ceiling - drywall joint compou	Negative	na	1	
			wall - drywall joint compound	Negative	na	1	
		323a-1c	ceiling - drywall joint compou	Negative	na	1	
wall - drywall joint compound	Negative		na	1			
PB301B	Office	300-4a	yellow carpet mastic	Negative	na	1	
		300-4b	yellow carpet mastic	Negative	na	1	
		300-4c	yellow carpet mastic	Negative	na	1	
		323a-1a	grey drywall wall joint compo	Negative	na	2	
		323a-1b	grey drywall clg joint compou	Negative	na	1	
			grey drywall wall joint compo	Negative	na	1	
323a-1c	grey drywall clg joint compou	Negative	na	2			
PB302	Office	300-4a	yellow carpet mastic	Negative	na	1	

		300-4b	yellow carpet mastic	Negative	na	1		
		300-4c	yellow carpet mastic	Negative	na	1		
		323a-1a	grey drywall wall joint compo	Negative	na	2		
		323a-1b	grey drywall clg joint compou	Negative	na	1		
			grey drywall wall joint compo	Negative	na	1		
		323a-1c	grey drywall clg joint compou	Negative	na	2		
PB303 & (A,B)	Office	303-5a	wall - drywall joint compound	Negative	na	1		
		303-5b	wall - drywall joint compound	Negative	na	1		
		303-5c	wall - drywall joint compound	Negative	na	1		
		323a-2a	black baseboard	Negative	na	1		
			yellow mastic	Negative	na	1		
		323a-2b	black baseboard	Negative	na	1		
			yellow mastic	Negative	na	1		
		323a-2c	black baseboard	Negative	na	1		
			yellow mastic	Negative	na	1		
		na	ceiling	na	na	1		
			floor	na	na	1		
		PB304 & PB304	Office	303-5a	wall - drywall joint compound	Negative	na	1
303-5b	wall - drywall joint compound			Negative	na	1		
303-5c	wall - drywall joint compound			Negative	na	1		
323a-2a	black baseboard			Negative	na	1		
	yellow mastic			Negative	na	1		
323a-2b	black baseboard			Negative	na	1		
	yellow mastic			Negative	na	1		
323a-2c	black baseboard			Negative	na	1		
	yellow mastic			Negative	na	1		
na	ceiling			na	na	1		
	floor			na	na	1		
PB305 & PB305	Office			303-5a	wall - drywall joint compound	Negative	na	1
		303-5b	wall - drywall joint compound	Negative	na	1		
		303-5c	wall - drywall joint compound	Negative	na	1		
		323a-2a	black baseboard	Negative	na	1		
			yellow mastic	Negative	na	1		
		323a-2b	black baseboard	Negative	na	1		
			yellow mastic	Negative	na	1		
		323a-2c	black baseboard	Negative	na	1		
			yellow mastic	Negative	na	1		
		na	ceiling	na	na	1		
			floor	na	na	1		
		PB306A	Office	300-4a	yellow carpet mastic	Negative	na	1
300-4b	yellow carpet mastic			Negative	na	1		
300-4c	yellow carpet mastic			Negative	na	1		
303-5a	grey drywall wall joint compo			Negative	na	1		
303-5b	grey drywall wall joint compo			Negative	na	1		
303-5c	grey drywall wall joint compo			Negative	na	1		
323a-2a	black baseboard			Negative	na	1		
	yellow mastic			Negative	na	2		
323a-2b	black baseboard			Negative	na	2		
	yellow mastic			Negative	na	1		
na	ceiling			na	na	1		
PB307A	Office			41	ceiling tile	Negative	na	1
				42	ceiling tile	Negative	na	1
				43	ceiling tile	Negative	na	1
				44	baseboard	Negative	na	1
		mastic	Negative		na	1		
		45	baseboard	Negative	na	1		
			mastic	Negative	na	1		
		46	baseboard	Negative	na	1		
			mastic	Negative	na	1		
		300-4a	yellow carpet mastic	Negative	na	1		
		300-4b	yellow carpet mastic	Negative	na	1		
		300-4c	yellow carpet mastic	Negative	na	1		
		303-5a	grey drywall wall joint compo	Negative	na	1		
		303-5b	grey drywall wall joint compo	Negative	na	1		
		303-5c	grey drywall wall joint compo	Negative	na	1		
		323a-2a	black baseboard	Negative	na	1		
			yellow mastic	Negative	na	1		
		323a-2b	black baseboard	Negative	na	1		

			yellow mastic	Negative	na	1
		323a-2c	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
PB308	Office	300-4a	yellow carpet mastic	Negative	na	1
		300-4b	yellow carpet mastic	Negative	na	1
		300-4c	yellow carpet mastic	Negative	na	1
		303-5a	wall - drywall joint compound	Negative	na	1
		303-5b	wall - drywall joint compound	Negative	na	1
		303-5c	wall - drywall joint compound	Negative	na	1
		na	ceiling	na	na	1
PB309	Office	300-4a	yellow carpet mastic	Negative	na	1
		300-4b	yellow carpet mastic	Negative	na	1
		300-4c	yellow carpet mastic	Negative	na	1
		303-5a	wall - drywall joint compound	Negative	na	1
		303-5b	wall - drywall joint compound	Negative	na	1
		303-5c	wall - drywall joint compound	Negative	na	1
		na	ceiling	na	na	1
PB310	Office	303-5a	ceiling - drywall joint compou	Negative	na	2
		303-5b	ceiling - drywall joint compou	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		303-5c	wall - drywall joint compound	Negative	na	2
		323a-2a	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2b	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2c	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		na	floor	na	na	1
PB311	Office	300-4a	yellow carpet mastic	Negative	na	1
		300-4b	yellow carpet mastic	Negative	na	1
		300-4c	yellow carpet mastic	Negative	na	1
		303-5a	ceiling - drywall joint compou	Negative	na	2
		303-5b	ceiling - drywall joint compou	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		303-5c	wall - drywall joint compound	Negative	na	2
		323a-2a	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2b	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2c	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
PB312	Office	300-4a	yellow carpet mastic	Negative	na	1
		300-4b	yellow carpet mastic	Negative	na	1
		300-4c	yellow carpet mastic	Negative	na	1
		na	ceiling	na	na	1
			wall	na	na	1
PB313	Office	300-4a	yellow carpet mastic	Negative	na	1
		300-4b	yellow carpet mastic	Negative	na	1
		300-4c	yellow carpet mastic	Negative	na	1
		na	ceiling	na	na	1
			wall	na	na	1
PB314	Copier Room	303-5a	ceiling - drywall joint compou	Negative	na	2
		303-5b	ceiling - drywall joint compou	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		303-5c	wall - drywall joint compound	Negative	na	2
		314-6a	black mastic	Negative	na	1
			brown vinyl floor tile	Positive	Chrysotile	1
		314-6b	black mastic	Negative	na	1
			brown vinyl floor tile	Positive	Chrysotile	1
		314-6c	black mastic	Negative	na	1
			brown vinyl floor tile	Positive	Chrysotile	1
		323a-2a	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2b	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2c	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
PB315	Electrical Room	303-5a	ceiling - drywall joint compou	Negative	na	2

		303-5b	ceiling - drywall joint compou	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		303-5c	wall - drywall joint compound	Negative	na	2
		314-6a	black mastic	Negative	na	1
			brown vinyl floor tile	Positive	Chrysotile	1
		314-6b	black mastic	Negative	na	1
			brown vinyl floor tile	Positive	Chrysotile	1
		314-6c	black mastic	Negative	na	1
			brown vinyl floor tile	Positive	Chrysotile	1
		323a-2a	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2b	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2c	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
PB316	Office	300-4a	yellow carpet mastic	Negative	na	1
		300-4b	yellow carpet mastic	Negative	na	1
		300-4c	yellow carpet mastic	Negative	na	1
		303-5a	ceiling - drywall joint compou	Negative	na	2
		303-5b	ceiling - drywall joint compou	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		303-5c	wall - drywall joint compound	Negative	na	2
PB317	Office	300-4a	yellow carpet mastic	Negative	na	1
		300-4b	yellow carpet mastic	Negative	na	1
		300-4c	yellow carpet mastic	Negative	na	1
		303-5a	wall - drywall joint compound	Negative	na	1
		303-5b	wall - drywall joint compound	Negative	na	1
		303-5c	wall - drywall joint compound	Negative	na	1
		na	ceiling	na	na	1
PB318	Office	300-4a	yellow carpet mastic	Negative	na	1
		300-4b	yellow carpet mastic	Negative	na	1
		300-4c	yellow carpet mastic	Negative	na	1
		303-5a	ceiling - drywall joint compou	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		303-5b	ceiling - drywall joint compou	Negative	na	1
			wall - drywall joint compound	Negative	na	1
		303-5c	ceiling - drywall joint compou	Negative	na	1
			wall - drywall joint compound	Negative	na	1
PB319	Washroom	na	ceiling	na	na	1
			floor	na	na	1
			wall	na	na	1
PB320	Washroom	na	ceiling	na	na	1
			floor	na	na	1
			wall	na	na	1
PB321	Classroom	303-5a	wall - drywall joint compound	Negative	na	1
		303-5b	wall - drywall joint compound	Negative	na	1
		303-5c	wall - drywall joint compound	Negative	na	1
		323a-2a	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2b	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2c	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		na	ceiling	na	na	1
			floor	na	na	1
PB321cc	Corridor - South Wing 321-303	303-5a	wall - drywall joint compound	Negative	na	1
		303-5b	wall - drywall joint compound	Negative	na	1
		303-5c	wall - drywall joint compound	Negative	na	1
		na	ceiling	na	na	1
			floor	na	na	1
PB322	Boiler Room	na	ceiling	na	na	1
			floor	na	na	1
			pipe insulation	na	na	1
			wall	na	na	1
PB322cc	Corridor - from 322 to 323A	303-5a	wall - drywall joint compound	Negative	na	1
		303-5b	wall - drywall joint compound	Negative	na	1
		303-5c	wall - drywall joint compound	Negative	na	1
		na	ceiling	na	na	1

			floor	na	na	1
PB323A	Classroom	323a-1a	grey drywall wall joint compo	Negative	na	1
		323a-1b	grey drywall wall joint compo	Negative	na	1
		323a-1c	grey drywall wall joint compo	Negative	na	1
		323a-2a	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2b	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2c	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		na	ceiling	na	na	1
na	floor	na	na	1		
	Office	na	baseboard and mastic	Negative	na	1
PB323B	Boardroom	38	ceiling-plaster	Negative	na	1
		39	ceiling-plaster	Negative	na	1
		40	ceiling-plaster	Negative	na	1
		300-4a	yellow carpet mastic	Negative	na	1
		300-4b	yellow carpet mastic	Negative	na	1
		300-4c	yellow carpet mastic	Negative	na	1
		323a-2a	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2b	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		323a-2c	black baseboard	Negative	na	1
			yellow mastic	Negative	na	1
		na	wall	na	na	1
		PB324	Classroom	24	grey/white ceiling tile	Negative
25	grey/white ceiling tile			Negative	na	1
26	grey/white ceiling tile			Negative	na	1
27	black mastic			Negative	na	1
	grey floor tile			Positive	Chrysotile	1
28	black mastic			Negative	na	1
29	black mastic			Negative	na	1
30	black mastic			Negative	na	1
	brown baseboard			Negative	na	1
31	black mastic			Negative	na	1
	brown baseboard			Negative	na	1
32	black mastic			Negative	na	1
	brown baseboard			Negative	na	1
na	wall			na	na	1
PB324cc	Corridor	21	grey/white ceiling tile	Negative	na	1
		22	grey/white ceiling tile	Negative	na	1
		23	grey/white ceiling tile	Negative	na	1
		27	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
		28	black mastic	Negative	na	1
		29	black mastic	Negative	na	1
		33	grey/white ceiling tile	Negative	na	1
		34	grey/white ceiling tile	Negative	na	1
		35	grey/white ceiling tile	Negative	na	1
		36	grey/white ceiling tile	Negative	na	1
		37	grey/white ceiling tile	Negative	na	1
		na	block wall	na	na	1
PB324ss	South Stairs	na	ceiling	na	na	1
		na	floor	na	na	1
		na	wall	na	na	1
PB325	Classroom	27	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
		28	black mastic	Negative	na	1
		29	black mastic	Negative	na	1
na	ceiling	na	na	1		
	wall	na	na	1		
PB326	Classroom	27	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
		28	black mastic	Negative	na	1
		29	black mastic	Negative	na	1
na	ceiling	na	na	1		
	wall	na	na	1		

PB327	Classroom	27	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
		28	black mastic	Negative	na	1
		29	black mastic	Negative	na	1
		na	ceiling	na	na	1
			wall	na	na	1
PB328	Classroom	27	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
		28	black mastic	Negative	na	1
		29	black mastic	Negative	na	1
		na	ceiling	na	na	1
			wall	na	na	1
PB329	Women's Washroom	329WW-7a	mastic	Negative	na	1
			red-brown floor tile	Negative	na	1
		329WW-7b	mastic	Negative	na	1
			red-brown floor tile	Negative	na	1
		329WW-7c	mastic	Negative	na	1
			red-brown floor tile	Negative	na	1
		na	ceiling	na	na	1
			wall	na	na	1
PB331	Men's Washroom	27	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
		28	black mastic	Negative	na	1
		29	black mastic	Negative	na	1
		na	ceiling	na	na	1
			wall	na	na	1
PB332	Office	27	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
		28	black mastic	Negative	na	1
		29	black mastic	Negative	na	1
		na	ceiling	na	na	1
			wall	na	na	1
PB333	Office	27	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
		28	black mastic	Negative	na	1
		29	black mastic	Negative	na	1
		na	ceiling	na	na	1
			wall	na	na	1
PB334	Classroom	27	black mastic	Negative	na	1
			grey floor tile	Positive	Chrysotile	1
		28	black mastic	Negative	na	1
		29	black mastic	Negative	na	1
		na	ceiling	na	na	1
			wall	na	na	1
PB334ss	East Stairs	na	ceiling	na	na	1
			floor	na	na	1
			wall	na	na	1
PB335	Library	21	grey/white ceiling tile	Negative	na	1
			grey/white ceiling tile	Negative	na	1
			grey/white ceiling tile	Negative	na	1
			grey/white ceiling tile	Negative	na	1
		na	block walls	na	na	1
			floor	na	na	1