

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

InAir Batch No. (All)

Count of Sample ID									
Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments	
Woodroffe	W - ACCE Building		Main Lobby/Atrium	AC-ACE-ASB-03A	Spray Foam Insulation	Negative	na	na	
				AC-ACE-ASB-03B	Spray Foam Insulation	Negative	na	na	
				AC-ACE-ASB-03C	Spray Foam Insulation	Negative	na	na	
	W - A Tunnels			Tunnels	AC-TA-ASB-01A	Parging Elbow	Positive	Chrysotile	Positive
					AC-TA-ASB-01B	Parging Elbow	Positive Stop	Chrysotile	Positive Stop
					AC-TA-ASB-01C	Parging Elbow	Positive Stop	Chrysotile	Positive Stop
					AC-TA-ASB-02A	Orange Parging Elbow	Positive	Chrysotile	Positive
					AC-TA-ASB-02B	Orange Parging Elbow	Positive Stop	Chrysotile	Positive Stop
					AC-TA-ASB-02C	Orange Parging Elbow	Positive Stop	Chrysotile	Positive Stop
					AC-TF-ASB-03A	Spray Foam Insulation	Negative	na	na
					AC-TF-ASB-03B	Spray Foam Insulation	Negative	na	na
					AC-TF-ASB-03C	Spray Foam Insulation	Negative	na	na
					AC-TE-ASB-04A	White Parging Elbow	Positive	Chrysotile	Positive
					AC-TE-ASB-04B	White Parging Elbow	Positive Stop	Chrysotile	Positive Stop
					AC-TE-ASB-04C	White Parging Elbow	Positive Stop	Chrysotile	Positive Stop
					AC-TG-ASB-05A	Black Tar / Mastic	Negative	na	na
					AC-TG-ASB-05B	Black Tar / Mastic	Negative	na	na
				AC-TG-ASB-05C	Black Tar / Mastic	Negative	na	na	
				AC-TG-ASB-05D	Black Tar / Mastic	Negative	na	na	
				AC-TG-ASB-05E	Black Tar / Mastic	Negative	na	na	
				AC-TG-ASB-05F	Black Tar / Mastic	Negative	na	na	
				AC-TG-ASB-05G	Black Tar / Mastic	Negative	na	na	
				AC-TG-ASB-06A	Green Parging Elbow	Positive	Chrysotile	Positive	
				AC-TG-ASB-06B	Green Parging Elbow	Positive Stop	Chrysotile	Positive Stop	
				AC-TG-ASB-06C	Green Parging Elbow	Positive Stop	Chrysotile	Positive Stop	
				AC-TL-ASB-07A	White Vinyl Floor Tile	Positive	Chrysotile	Positive	
				AC-TL-ASB-07B	White Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop	
				AC-TL-ASB-07C	White Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop	
				Heating Plant	AC-HP-ASB-08A	Orange Parging Elbow	Positive	Chrysotile	Positive
					AC-HP-ASB-08B	Orange Parging Elbow	Positive Stop	Chrysotile	Positive Stop
					AC-HP-ASB-08C	Orange Parging Elbow	Positive Stop	Chrysotile	Positive Stop
	AC-HP-ASB-09A	Orange Pipe Parging	Positive		Chrysotile	Positive			
	AC-HP-ASB-09B	Orange Pipe Parging	Positive Stop		Chrysotile	Positive Stop			
	AC-HP-ASB-09C	Orange Pipe Parging	Positive Stop		Chrysotile	Positive Stop			
	AC-HP-ASB-10A	Orange Tank Insulation	Positive		Chrysotile	Positive			
	AC-HP-ASB-10B	Orange Tank Insulation	Positive Stop		Chrysotile	Positive Stop			
	AC-HP-ASB-10C	Orange Tank Insulation	Positive Stop		Chrysotile	Positive Stop			
	AC-HP-ASB-11A	Chimney Parging	Positive		Chrysotile	Positive			
	AC-HP-ASB-11B	Chimney Parging	Positive Stop	Chrysotile	Positive Stop				
	AC-HP-ASB-11C	Chimney Parging	Positive Stop	Chrysotile	Positive Stop				
	WA100CC1		Hallway	na	no acm	na	na	na	
WA100CC2		Hallway	na	no acm	na	na	na		
WA100CC3		Hallway	na	no acm	na	na	na		
WA100CC4		Hallway	na	no acm	na	na	na		
WA100CC5		Hallway	na	no acm	na	na	na		
WA100CC6		Hallway	na	no acm	na	na	na		
WA100CC7		Hallway	108	ceiling tile	Negative	na	na		
			109	ceiling tile	Negative	na	na		
			110	ceiling tile	Negative	na	na		
			111	ceiling tile	Negative	na	na		
			112	ceiling tile	Negative	na	na		

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WA100CC8		Hallway	na	no acm	na	na	na
	WA100CC9		Hallway	na	no acm	na	na	na
	WA100CC10		Hallway	na	no acm	na	na	na
	WA100CC11		Hallway	na	no acm	na	na	na
	WA100CC12		Hallway	na	no acm	na	na	na
	WA100CC13		Hallway	na	no acm	na	na	na
	WA100CC14		Hallway	30	ceiling tile	Negative	na	na
				31	ceiling tile	Negative	na	na
				32	ceiling tile	Negative	na	na
				33	ceiling tile	Negative	na	na
				34	ceiling tile	Negative	na	na
	WA100CC15		Hallway	na	no acm	na	na	na
	WA100CC16		Hallway	na	no acm	na	na	na
	WA100CC17		Hallway	na	no acm	na	na	na
	WA100CC18		Hallway	na	no acm	na	na	na
	WA100CC19		Hallway	na	no acm	na	na	na
	WA100CC20		Hallway	na	no acm	na	na	na
	WA100CC21		Hallway	na	no acm	na	na	na
	WA100CC22		Hallway	na	no acm	na	na	na
	WA100CC23		Hallway	na	no acm	na	na	na
	WA100CC24		Hallway	na	no acm	na	na	na
	WA100CC25		Hallway	na	no acm	na	na	na
	WA100CC26		Hallway	na	no acm	na	na	na
	WA100CC27		Hallway	na	no acm	na	na	na
	WA100CC28		Hallway	na	no acm	na	na	na
	WA100SS1		Stairwell	na	no acm	na	na	na
	WA100SS2		Stairwell	na	no acm	na	na	na
	WA100SS3		Stairwell	na	no acm	na	na	na
	WA100SS4		Stairwell	na	no acm	na	na	na
	WA100SS5		Stairwell	na	no acm	na	na	na
	WA100SS6		Stairwell	na	no acm	na	na	na
	WA100SS7		Stairwell	na	no acm	na	na	na
	WA100SS8		Stairwell	na	no acm	na	na	na
	WA1004CNRS		4-way crossing	na	no acm	na	na	na
	WA100VS1		Vestebule	na	no acm	na	na	na
	WA100VS2		Vestebule	na	no acm	na	na	na
	WA100VS3		Vestebule	na	no acm	na	na	na
	WA100VS4		Vestebule	na	no acm	na	na	na
	WA100VS5		Vestebule	na	no acm	na	na	na
	WA100		Ceiling above Reception area	AC-WA1-ASB-02-A	Elbow Parging	Positive	Chrysotile	Positive
				AC-WA1-ASB-02-B	Elbow Parging	Positive Stop	na	na
				AC-WA1-ASB-02-C	Elbow Parging	Positive Stop	na	na
	WA100A		Sitting Area	na	no acm	na	na	na
	WA100b		Storage	AC-WA1-ASB-01-A	vinyl floor tile	Negative	na	na
				AC-WA1-ASB-01-B	vinyl floor tile	Negative	na	na
	WA100C		(Blank)	na	no acm	na	na	na
	WA100D		(Blank)	AC-WA1-ASB-01-C	vinyl floor tile	Negative	na	na
	WA101		(blank)	26-07-06-14a	pipe insulation	Positive	Chrysotile	Positive
				26-07-06-14b	pipe insulation	Positive Stop	Chrysotile	Positive Stop
				26-07-06-14c	pipe insulation	Positive Stop	Chrysotile	Positive Stop
				26-07-06-15a	plaster	Negative	na	na
				26-07-06-15b	plaster	Negative	na	na
				26-07-06-15c	plaster	Negative	na	na
				26-07-06-16a	drywall compound	Negative	na	na
				26-07-06-16b	drywall compound	Negative	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
				26-07-06-16c	drywall compound	Negative	na	na
				26-07-06-17a	baseboard	Negative	na	na
					mastic	Negative	na	na
				26-07-06-17b	baseboard	Negative	na	na
					mastic	Negative	na	na
				26-07-06-17c	baseboard	Negative	na	na
					mastic	Negative	na	na
				26-07-06-18a	carpet mastic	Negative	na	na
				26-07-06-18b	carpet mastic	Negative	na	na
				26-07-06-18c	carpet mastic	Negative	na	na
				26-07-06-19a	floor tile	Negative	na	na
					mastic	Negative	na	na
				26-07-06-19b	floor tile	Negative	na	na
					mastic	Negative	na	na
				26-07-06-19c	floor tile	Negative	na	na
					mastic	Negative	na	na
WA101			Vault	26-07-06-20a	floor tile	Positive	Chrysotile	Removed
					mastic	Positive	Chrysotile	Removed
			(blank)	26-07-06-20b	floor tile & mastic	na	na	na
				26-07-06-20c	floor tile & mastic	na	na	na
WA101A			Sitting Area	na	no acm	na	na	na
WA101B			(Blank)	na	no acm	na	na	na
WA101C			(Blank)	na	no acm	na	na	na
WA101D			Office	na	no acm	na	na	na
WA101E			Office	na	no acm	na	na	na
WA102			(blank)	113	plaster	Negative	na	na
				114	plaster	Negative	na	na
				115	plaster	Negative	na	na
				116	drywall compound	Negative	na	na
				117	drywall compound	Negative	na	na
				118	drywall compound	Negative	na	na
				119	plaster	Negative	na	na
				120	plaster	Negative	na	na
WA103			Office	A103-2a	pipe insulation	Positive	Chrysotile	Positive
				A103-2b	pipe insulation	Positive Stop	Chrysotile	Positive Stop
				A103-2c	pipe insulation	Positive Stop	Chrysotile	Positive Stop
				A103-3a	wall drywall joint compound	na	na	na
				A103-3b	wall drywall joint compound	na	na	na
				A103-3c	wall drywall joint compound	na	na	na
				A103-4a	grey plaster - wall	Negative	na	na
					white plaster - wall	Negative	na	na
				A103-4b	grey plaster - wall	Negative	na	na
					white plaster - wall	Negative	na	na
				A103-4c	grey plaster - wall	Negative	na	na
					white plaster - wall	Negative	na	na
				A103-5	yellow carpet mastic	Negative	na	na
				A103-5a	yellow carpet mastic	Negative	na	na
				na	new ceiling tile	no acm	na	na
WA104			(blank)	108	ceiling tile	Negative	na	na
				109	ceiling tile	Negative	na	na
				110	ceiling tile	Negative	na	na
				111	ceiling tile	Negative	na	na
				112	ceiling tile	Negative	na	na
				113	plaster	Negative	na	na
				114	plaster	Negative	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
				115	plaster	Negative	na	na
				119	plaster	Negative	na	na
				120	plaster	Negative	na	na
				121	baseboard	Negative	na	na
					mastic	Negative	na	na
				122	baseboard	Negative	na	na
					mastic	Negative	na	na
				123	baseboard	Negative	na	na
					mastic	Negative	na	na
	WA105A		Men's Washroom	na	no acm	na	na	na
	WA105B		Women's Washroom	na	no acm	na	na	na
	WA106		Sitting Area	na	no acm	na	na	na
	WA107		(blank)	na	no acm	na	na	na
	WA107A		Storage	na	no acm	na	na	na
	WA108		Handicap Washroom	na	no acm	na	na	na
	WA109		(Blank)	na	no acm	na	na	na
	WA109A		(blank)	113	plaster	Negative	na	na
				114	plaster	Negative	na	na
				115	plaster	Negative	na	na
				119	plaster	Negative	na	na
				120	plaster	Negative	na	na
				A109A-1	ceiling plaster	Negative	na	na
					wall plaster	Negative	na	na
				A109A-2	ceiling plaster	Negative	na	na
					wall plaster	Negative	na	na
				A109A-3	ceiling plaster	Negative	na	na
					wall plaster	Negative	na	na
				A109A-4	drywall compound	Negative	na	na
				A109A-5	drywall compound	Negative	na	na
				A109A-6	drywall compound	Negative	na	na
				A109A-7	floor carpet	Negative	na	na
				A109A-8	floor carpet	Negative	na	na
				A109A-9	floor carpet	Positive	Chrysotile	Removed
	WA110		(blank)	104	ceiling tile	Negative	na	na
				105	ceiling tile	Negative	na	na
				106	ceiling tile	Negative	na	na
				107	ceiling tile	Negative	na	na
				108	ceiling tile	Negative	na	na
				109	drywall compound	Negative	na	na
				110	drywall compound	Negative	na	na
				111	drywall compound	Negative	na	na
				112	baseboard	Negative	na	na
					mastic	Negative	na	na
				113	baseboard	Negative	na	na
					mastic	Negative	na	na
				114	baseboard	Negative	na	na
					mastic	Negative	na	na
				115	pipe fittings	Positive	Chrysotile	Removed
				116	stop	Positive	Chrysotile	Removed
				117	stop	Positive	Chrysotile	Removed
				118	floor tile	Negative	na	na
					mastic	Positive	Chrysotile	Removed
				119	floor tile	Negative	na	na
					mastic	Positive	Chrysotile	Removed
				120	floor tile	Negative	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
					mastic	Negative	na	na
				121	floor tile	Negative	na	na
					mastic	Negative	na	na
				122	floor tile	Negative	na	na
					mastic	Positive	Chrysotile	Removed
				123	floor tile	Negative	na	na
					mastic	Positive	Chrysotile	Removed
	WA110A		Storage	na	no acm	na	na	na
	WA111		Hair Washing	na	no acm	na	na	na
	WA112		(Blank)	na	no acm	na	na	na
	WA113		(Blank)	na	no acm	na	na	na
	WA114A		Office	na	no acm	na	na	na
	WA114B		Office	na	no acm	na	na	na
	WA114C		Office	na	no acm	na	na	na
	WA115A		Office	na	no acm	na	na	na
	WA115B		Office	na	no acm	na	na	na
	WA115C		Office	na	no acm	na	na	na
	WA116		Classroom	WA113-001a	pipe insulation	Positive	Chrysotile	Positive
				WA113-001b	pipe insulation	Positive Stop	Chrysotile	Positive Stop
				WA113-001c	pipe insulation	Positive Stop	Chrysotile	Positive Stop
	WA116A		Metalurgy Lab	na	no acm	na	na	na
	WA117		MMA/Boxing Gym	na	no acm	na	na	na
	WA118		Study Area	na	no acm	na	na	na
	WA118A		Meeting Room	na	no acm	na	na	na
	WA118B		Meeting Room	na	no acm	na	na	na
	WA119		Exercise Room	na	no acm	na	na	na
	WA120		Gymnasium	na	no acm	na	na	na
	WA120A		(blank)	na	no acm	na	na	na
	WA120B		(blank)	na	no acm	na	na	na
	WA121SC		Gymnasium Entrance	na	no acm	na	na	na
	WA121RE		Gymnasium Reception	na	no acm	na	na	na
	WA121A		(blank)	na	no acm	na	na	na
	WA121B		(blank)	na	no acm	na	na	na
	WA121C		(blank)	na	no acm	na	na	na
	WA121D		(blank)	na	no acm	na	na	na
	WA121E		(blank)	na	no acm	na	na	na
	WA122		(blank)	na	no acm	na	na	na
	WA122A		(blank)	na	no acm	na	na	na
	WA122B		(blank)	na	no acm	na	na	na
	WA122C		(blank)	na	no acm	na	na	na
	WA122D		(blank)	na	no acm	na	na	na
	WA122E		(blank)	na	no acm	na	na	na
	WA122F		(blank)	na	no acm	na	na	na
	WA122G		(blank)	na	no acm	na	na	na
	WA122H	A122CC	Hall adjacent to A122	na	no acm	na	na	na
	WA123J		(blank)	na	no acm	na	na	na
	WA123		(blank)	na	no acm	na	na	na
	WA123A		(blank)	na	no acm	na	na	na
	WA123B		(blank)	na	no acm	na	na	na
	WA123C		(blank)	na	no acm	na	na	na
	WA123D		(blank)	na	no acm	na	na	na
	WA123E		(blank)	na	no acm	na	na	na
	WA123F		(blank)	na	no acm	na	na	na
	WA123G		(blank)	na	no acm	na	na	na
	WA123H		Hallway Adjacent to A120	na	no acm	na	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WA123J		(blank)	na	no acm	na	na	na
	WA123K		(blank)	na	no acm	na	na	na
	WA123L		(blank)	na	no acm	na	na	na
	WA123M		(blank)	na	no acm	na	na	na
	WA123N		(blank)	na	no acm	na	na	na
	WA123O		(blank)	na	no acm	na	na	na
	WA123P		(blank)	na	no acm	na	na	na
	WA123Q		(blank)	na	no acm	na	na	na
	WA123R		(blank)	na	no acm	na	na	na
	WA123S		(blank)	na	no acm	na	na	na
	WA123T		(blank)	na	no acm	na	na	na
	WA123U		(blank)	na	no acm	na	na	na
	WA123V		(blank)	na	no acm	na	na	na
	WA123W		(blank)	na	no acm	na	na	na
	WA123X		(blank)	na	no acm	na	na	na
	WA124		Tim Horton's Sitting Area	na	no acm	na	na	na
	WA124A		Tim Horton's	na	no acm	na	na	na
	WA124B		Tim Horton's Kitchen	na	no acm	na	na	na
	WA125	A125RE	A125 - path, Point #1 behind service d	na	new ceiling tile	no acm	na	na
		A125SC3	A125 - path, Point #3 hallway	na	new ceiling tile	no acm	na	na
		A125SC2	(blank)	na	all new	no acm	na	na
		A125SC1	A125 - path, Point #2 ceramic tile, old	na	na	no acm	na	na
	WA125A		(blank)	na	no acm	na	na	na
	WA125B		(blank)	na	no acm	na	na	na
	WA125C		(blank)	na	no acm	na	na	na
	WA125D		(blank)	na	no acm	na	na	na
	WA125E		(blank)	na	no acm	na	na	na
	WA125F		(blank)	na	no acm	na	na	na
	WA125G		(blank)	na	no acm	na	na	na
	WA125H		(blank)	na	no acm	na	na	na
	WA125J		(blank)	na	no acm	na	na	na
	WA125K		(blank)	na	no acm	na	na	na
	WA125L		(blank)	na	no acm	na	na	na
	WA125M		(blank)	na	no acm	na	na	na
	WA125N		(blank)	na	no acm	na	na	na
	WA125O		(blank)	na	no acm	na	na	na
	WA125P		(blank)	na	no acm	na	na	na
	WA125Q		(blank)	na	no acm	na	na	na
	WA125R		(blank)	na	no acm	na	na	na
	WA125S		(blank)	na	no acm	na	na	na
	WA125T		(blank)	na	no acm	na	na	na
	WA125V		(blank)	na	no acm	na	na	na
	WA125W		(blank)	na	no acm	na	na	na
	WA125X		(blank)	na	no acm	na	na	na
	WA126		Classroom	na	no acm	na	na	na
	WA126A		Office	na	no acm	na	na	na
	WA126B		Office	na	no acm	na	na	na
	WA127A		Office	na	no acm	na	na	na
	WA127B		Office	na	no acm	na	na	na
	WA127C		Office	na	no acm	na	na	na
	WA128		Classroom	na	no acm	na	na	na
	WA128A		Office	na	no acm	na	na	na
	WA128B		Laboratory	na	no acm	na	na	na
	WA128C		Laboratory	na	no acm	na	na	na
	WA129		(blank)	na	no acm	na	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WA129A		(blank)	na	no acm	na	na	na
	WA129B		(blank)	na	no acm	na	na	na
	WA129C		(blank)	na	no acm	na	na	na
	WA129D		(blank)	na	no acm	na	na	na
	WA130		(blank)	na	no acm	na	na	na
	WA130A		(blank)	na	no acm	na	na	na
	WA130B		(blank)	na	no acm	na	na	na
	WA130C		(blank)	na	no acm	na	na	na
	WA130D		(blank)	na	no acm	na	na	na
	WA130E		(blank)	na	no acm	na	na	na
	WA130F		(blank)	na	no acm	na	na	na
	WA130G		(blank)	na	no acm	na	na	na
	WA131		(blank)	na	no acm	na	na	na
	WA131SC		(blank)	na	no acm	na	na	na
	WA131A		(blank)	na	no acm	na	na	na
	WA131B		(blank)	na	no acm	na	na	na
	WA131C		(blank)	na	no acm	na	na	na
	WA131D		(blank)	na	no acm	na	na	na
	WA131E		(blank)	na	no acm	na	na	na
	WA131F		(blank)	na	no acm	na	na	na
	WA131G		(blank)	na	no acm	na	na	na
	WA131H		(blank)	na	no acm	na	na	na
	WA131J		(blank)	na	no acm	na	na	na
	WA132		(blank)	na	no acm	na	na	na
	WA132A		(blank)	27	plaster	Negative	na	na
				28	plaster	Negative	na	na
				29	plaster	Negative	na	na
	WA132B		(blank)	na	no acm	na	na	na
	WA132C		(blank)	na	no acm	na	na	na
	WA132D		(blank)	na	no acm	na	na	na
	WA132E		(blank)	na	no acm	na	na	na
	WA133		(blank)	13	drywall compound	Positive	Chrysotile	Positive
				14	drywall compound	Positive Stop	Chrysotile	Positive Stop
				15	drywall compound	Positive Stop	Chrysotile	Positive Stop
				17	drywall compound	Positive Stop	Chrysotile	Positive Stop
	WA133A		(blank)	na	no acm	na	na	na
	WA133B		(blank)	na	no acm	na	na	na
	WA133C		(blank)	na	no acm	na	na	na
	WA134		(blank)	na	no acm	na	na	na
	WA134A		(blank)	na	no acm	na	na	na
	WA134B		(blank)	na	no acm	na	na	na
	WA134C		(blank)	na	no acm	na	na	na
	WA134D		(blank)	na	no acm	na	na	na
	WA134E		(blank)	na	no acm	na	na	na
	WA134F		(blank)	na	no acm	na	na	na
	WA134G		(blank)	na	no acm	na	na	na
	WA134L		(blank)	na	no acm	na	na	na
	WA135A		(blank)	na	no acm	na	na	na
	WA135B		(blank)	na	no acm	na	na	na
	WA135C		(blank)	na	no acm	na	na	na
	WA135D		(blank)	na	no acm	na	na	na
	WA136A		(blank)	na	no acm	na	na	na
	WA136B		(blank)	na	no acm	na	na	na
	WA136C		(blank)	na	no acm	na	na	na
	WA136D		(blank)	na	no acm	na	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments	
	WA137		Shop	A137-10a	ceiling tile	Negative	na	na	
				A137-10b	ceiling tile	Negative	na	na	
				A137-10c	ceiling tile	Negative	na	na	
				A137-11a	wall drywall joint compound	Negative	na	na	
				A137-11b	wall drywall joint compound	Negative	na	na	
				A137-11c	wall drywall joint compound	Negative	na	na	
	WA137A		(blank)		A137-1	grey/white ceiling tile	Negative	na	na
					A137-2	grey/white ceiling tile	Negative	na	na
					A137-3	grey/white ceiling tile	Negative	na	na
	WA138		(blank)		na	no acm	na	na	na
	WA138A		(blank)		na	no acm	na	na	na
	WA138C		(blank)		na	no acm	na	na	na
	WA139		(blank)		na	no acm	na	na	na
	WA139A		(blank)		na	no acm	na	na	na
	WA139B		(blank)		na	no acm	na	na	na
	WA139C		(blank)		na	no acm	na	na	na
	WA139D		(blank)		na	no acm	na	na	na
	WA140A			Classroom	na	no acm	na	na	na
	A140B		(blank)		na	no acm	na	na	na
	WA140C		(blank)		na	no acm	na	na	na
	WA140D		(blank)		na	no acm	na	na	na
	WA140E		(blank)		na	no acm	na	na	na
	WA140F		(blank)		na	no acm	na	na	na
	WA140G		(blank)		na	no acm	na	na	na
	WA140H	Previously 140A	(blank)		A140a-12a	ceiling tile	Positive	Chrysotile	Positive
					A140a-12b	ceiling tile	Positive Stop	Chrysotile	Positive Stop
					A140a-12c	ceiling tile	Positive Stop	Chrysotile	Positive Stop
					A190b-4a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
					A140a-13a	wall drywall joint compound	Negative	na	na
					A140a-13b	wall drywall joint compound	Negative	na	na
					A140a-13c	wall drywall joint compound	Negative	na	na
	WA141			Shop	A141-10a	black mastic	Negative	na	na
						grey vinyl floor tile - white	Negative	na	na
					A141-10b	black mastic	Positive	Chrysotile	Positive
						grey vinyl floor tile - white	Negative	na	na
					A141-10c	black mastic	Negative	na	na
						grey vinyl floor tile - white	Negative	na	na
					A141-6a	ceiling tile	Negative	na	na
					A141-6b	ceiling tile	Negative	na	na
					A141-6c	ceiling tile	Negative	na	na
					A141-6d	ceiling tile	Negative	na	na
					A141-6e	ceiling tile	Negative	na	na
					A141-7a	wall drywall joint compound	Negative	na	na
					A141-7b	wall drywall joint compound	Negative	na	na
					A141-7c	wall drywall joint compound	Negative	na	na
					A141-8a	black baseboard	Negative	na	na
						cream mastic	Negative	na	na
A141-8b					black baseboard	Negative	na	na	
					cream mastic	Negative	na	na	
A141-8c					black baseboard	Negative	na	na	
					cream mastic	Negative	na	na	
A141-9a	blue mastic	Positive	Chrysotile	Positive					
	blue vinyl floor tile	Positive	Chrysotile	Positive					
A141-9b	blue vinyl floor tile and mastic	Positive Stop	Chrysotile	Positive Stop					
A141-9c	blue vinyl floor tile and mastic	Positive Stop	Chrysotile	Positive Stop					

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments	
	WA141A		(blank)	na	na	no acm	no acm	na	
	WA141B		Storage	A141-9a	blue mastic	Positive	Chrysotile	Positive	
					blue vinyl floor tile	Positive	Chrysotile	Positive	
					A141-9b	blue vinyl floor tile and mastic	Positive Stop	Chrysotile	Positive Stop
					A141-9c	blue vinyl floor tile and mastic	Positive Stop	Chrysotile	Positive Stop
	WA142		Classroom	na	no acm	na	na	na	
	WA142A		Storage	na	no acm	na	na	na	
	WA142B		Classroom	na	no acm	na	na	na	
	WA143A		Office	na	no acm	na	na	na	
	WA143B		Office	na	no acm	na	na	na	
	WA143C		Office	na	no acm	na	na	na	
	WA143D		Office	na	no acm	na	na	na	
	WA143E		Office	na	no acm	na	na	na	
	WA143F		Office	na	no acm	na	na	na	
	WA143G		Office	na	no acm	na	na	na	
	WA143SC		Office	na	no acm	na	na	na	
	WA143J		Studio	na	no acm	na	na	na	
	WA143K		Studio	na	no acm	na	na	na	
	WA143L		Studio	na	no acm	na	na	na	
	WA144		Office	na	no acm	na	na	na	
	WA144A		Office	na	no acm	na	na	na	
	WA144B		Office	na	no acm	na	na	na	
	WA145CC1		Entrance to WA145	na	no acm	na	na	na	
	WA145CC2		Hallway to WA145 and 147	na	no acm	na	na	na	
	WA145A		(blank)	na	no acm	na	na	na	
	WA145B		(blank)	na	no acm	na	na	na	
	WA145C		(blank)	na	no acm	na	na	na	
	WA145D		(blank)	na	no acm	na	na	na	
	WA145E		(blank)	na	no acm	na	na	na	
	WA145F		(blank)	na	no acm	na	na	na	
	WA145G		(blank)	na	no acm	na	na	na	
	WA145H		(blank)	na	no acm	na	na	na	
	WA145J		(blank)	na	no acm	na	na	na	
	WA145K		(blank)	na	no acm	na	na	na	
	WA145L		(blank)	na	no acm	na	na	na	
	WA145Q		(blank)	na	no acm	na	na	na	
	WA145V		(blank)	na	no acm	na	na	na	
	WA145W		(blank)	na	no acm	na	na	na	
	WA146		(blank)	na	no acm	na	na	na	
	WA146A		(blank)	na	no acm	na	na	na	
	WA146B		(blank)	na	no acm	na	na	na	
	WA147A		(blank)	na	no acm	na	na	na	
	WA147B		(blank)	na	no acm	na	na	na	
	WA147C		(blank)	na	no acm	na	na	na	
	WA147D		(blank)	na	no acm	na	na	na	
	WA147E		(blank)	na	no acm	na	na	na	
	WA147F		(blank)	na	no acm	na	na	na	
	WA147G		(blank)	na	no acm	na	na	na	
	WA147H		(blank)	na	no acm	na	na	na	
	WA147J		(blank)	na	no acm	na	na	na	
	WA147K		(blank)	na	no acm	na	na	na	
	WA147L		(blank)	na	no acm	na	na	na	
	WA147M		(blank)	na	no acm	na	na	na	
	WA147N		(blank)	na	no acm	na	na	na	
	WA148		Classroom	na	no acm	na	na	na	

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WA149		Storage	AC-WA-ASB-03-A	vinyl floor tile	Positive	Chrysotile	Positive
				AC-WA-ASB-03-B	vinyl floor tile	Positive Stop	Chrysotile	Positive Stop
				AC-WA-ASB-03-C	vinyl floor tile	Positive Stop	Chrysotile	Positive Stop
	WA150		Office	WA158-001a	grey/white specks vinyl floor tile	Positive	Chrysotile	Positive
				WA158-001b	grey/white specks vinyl floor tile	Positive Stop	Chrysotile	Positive Stop
				WA158-001c	grey/white specks vinyl floor tile	Positive Stop	Chrysotile	Positive Stop
				WA150-001a	pipe elbow	Positive	Chrysotile	Positive
				WA150-001b	pipe elbow	Positive Stop	Chrysotile	Positive Stop
				WA150-001c	pipe elbow	Positive Stop	Chrysotile	Positive Stop
	WA151		(blank)	WA151-001a	Grey Pipe Insulation	Positive	Chrysotile	Removed
	WA151A		(blank)	na	no acm	na	na	na
	WA151B		(blank)	na	no acm	na	na	na
	WA158		Office	WA158-001a	vinyl floor tile	Positive	Chrysotile	Positive
				WA158-001c	vinyl floor tile	Positive Stop	Chrysotile	Positive Stop
				WA158-001b	vinyl floor tile	Positive Stop	Chrysotile	Positive Stop
				WA151-001c	Grey Pipe Insulation	Positive	Chrysotile	Removed
	WA158A		Office	WA158-001a	vinyl floor tile	Positive	Chrysotile	Positive
				WA158-001c	vinyl floor tile	Positive Stop	Chrysotile	Positive Stop
				WA158-001b	vinyl floor tile	Positive Stop	Chrysotile	Positive Stop
				WA113-001a	Pipe Elbow Insulation (grey/white)	Positive	Chrysotile	Positive
				WA113-001b	Pipe Elbow Insulation (grey/white)	Positive Stop	Chrysotile	Positive Stop
	WA158B		Office	WA105A-001A	vinyl floor tile	Positive	Chrysotile	Positive
				WA105A-001B	vinyl floor tile	Positive Stop	Chrysotile	Positive Stop
				WA105A-001C	vinyl floor tile	Positive Stop	Chrysotile	Positive Stop
				WA105A-001A	Black Mastic	Positive	Chrysotile	Positive
				WA105A-001B	Black Mastic	Positive Stop	Chrysotile	Positive Stop
				WA105A-001C	Black Mastic	Positive Stop	Chrysotile	Positive Stop
	WA158C		Office	WA105A-001A	vinyl floor tile	Positive	Chrysotile	Positive
				WA105A-001B	vinyl floor tile	Positive Stop	Chrysotile	Positive Stop
WA105A-001C				vinyl floor tile	Positive Stop	Chrysotile	Positive Stop	
WA105A-001A				Black Mastic	Positive	Chrysotile	Positive	
WA105A-001B				Black Mastic	Positive Stop	Chrysotile	Positive Stop	
WA105A-001C				Black Mastic	Positive Stop	Chrysotile	Positive Stop	
WA158D		Office	WA105A-001A	vinyl floor tile	Positive	Chrysotile	Positive	
			WA105A-001B	vinyl floor tile	Positive Stop	Chrysotile	Positive Stop	
			WA105A-001C	vinyl floor tile	Positive Stop	Chrysotile	Positive Stop	
			WA105A-001A	Black Mastic	Positive	Chrysotile	Positive	
			WA105A-001B	Black Mastic	Positive Stop	Chrysotile	Positive Stop	
			WA105A-001C	Black Mastic	Positive Stop	Chrysotile	Positive Stop	
WA158E		(blank)	na	no acm	na	na	na	
WA158F		(blank)	na	no acm	na	na	na	
WA158G		(blank)	na	no acm	na	na	na	
WA158EE		(blank)	na	no acm	na	na	na	
WA158VS		(blank)	na	no acm	na	na	na	
WA159		Office	WA105A-001A	vinyl floor tile	Positive	Chrysotile	Positive	
			WA105A-001B	vinyl floor tile	Positive Stop	Chrysotile	Positive Stop	
			WA105A-001C	vinyl floor tile	Positive Stop	Chrysotile	Positive Stop	
			WA105A-001A	Black Mastic	Positive	Chrysotile	Positive	
			WA105A-001B	Black Mastic	Positive Stop	Chrysotile	Positive Stop	
			WA105A-001C	Black Mastic	Positive Stop	Chrysotile	Positive Stop	
WA169		(blank)	na	no acm	na	na	na	
WA170		Observatory	na	no acm	na	na	na	
WA170A		Storage	na	no acm	na	na	na	
WA170B		Office	na	no acm	na	na	na	

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WA170EE		Electrical Room	na	no acm	na	na	na
	WA170SC		Washroom Entrance	na	no acm	na	na	na
	WA171		Freezer Area	na	no acm	na	na	na
	WA171A		Walk-in Fridge	na	no acm	na	na	na
	WA173		Men's Washroom	na	no acm	na	na	na
	WA174		Women's Washroom	na	no acm	na	na	na
	WA175		Dish Pit	na	no acm	na	na	na
	WA176		Food Service	na	no acm	na	na	na
	WA176A		Office	na	no acm	na	na	na
	WA176B		HVAC	na	no acm	na	na	na
	WA178		Staff Room	na	no acm	na	na	na
	WA178A		Staff Room Washroom	na	no acm	na	na	na
	WA179		Electrical Room	na	no acm	na	na	na
	WA180		Kitchen	na	no acm	na	na	na
	WA180A		Storage	na	no acm	na	na	na
	WA181		Art Classroom	WA181-001a	Pipe Elbow Insulation	Positive	Chrysotile	Positive
				WA181-001b	Pipe Elbow Insulation	Positive Stop	Chrysotile	Positive Stop
				WA181-001c	Pipe Elbow Insulation	Positive Stop	Chrysotile	Positive Stop
	WA181A		Storage	na	no acm	na	na	na
	WA181B		Office	na	no acm	na	na	na
	WA182		(blank)	na	no acm	na	na	na
	WA182A		(blank)	na	no acm	na	na	na
	WA183		Loading/Receiving Bay	A183-PJ-a	Pipe Elbow (White)	Positive	Chrysotile, Amosi	Positive
	WA190		Innovation Centre	A190b-1a	cream ceiling stipple	Negative	na	na
				A190b-1b	cream ceiling stipple	Negative	na	na
				A190b-1c	cream ceiling stipple	Negative	na	na
				A190b-2a	brown/cream wall drywall joint com	Negative	na	na
				A190b-2b	brown/cream wall drywall joint com	Negative	na	na
				A190b-2c	brown/cream wall drywall joint com	Negative	na	na
				A190b-3a	black baseboard	Negative	na	na
					brown mastic	Negative	na	na
				A190b-3b	black baseboard	Negative	na	na
					brown mastic	Negative	na	na
				A190b-3c	black baseboard	Negative	na	na
					brown mastic	Negative	na	na
				A190e-7a	mastic	Negative	na	na
					vinyl floor tile	Positive	Chrysotile	Removed
				A190e-7b	mastic	Negative	na	na
				A190e-7c	mastic	Negative	na	na
	WA190A		Shipping/Receiving	A190A-002a	vinyl floor tile	Positive	Chrysotile	Positive
				A190A-002b	vinyl floor tile	Positive Stop	Chrysotile	Positive Stop
	WA190B		Mail Services	A190-4a	vinyl floor tile	Positive	Chrysotile	Positive
				A190-4b	vinyl floor tile	Positive Stop	Chrysotile	Positive Stop
	WA190C		Publishing	A190-4a	vinyl floor tile	Positive	Chrysotile	Positive
				A190-4b	vinyl floor tile	Positive Stop	Chrysotile	Positive Stop
	WA190D		(blank)	A190b-1a	cream ceiling stipple	Negative	na	na
				A190b-1b	cream ceiling stipple	Negative	na	na
				A190b-1c	cream ceiling stipple	Negative	na	na
				A190b-2a	brown/cream wall drywall joint com	Negative	na	na
				A190b-2b	brown/cream wall drywall joint com	Negative	na	na
				A190b-2c	brown/cream wall drywall joint com	Negative	na	na
				A190b-3a	black baseboard	Negative	na	na
					brown mastic	Negative	na	na
				A190b-3b	black baseboard	Negative	na	na
					brown mastic	Negative	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
				A190b-3c	black baseboard	Negative	na	na
					brown mastic	Negative	na	na
				A190d-5a	carpet	Negative	na	na
				A190d-5b	carpet	Negative	na	na
				A190d-5c	carpet	Negative	na	na
				A190d-6a	mastic	Negative	na	na
					vinyl floor tile	Negative	na	na
				A190d-6b	mastic	Negative	na	na
					vinyl floor tile	Negative	na	na
				A190d-6c	mastic	Negative	na	na
					vinyl floor tile	Negative	na	na
	WA190E		(blank)	no	no acm	na	na	na
	WA190F		(blank)	no	no acm	na	na	na
	WA190G		(blank)	no	no acm	na	na	na
	WA190H		(blank)	no	no acm	na	na	na
	WA190J		(blank)	no	no acm	na	na	na
	WA190L		IT Closet	A190-4a	Vinyl Floor Tile	Positive	Chrysotile	Positive
	WA190M		Shipping/Receiving Office	no	no acm	na	na	na
	WA190SC	Previously A190K	Publishing Hallway	no	no acm	na	na	na
	WA191		Office	na	Refurbished 2016	no acm	na	na
	WA191A		Kitchen	na	Refurbished 2016	no acm	na	na
	WA191B		Office	na	Refurbished 2016	no acm	na	na
	WA191C		Office	na	Refurbished 2016	no acm	na	na
	WA191D		Office	na	Refurbished 2016	no acm	na	na
	WA191E		Office	A191E-11a	ceiling drywall joint compound	Positive	Chrysotile	Removed
A191E-11b				ceiling drywall joint compound	Positive	Chrysotile	Removed	
A191E-11c				STOP POSITIVE	Positive Stop	na	Removed	
A191E-12a				ceiling tile	Negative	na	na	
A191E-12b				ceiling tile	Negative	na	na	
A191E-12c				ceiling tile	Negative	na	na	
na				floor carpet	no acm	na	na	
	WA191F		(blank)	no	no acm	na	na	na
	WA191SS1		(blank)	no	no acm	na	na	na
	WA191SC1		(blank)	no	no acm	na	na	na
	WA191SC2		(blank)	no	no acm	na	na	na
	WA191SC3		(blank)	no	no acm	na	na	na
	WA191SC4		(blank)	no	no acm	na	na	na
	WA192		Control Room	na	Refurbished 2016	no acm	na	na
	WA192A		(blank)	na	Refurbished 2016	no acm	na	na
	WA192B		(blank)	na	Refurbished 2016	no acm	na	na
	WA200LS1		Hall Study Pods	no	no acm	na	na	na
	WA200LS2		Hall Study Pods	no	no acm	na	na	na
	WA200LS3		Hall Study Pods	no	no acm	na	na	na
	WA200SS1		Staircase	no	no acm	na	na	na
	WA200SS2		Staircase	no	no acm	na	na	na
	WA200SS3		Staircase	no	no acm	na	na	na
	WA200SS4		Staircase	no	no acm	na	na	na
	WA200CC1		Hallway Adjacent to A219	no	no acm	na	na	na
	WA200CC2		Hallway Adjacent to A210	no	no acm	na	na	na
	WA200CC3		Hallway Adjacent to A226	no	no acm	na	na	na
	WA200CC4		Hallway Parallel to A200LS1	no	no acm	na	na	na
	WA200CC5		Hallway Parallel to A200LS2	no	no acm	na	na	na
	WA200CC6		Hallway Connecting to Building B	no	no acm	na	na	na
	WA200CC7		Hallway Adjacent to A204	no	no acm	na	na	na
	WA200CC8		Hallway Adjacent to A200A	no	no acm	na	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments	
	WA200A		Men's Washroom	124	plaster	Negative	na	na	
				125	plaster	Negative	na	na	
				126	plaster	Negative	na	na	
				127	plaster	Negative	na	na	
				128	plaster	Negative	na	na	
	WA200B		Women's Washroom	no	no acm	na	na	na	
	WA201			Wheelchair Storage	25-07-06-1a	plaster	Negative	na	na
					25-07-06-1b	plaster	Negative	na	na
					25-07-06-1c	plaster	Negative	na	na
					25-07-06-2a	ceiling tile	Negative	na	na
					25-07-062b	ceiling tile	Negative	na	na
					25-07-062c	ceiling tile	Negative	na	na
					25-07-06-3a	drywall compound	Negative	na	na
					25-07-06-3b	drywall compound	Negative	na	na
					25-07-06-3c	drywall compound	Negative	na	na
					25-07-06-4a	baseboard	Negative	na	na
						mastic	Negative	na	na
					25-07-06-4b	baseboard	Negative	na	na
						mastic	Negative	na	na
					25-07-06-4c	baseboard	Negative	na	na
						mastic	Negative	na	na
					25-07-06-5a	mastic	Negative	na	na
						vinyl tile	Positive	Chrysotile	Positive
					25-07-06-5b	mastic	Negative	na	na
					25-07-06-5c	mastic	Negative	na	na
	WA202	Previously A203A	(blank)	108	ceiling tile	Negative	na	na	
				109	ceiling tile	Negative	na	na	
				110	ceiling tile	Negative	na	na	
				111	ceiling tile	Negative	na	na	
				112	ceiling tile	Negative	na	na	
				113	plaster	Negative	na	na	
				114	plaster	Negative	na	na	
				115	plaster	Negative	na	na	
				119	plaster	Negative	na	na	
				120	plaster	Negative	na	na	
				121	baseboard	Negative	na	na	
					mastic	Negative	na	na	
				122	baseboard	Negative	na	na	
					mastic	Negative	na	na	
				123	baseboard	Negative	na	na	
					mastic	Negative	na	na	
				124	baseboard	Negative	na	na	
					mastic	Negative	na	na	
				125	baseboard	Negative	na	na	
					mastic	Negative	na	na	
				126	baseboard	Negative	na	na	
					mastic	Negative	na	na	
				136	ceiling tile	Negative	na	na	
				137	ceiling tile	Negative	na	na	
				138	ceiling tile	Negative	na	na	
139				plaster	Negative	na	na		
140	plaster	Negative	na	na					
141	plaster	Negative	na	na					
142	baseboard	Negative	na	na					
	mastic	Negative	na	na					

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
				143	baseboard	Negative	na	na
					mastic	Negative	na	na
				144	baseboard	Negative	na	na
					mastic	Negative	na	na
				145	baseboard	Negative	na	na
					mastic	Negative	na	na
				146	baseboard	Negative	na	na
					mastic	Negative	na	na
				147	baseboard	Negative	na	na
					mastic	Negative	na	na
				148	floor tile	Negative	na	na
					mastic	Positive	Chrysotile	Removed
				149	floor tile	Negative	na	na
					mastic	Negative	na	na
				150	floor tile	Negative	na	na
					mastic	Positive	Chrysotile	Removed
				156	plaster	Negative	na	na
				157	plaster	Negative	na	na
WA202A		(blank)		na	no acm	na	na	na
WA202B		(blank)		na	no acm	na	na	na
WA202C		(blank)		na	no acm	na	na	na
WA202D		(blank)		na	no acm	na	na	na
WA203Acc			Corridor between A203A, A211A, A21	108	ceiling tile	Negative	na	na
				109	ceiling tile	Negative	na	na
				110	ceiling tile	Negative	na	na
				111	ceiling tile	Negative	na	na
				112	ceiling tile	Negative	na	na
WA204		(blank)		na	no acm	na	na	na
WA204A		(blank)		na	no acm	na	na	na
WA204B		(blank)		na	no acm	na	na	na
WA205		Classroom		na	no acm	na	na	na
WA206		Office		na	no acm	na	na	na
WA207		(blank)		na	no acm	na	na	na
WA207A		(blank)		na	no acm	na	na	na
WA207B		(blank)		na	no acm	na	na	na
WA207C		(blank)		na	no acm	na	na	na
WA208			Office	151	ceiling tile	Negative	na	na
				152	ceiling tile	Negative	na	na
				153	ceiling tile	Negative	na	na
				154	ceiling tile	Negative	na	na
				155	ceiling tile	Negative	na	na
				159	baseboard	Negative	na	na
					mastic	Negative	na	na
				160	baseboard	Negative	na	na
					mastic	Negative	na	na
				161	baseboard	Negative	na	na
					mastic	Negative	na	na
				162	floor tile	Negative	na	na
					mastic	Negative	na	na
				163	floor tile	Negative	na	na
					mastic	Negative	na	na
				164	floor tile	Negative	na	na
					mastic	Negative	na	na
				165	floor tile	Negative	na	na
					mastic	Negative	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
				166	floor tile	Negative	na	na
					mastic	Negative	na	na
				167	floor tile	Negative	na	na
					mastic	Negative	na	na
	WA208A		Office	na	no acm	na	na	na
	WA208B		Office	na	no acm	na	na	na
	WA208C		Office	na	no acm	na	na	na
	WA208D		Office	na	no acm	na	na	na
	WA209		(blank)	A209-10a	baseboard	Negative	na	na
					mastic	Negative	na	na
				A209-10b	baseboard	Negative	na	na
					mastic	Negative	na	na
				A209-10c	baseboard	Negative	na	na
					mastic	Negative	na	na
				A209-11a	floor tile	Negative	na	na
					mastic	Negative	na	na
				A209-11b	floor tile	Negative	na	na
					mastic	Negative	na	na
				A209-11c	floor tile	Negative	na	na
					mastic	Negative	na	na
				A209-9a	wall plaster - grey	Negative	na	na
					wall plaster - white	Negative	na	na
				A209-9b	wall plaster - grey	Negative	na	na
					wall plaster - white	Negative	na	na
				A209-9c	wall plaster - grey	Negative	na	na
					wall plaster - white	Negative	na	na
	WA210		Classroom	na	no acm	na	na	na
	WA210A		Office	na	no acm	na	na	na
	WA211		Classroom	108	ceiling tile	Negative	na	na
				109	ceiling tile	Negative	na	na
				110	ceiling tile	Negative	na	na
				111	ceiling tile	Negative	na	na
				112	ceiling tile	Negative	na	na
	WA212		Classroom	A212-16a	grey/white ceiling tile	Negative	na	na
				A212-16b	grey/white ceiling tile	Negative	na	na
				A212-16c	grey/white ceiling tile	Negative	na	na
				A212-17a	black mastic	Positive	Chrysotile	
					grey vinyl tile	Positive	Chrysotile	
				A212-17b	grey vinyl tile and mastic	Positive Stop	na	
				A212-17c	grey vinyl tile and mastic	Positive Stop	na	
				A212-18a	black mastic	Positive	Chrysotile	
					yellow vinyl floor tile	Positive	Chrysotile	
				A212-18b	black mastic	Positive	Chrysotile	
				A212-18c	yellow vinyl floor tile and mastic	Positive Stop	na	
	WA213		Classroom	WA212-001a	black mastic	Positive	Chrysotile	
					yellow vinyl floor tile	Positive	Chrysotile	
	WA214		Office	WA212-001a	black mastic	Positive	Chrysotile	
					yellow vinyl floor tile	Positive	Chrysotile	
				WA149-001a	Light Brown Vinyl Floor Tile	Positive	Chrysotile	Positive
	WA214A		Storage	na	no acm	na	na	na
	WA214B		Office	na	no acm	na	na	na
	WA214C		Office	WA149-001a	Light Brown Vinyl Floor Tile	Positive	Chrysotile	Positive
	WA214D		Storage	WA149-001a	Light Brown Vinyl Floor Tile	Positive	Chrysotile	Positive
	WA215		Classroom	na	no acm	na	na	na
	WA216		Classroom	na	no acm	na	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WA217		Classroom	na	no acm	na	na	na
	WA219		Classroom	na	no acm	na	na	na
	WA221		Exercise Room	na	no acm	na	na	na
	WA221A		Washroom	na	no acm	na	na	na
	WA221B		Storage	na	no acm	na	na	na
	WA222		Office	na	no acm	na	na	na
	WA222A		Office	na	no acm	na	na	na
	WA222SC		Athletics Entramce	na	no acm	na	na	na
	WA222SS1		Staircase beside WA223A	na	no acm	na	na	na
	WA222SS2		Staircase adjacent to WA223D	na	no acm	na	na	na
	WA223		Exercise Room/Athletics	na	Refurbished	No acm	na	na
	WA223A		VolleyBall Office	na	Refurbished	No acm	na	na
	WA223B		Meeting Room	na	Refurbished	No acm	na	na
	WA223C		MultiMedia Meeting Room	na	Refurbished	No acm	na	na
	WA223D		Basketball Office	na	Refurbished	No acm	na	na
	WA223E		Storage	na	Refurbished	No acm	na	na
	WA225		Fitness Room	na	no acm	na	na	na
	WA225A		Janitorial Closet	na	no acm	na	na	na
	WA226		IT Closet	1	ceiling tile	Negative	na	na
				2	ceiling tile	Negative	na	na
				3	ceiling tile	Negative	na	na
				4	drywall compound	Negative	na	na
				5	drywall compound	Negative	na	na
				6	drywall compound	Negative	na	na
				168	ceiling tile	Negative	na	na
				169	ceiling tile	Negative	na	na
				170	ceiling tile	Negative	na	na
				171	drywall compound	Negative	na	na
				172	drywall compound	Negative	na	na
				173	drywall compound	Negative	na	na
	WA226cc		Corridor	174	ceiling tile	Negative	na	na
				175	ceiling tile	Negative	na	na
				176	ceiling tile	Negative	na	na
				177	ceiling tile	Negative	na	na
				178	ceiling tile	Negative	na	na
				179	ceiling tile	Negative	na	na
	WA229A		Office	na	no acm	na	na	na
	WA229B		Office	na	no acm	na	na	na
	WA229C		Office	na	no acm	na	na	na
	WA229D		Office	na	no acm	na	na	na
	WA229E		Office	na	no acm	na	na	na
	WA229F		Office	na	no acm	na	na	na
	WA229G		Office	na	no acm	na	na	na
	WA229H		Office	na	no acm	na	na	na
	WA229SC		Hallway adjacent to A229A-H	na	no acm	na	na	na
	WA229SS1		Stairway Adjacent to A229A	na	no acm	na	na	na
	WA229SS2		Stairway Adjacent to A229G	na	no acm	na	na	na
	WA250		Main Electrical Room	na	no acm	na	na	na
	WA250A		Storage Room	na	no acm	na	na	na
	WB000SS1		Stairwell	na	no acm	na	na	na
	WB000SS2		Stairwell	na	no acm	na	na	na
	WB000SS3		Stairwell	na	no acm	na	na	na
	WB000SS4		Stairwell	na	no acm	na	na	na
	WB001		Basement Hallway	na	no acm	na	na	na
	WB001A		Storage	na	no acm	na	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WB001B		Storage	na	no acm	na	na	na
	WB001C		Storage	na	no acm	na	na	na
	WB001D		Storage	na	no acm	na	na	na
	WB001E		Storage	na	no acm	na	na	na
	WB001F		Storage	na	no acm	na	na	na
	WB001G		Storage	na	no acm	na	na	na
	WB001H		Storage	na	no acm	na	na	na
	WB002		Storage	na	no acm	na	na	na
	WB003		Storage	na	no acm	na	na	na
	WB004		Storage	na	no acm	na	na	na
	WB004A		Storage	na	no acm	na	na	na
	WB005	WA005 on CAD Draw	Storage	na	no acm	na	na	na
	WB006		(blank)	na	no acm	na	na	na
	WB1		Hallway, access door	HALL-15a	ceiling stipple	Negative	na	na
	WB100CC1		Hallway from B150 - B100SS6	na	no acm	na	na	na
	WB100CC2		Hallway from B165 - B100BARAMP	na	no acm	na	na	na
	WB100CC3		Corridor from B167 - B168	na	no acm	na	na	na
	WB100CC4		Hallway from B170 - B187	na	no acm	na	na	na
	WB100CC5		Corridor from B180- B181	na	no acm	na	na	na
	WB100CC6		Hallway from B100SS5 - B186	na	no acm	na	na	na
	WB100CC7		Corridor B112A - B115D	WB457-001a	Tar on Duct Insulation	Positive	Chrysotile	Positive
				WB457-001b	Tar on Duct Insulation	Positive Stop	Chrysotile	Positive Stop
				WB457-001c	Tar on Duct Insulation	Positive Stop	Chrysotile	Positive Stop
	WB100CC8		Hallway Outside WB119	AC-WB1-ASB-01-A	ceiling stipple	Positive	Chrysotile	Positive
				AC-WB1-ASB-01-B	ceiling stipple	Positive Stop	Chrysotile	Positive Stop
				AC-WB1-ASB-01-C	ceiling stipple	Positive Stop	Chrysotile	Positive Stop
				AC-WB1-ASB-01-D	ceiling stipple	Positive Stop	Chrysotile	Positive Stop
				AC-WB1-ASB-01-E	ceiling stipple	Positive Stop	Chrysotile	Positive Stop
	WB100CC9		Corridor B122A - B125D	WB457-001a	Tar on Duct Insulation	Positive	Chrysotile	Positive
				WB457-001b	Tar on Duct Insulation	Positive Stop	Chrysotile	Positive Stop
				WB457-001c	Tar on Duct Insulation	Positive Stop	Chrysotile	Positive Stop
				162	ceiling stipple	Positive	Chrysotile	Positive
				163	ceiling stipple	Positive	Chrysotile	Positive
				164	ceiling stipple	Positive Stop	Chrysotile	Positive Stop
	WB100CC10		Corridor B112A - B115D	WB457-001a	Tar on Duct Insulation	Positive	Chrysotile	Positive
				WB457-001b	Tar on Duct Insulation	Positive Stop	Chrysotile	Positive Stop
				WB457-001c	Tar on Duct Insulation	Positive Stop	Chrysotile	Positive Stop
	WB100CC11		Corridor B134A - B137D	WB457-001a	Tar on Duct Insulation	Positive	Chrysotile	Positive
				WB457-001b	Tar on Duct Insulation	Positive Stop	Chrysotile	Positive Stop
				WB457-001c	Tar on Duct Insulation	Positive Stop	Chrysotile	Positive Stop
	WB100CC7		Corridor B112A - B115D	WB457-001a	Tar on Duct Insulation	Positive	Chrysotile	Positive
				WB457-001b	Tar on Duct Insulation	Positive Stop	Chrysotile	Positive Stop
				WB457-001c	Tar on Duct Insulation	Positive Stop	Chrysotile	Positive Stop
	WB100CC13		Corridor B144A - B147D	WB457-001a	Tar on Duct Insulation	Positive	Chrysotile	Positive
				WB457-001b	Tar on Duct Insulation	Positive Stop	Chrysotile	Positive Stop
				WB457-001c	Tar on Duct Insulation	Positive Stop	Chrysotile	Positive Stop
	WB100CC14		Hallway between B132 and B163	HALL-16a	pipe insulation	Positive	Chrysotile	Positive
				HALL-16b	pipe insulation	Positive Stop	na	Positive Stop
				HALL-16c	pipe insulation	Positive Stop	na	Positive Stop
			Hallway, access door	HALL-15b	ceiling stipple	Negative	na	na
				HALL-15c	ceiling stipple	Negative	na	na
	WB100ROTUNDA		Stage/Sitting Area	WB351cc-WB357cc-0	Red Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB351cc-WB357cc-0	Red Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
				WB351cc-WB357cc-0	Red Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
	WB100BARAMP		Ramp to A building	na	no acm	na	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WB100SS1		Stairwell	na	no acm	na	na	na
	WB100SS2		Stairwell	na	no acm	na	na	na
	WB100SS3		Stairwell	na	no acm	na	na	na
	WB100SS4		Stairwell	na	no acm	na	na	na
	WB100SS5		Stairwell	na	no acm	na	na	na
	WB100SS6		Stairwell	na	no acm	na	na	na
	WB100SS7		Stairwell	na	no acm	na	na	na
	WB100VS1		Ramp to Stairwell WB100SS1	na	no acm	na	na	na
	WB101		Janitor's Closet	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB102		(blank)	na	no acm	na	na	na
	WB102A		(blank)	na	no acm	na	na	na
	WB110		(blank)	na	no acm	na	na	na
	WB111		Classroom	na	no acm	na	na	na
	WB112A		Office	WB253-004a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB112B		Office	WB253-004a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB112C		Office	WB253-004a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB112D		Office	WB253-004a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB113		Storage	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB114		Office	na	no acm	na	na	na
	WB114S		Office	WB351cc-WB357cc-	Orange Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB115A		Office	WB253-004a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB115B		Office	WB253-004a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB115C		Office	WB253-004a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB115D		Office	WB253-004a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB116		Storage	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB117		(blank)	31	ceiling tile	Negative	na	na
				32	ceiling tile	Negative	na	na
				33	ceiling tile	Negative	na	na
				34	pipe fittings	Positive	Chrysotile	Removed
				35	pipe fittings	Positive	Chrysotile	Removed
				36	pipe fittings	Positive	Chrysotile	Removed
				37	floor tile	Negative	na	na
					mastic	Negative	na	na
				38	floor tile	Negative	na	na
					mastic	Negative	na	na
				39	floor tile	Negative	na	na
					mastic	Negative	na	na
	WB118		Washroom	WB457-001a	Tar on Duct Insulation	Positive	Chrysotile	Positive
	WB119		Classroom	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB120		Cafeteria	na	no acm	na	na	na
	WB121		Office	na	no acm	na	na	na
	WB122A		Office	WB253-004a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB122B		Office	WB253-004a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB122C		Office	WB253-004a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB122D		Office	WB253-004a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB123		IT Closet	na	no acm	na	na	na
	WB124		Office	na	no acm	na	na	na
	WB124S		Office	WB351cc-WB357cc-	Orange Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB125A		Office	WB253-004a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB125B		Office	WB253-004a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB125C		Office	WB253-004a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB125D		Office	WB253-004a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB126		Storage	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB127		Office	na	no acm	na	na	na
	WB127A		Office	na	no acm	na	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WB130		Classroom	WB327-001a	Silver Pipe Insulation	Positive	Chrysotile	Removed
	WB131		Women's Washroom	WB457-001a	Tar on Duct Insulation	Positive	Chrysotile	Positive
WB457-001b				Tar on Duct Insulation	Positive Stop	Chrysotile	Positive Stop	
WB457-001c				Tar on Duct Insulation	Positive Stop	Chrysotile	Positive Stop	
	WB132		Classroom	74	ceiling tile	Negative	na	na
75				ceiling tile	Negative	na	na	
76				ceiling tile	Negative	na	na	
77				drywall compound	Negative	na	na	
78				drywall compound	Negative	na	na	
79				drywall compound	Negative	na	na	
80				baseboard	Negative	na	na	
				mastic	Negative	na	na	
81				baseboard	Negative	na	na	
				mastic	Negative	na	na	
82				baseboard	Negative	na	na	
				mastic	Negative	na	na	
B132-17a				pipe insulation	Positive	Chrysotile	Removed	
B132-17b				pipe insulation	Positive Stop	Chrysotile	Removed	
B132-17c				pipe insulation	Positive Stop	Chrysotile	Removed	
B132-18a				ceiling tile	Negative	na	na	
B132-18b				ceiling tile	Negative	na	na	
B132-18c				ceiling tile	Negative	na	na	
B132-19a				wall drywall joint compound	Negative	na	na	
B132-19b				wall drywall joint compound	Negative	na	na	
B132-19c				wall drywall joint compound	Negative	na	na	
B132-20a				baseboard	Negative	na	na	
B132-20b				baseboard	Negative	na	na	
B132-20c				baseboard	Negative	na	na	
B132-21a				mastic	Negative	na	na	
				vinyl floor tile	Positive	Chrysotile	Positive	
B132-21b	mastic	Negative	na	na				
B132-21c	mastic	Negative	na	na				
	WB133		(blank)	150	ceiling tile	Negative	na	na
151				ceiling tile	Negative	na	na	
152				ceiling tile	Negative	na	na	
153				floor tile	Positive	Chrysotile	Positive	
				mastic	Negative	na	na	
154				mastic	Negative	na	na	
155				mastic	Negative	na	na	
156				floor tile	Positive	Chrysotile	Positive	
				mastic	Negative	na	na	
157				mastic	Negative	na	na	
158				mastic	Negative	na	na	
159				baseboard	Negative	na	na	
				mastic	Negative	na	na	
160				baseboard	Negative	na	na	
				mastic	Negative	na	na	
161	baseboard	Negative	na	na				
	mastic	Negative	na	na				
WB134A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
WB134B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
WB134C		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
WB134D		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB135		IT Room	B135-14a	mastic	Negative	na	na
				vinyl floor tile	Positive	Chrysotile	Positive	

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
				B135-14b	mastic	Negative	na	na
				B135-14c	mastic	Positive	Chrysotile	Positive
	WB136		Office	na	no acm	na	na	na
	WB136s		Office	WB351cc-WB357cc-	Orange Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB137A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB137B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB137C		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB137D		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB138		Storage	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB139		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB139A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB140		Classroom	na	no acm	na	na	na
	WB141		Men's Washroom	na	no acm	na	na	na
	WB142		Classroom	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB143		Classroom	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB144A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB144B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB144C		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB144D		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB145		Storage	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB146		Office	na	no acm	na	na	na
	WB146s		Office	WB351cc-WB357cc-	Orange Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB147A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB147B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB147C		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB147D		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB148		Storage	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB149		Classroom	na	no acm	na	na	na
	WB150		Janitors Closet	na	no acm	na	na	na
	WB152		Classroom	WB253-001a	grey pipe elbow	Positive	Chrysotile	Positive
				WB457-001a	black/yellow tar on duct insulatio	Positive	Chrysotile	Positive
	WB152B		Classroom Storage	na	no acm	na	na	na
	WB153		Storage	na	no acm	na	na	na
	WB156		Classroom	na	no acm	na	na	na
	WB157		Classroom	na	no acm	na	na	na
	WB157DS		Storage	na	no acm	na	na	na
	WB157ST		Storage	na	no acm	na	na	na
	WB158		Classroom	na	no acm	na	na	na
	WB159		Classroom	na	no acm	na	na	na
	WB160A		Men's Washroom	na	no acm	na	na	na
	WB160B		Women's Washroom	na	no acm	na	na	na
	WB161		Storage	na	no acm	na	na	na
	WB162		Health Care Supplies Storage	na	no acm	na	na	na
	WB163		Food Service Supples Storage	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB164		Classroom	66	unknown	Negative	na	na
				67	unknown	Negative	na	na
				68	unknown	Negative	na	na
	WB165		Classroom	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB166		Classroom	B166-15a	ceiling insulation board	Negative	na	na
				B166-15b	ceiling insulation board	Negative	na	na
				B166-15c	ceiling insulation board	Negative	na	na
				B166-16a	floor tile	Positive	Chrysotile	Positive
					mastic	Negative	na	na
				B166-16b	floor tile	Negative	na	na
				B166-16c	floor tile	Negative	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WB167		Electrical Room	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB168		Classroom	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB169		(blank)	na	no acm	na	na	na
	WB170		(blank)	na	no acm	na	na	na
	WB170A		Storage	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB171		(blank)	na	no acm	na	na	na
	WB180		(blank)	na	no acm	na	na	na
	WB181		IT Closet	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
WB457-001a				Tar on Duct Insulation	Positive	Chrysotile	Positive	
60				Grey Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop	
WB457-001a				Tar on Duct Insulation	Positive Stop	Chrysotile	Positive Stop	
	WB182		(blank)	na	no acm	na	na	na
	WB183		(blank)	na	no acm	na	na	na
	WB184		(blank)	na	no acm	na	na	na
	WB185		(blank)	na	no acm	na	na	na
	WB185SC		(blank)	na	no acm	na	na	na
	WB186		(blank)	na	no acm	na	na	na
	WB187		IT Closet	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB190		(blank)	na	no acm	na	na	na
	WB191		(blank)	na	no acm	na	na	na
	WB200CC1		Hallway between WB251 to WB267	WB457-001a	black/yellow tar on duct insulatio	Positive	Chrysotile	Positive
	WB200CC2		Hallway	na	no acm	na	na	na
	WB200CC3		Hallway	na	no acm	na	na	na
	WB200CC4		Hallway between WB268 to WB280	WB462Acc-WB453cc	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
WB462Acc-WB453cc				Green Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop	
WB457-001a				black/yellow tar on duct insulatio	Positive	Chrysotile	Positive	
	WB200CC5		Hallway	na	no acm	na	na	na
	WB200CC6		Hallway	na	no acm	na	na	na
	WB200CC7		Hallway between WB202 to WB291	WB462Acc-WB453cc	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
WB462Acc-WB453cc				Green Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop	
	WB200CC8	WB216CC	Corridor between B212A & B215D	BHALL-15	ceiling stucco	Negative	na	na
BHALL-16				ceiling stucco	Negative	na	na	
BHALL-17				ceiling stucco	Negative	na	na	
BHALL-18				ceiling stucco	Negative	na	na	
BHALL-19				ceiling stucco	Negative	na	na	
WB457-001a				black/yellow tar on duct insulatio	Positive	Chrysotile	Positive	
WB462Acc-WB453cc				Green Vinyl Floor Tile	Positive	Chrysotile	Positive	
WB462Acc-WB453cc	Green Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop				
	WB200CC9		Hallway	na	no acm	na	na	na
	WB200CC10		Corridor between B222A & B225D	WB462Acc-WB453cc	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
WB462Acc-WB453cc				Green Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop	
WB457-001a				black/yellow tar on duct insulatio	Positive	Chrysotile	Positive	
	WB200CC11		Hallway	na	no acm	na	na	na
	WB200CC12		Corridor between B234A & B237D	WB462Acc-WB453cc	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
WB462Acc-WB453cc				Green Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop	
WB457-001a				black/yellow tar on duct insulatio	Positive	Chrysotile	Positive	
	WB200CC13		Hallway	na	no acm	na	na	na
	WB200CC14		Corridor between B251 & B245	102	ceiling stipple	Negative	na	na
103				ceiling stipple	Negative	na	na	
104				ceiling stipple	Negative	na	na	
105				ceiling tile	Negative	na	na	
106				ceiling tile	Negative	na	na	
107				ceiling tile	Negative	na	na	
WB457-001a	black/yellow tar on duct insulatio	Positive	Chrysotile	Positive				
	WB200CC15		Hallway	na	no acm	na	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WB200CC16		Hallway	na	no acm	na	na	na
	WB200VS		Vestebule to ACCE Bridge	na	no acm	na	na	na
	WB200SS1		Stairwell	na	no acm	na	na	na
	WB200SS2		Stairwell	na	no acm	na	na	na
	WB200SS3		Stairwell	na	no acm	na	na	na
	WB200SS4		Stairwell	na	no acm	na	na	na
	WB200SS5		Stairwell	na	no acm	na	na	na
	WB200LS1		Sitting/Study Area	na	no acm	na	na	na
	WB200LS2		Sitting/Study Area	na	no acm	na	na	na
	WB200LS3		Sitting/Study Area	na	no acm	na	na	na
	WB200LS4		Sitting/Study Area	na	no acm	na	na	na
	WB200LS5		Sitting/Study Area	na	no acm	na	na	na
	WB200LS6		Sitting/Study Area	na	no acm	na	na	na
	WB200LS7		Sitting/Study Area	na	no acm	na	na	na
	WB200LS8		Sitting/Study Area	na	no acm	na	na	na
	WB200LS9		Sitting/Study Area	na	no acm	na	na	na
	WB200LS10		Sitting/Study Area	na	no acm	na	na	na
	WB201		(blank)	na	no acm	na	na	na
	WB202		(blank)	na	no acm	na	na	na
	WB210		(blank)	na	no acm	na	na	na
	WB210A		(blank)	na	no acm	na	na	na
	WB210B		(blank)	na	no acm	na	na	na
	WB210C		(blank)	na	no acm	na	na	na
	WB210D		(blank)	WB462Acc-WB453cc	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB211		(blank)	B211-12	ceiling tile	Negative	na	na
				B211-13	ceiling tile	Negative	na	na
				B211-14	ceiling tile	Negative	na	na
	WB212A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB212B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB212C		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB212D		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB213		(blank)	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB214		Office	na	no acm	na	na	na
	WB214S		Office	WB462Acc-WB453cc	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB215A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB215B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB215C		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB215D		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB216		Storage	B216-23	floor tile	Positive	Chrysotile	Positive
					mastic	Negative	na	na
				B216-24	floor tile	Negative	na	na
				B216-25	floor tile	Negative	na	na
	WB217		Office	na	no acm	na	na	na
	WB218		Men's Washroom	WB457-001a	black/yellow tar on duct insulatic	Positive	Chrysotile	Positive
	WB220		(blank)	83	ceiling tile	Negative	na	na
				84	ceiling tile	Negative	na	na
				85	ceiling tile	Negative	na	na
				86	ceiling tile	Negative	na	na
				87	ceiling tile	Negative	na	na
				60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB221		(blank)	51	ceiling tile	Negative	na	na
				52	ceiling tile	Negative	na	na
				53	ceiling tile	Negative	na	na
				60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB222A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments	
	WB222B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB222C		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB222D		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB223		IT Room	B223-20	floor tile	Positive	Chrysotile	Positive	
					mastic	Negative	na	na	
					B223-21	floor tile	Negative	na	na
					B223-22	floor tile	Negative	na	na
	WB224		Office	na	no acm	na	na	na	
	WB224S		Office	WB462Acc-WB453cc	Green Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB225A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB225B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB225C		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB225D		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB226		Storage	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB227		(blank)	93	ceiling tile	Negative	na	na	
					94	ceiling tile	Negative	na	na
					95	ceiling tile	Negative	na	na
					60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB231		Women's Washroom	WB457-001a	black/yellow tar on duct insulation	Positive	Chrysotile	Positive	
	WB232		Classroom	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB233		(blank)	150	ceiling tile	Negative	na	na	
					151	ceiling tile	Negative	na	na
					152	ceiling tile	Negative	na	na
					153	floor tile	Positive	Chrysotile	Positive
						mastic	Negative	na	na
						154	mastic	Negative	na
				155	mastic	Negative	na	na	
	WB234A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB234B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB234C		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB234D		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB235		(blank)	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB236		Office	na	no acm	na	na	na	
	WB236S		(blank)	57	ceiling stipple	Negative	na	na	
					58	ceiling stipple	Negative	na	na
					59	ceiling stipple	Negative	na	na
					WB462Acc-WB453cc	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB237A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB237B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB237C		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB237D		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB238		Storage	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB239		(blank)	54	ceiling tile	Negative	na	na	
					55	ceiling tile	Negative	na	na
					56	ceiling tile	Negative	na	na
	WB241		Men's Washroom	na	no acm	na	na	na	
	WB242		Classroom	na	no acm	na	na	na	
	WB243		(blank)	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB244A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB244B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB244C		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB244D		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB245		(blank)	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
	WB246		Office	na	no acm	na	na	na	
	WB246S		Office	WB462Acc-WB453cc	Green Vinyl Floor Tile	Positive	Chrysotile	Positive	

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WB247A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB247B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB247C		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB247D		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB248		(blank)	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB249		(blank)	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB250		Janitor's Closet	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB251		(blank)	19	ceiling spray-on	Negative	na	na
				20	ceiling spray-on	Negative	na	na
				21	ceiling spray-on	Negative	na	na
				35	ceilling tile	Negative	na	na
				36	ceilling tile	Negative	na	na
				37	ceilling tile	Negative	na	na
				38	ceilling tile	Negative	na	na
				39	ceilling tile	Negative	na	na
	WB251A		Storage	na	no acm	na	na	na
	WB251B		Office	na	no acm	na	na	na
	WB251C		Office	na	no acm	na	na	na
	WB253		Classroom	WB457-001a	black/yellow tar on duct insulatio	Positive	Chrysotile	Positive
				WB253-001a	Silver Pipe Elbow	Positive	Chrysotile	Positive
				WB253-004a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB255		Classroom	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB255A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB257		Classroom	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB457-001a	black/yellow tar on duct insulatio	Positive	Chrysotile	Positive
	WB257A		Office	na	no acm	na	na	na
	WB257B		Storage	na	no acm	na	na	na
	WB261		Classroom	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB261A		Storage	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB262		(blank)	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB264		Women's Washroom	na	no acm	na	na	na
	WB265		Janitor's Closet	na	no acm	na	na	na
	WB267		Classroom	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB268		Classroom	na	no acm	na	na	na
	WB270		Lecture Room	na	no acm	na	na	na
	WB270A		(blank)	1	drywall compound	Negative	na	na
				2	drywall compound	Negative	na	na
				3	drywall compound	Negative	na	na
				185	drywall compound	Negative	na	na
				186	drywall compound	Negative	na	na
				187	drywall compound	Negative	na	na
	WB280		Storage	na	no acm	na	na	na
	WB282		(blank)	na	no acm	na	na	na
	WB282A		(blank)	na	no acm	na	na	na
	WB282B		(blank)	na	no acm	na	na	na
	WB282C		(blank)	na	no acm	na	na	na
	WB286		(blank)	88	ceiling tile	Negative	na	na
				89	ceiling tile	Negative	na	na
				90	ceiling tile	Negative	na	na
				91	ceiling tile	Negative	na	na
				92	ceiling tile	Negative	na	na
	WB289		(blank)	WB457-001a	black/yellow tar on duct insulatio	Positive	Chrysotile	Positive
	WB289A		(blank)	na	no acm	na	na	na
	WB289SC		(blank)	na	no acm	na	na	na
	WB291		(blank)	na	no acm	na	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WB292		(blank)	WB292-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
	WB300CC1		WB351cc-WB357cc	WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
	WB300CC2		Hallway behind WB370	WB457-001a	black/yellow tar on duct insulatio	Positive	Chrysotile	Positive
				WB457-001b	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
				WB457-001c	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
	WB300CC3		Hallway behind WB383	WB457-001a	black/yellow tar on duct insulatio	Positive	Chrysotile	Positive
				WB457-001b	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
				WB457-001c	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
	WB300CC4		WB366cc-WB302cc	WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
	WB300CC5		WB366cc-WB302cc	WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
	WB300CC6		WB312-WB215	12	ceiling tile	Negative	na	na
				13	ceiling tile	Negative	na	na
				14	ceiling tile	Negative	na	na
				15	ceiling tile	Negative	na	na
				16	ceiling tile	Negative	na	na
				25	ceiling stipple	Negative	na	na
				26	ceiling stipple	Negative	na	na
				27	ceiling stipple	Negative	na	na
				WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
	WB300CC7		Hallway	na	no acm	na	na	na
	WB300CC8		WB322-WB325	WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
	WB300CC9		Hallway	na	no acm	na	na	na
	WB300CC10		WB334-WB337	WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
	WB300CC11		Hallway	na	no acm	na	na	na
	WB300CC12		WB344-WB347	WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
	WB300CC13		WB362-WB266	WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
	WB300CC14		Hallway	na	no acm	na	na	na
	WB300SS1		Stairwell	na	no acm	na	na	na
	WB300SS2		Stairwell	na	no acm	na	na	na
	WB300SS3		Stairwell	na	no acm	na	na	na
	WB301		Janitor's Closet	WB327-001a	Silver Pipe Elbow	Positive	Chrysotile	Positive
	WB302		Office	WB457-001a	black/yellow tar on duct insulatio	Positive	Chrysotile	Positive
				WB457-001b	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
				WB457-001c	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
				60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB302A		Office	WB457-001a	black/yellow tar on duct insulatio	Positive	Chrysotile	Positive
				WB457-001b	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
				WB457-001c	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
				60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB310		(blank)	40	ceiling tile	Negative	na	na
				41	ceiling tile	Negative	na	na
				42	ceiling tile	Negative	na	na
				43	baseboard	Negative	na	na
					mastic	Negative	na	na
				44	baseboard	Negative	na	na
					mastic	Negative	na	na
				45	baseboard	Negative	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments		
					mastic	Negative	na	na		
				46	carpet	Negative	na	na		
				47	carpet	Negative	na	na		
				48	carpet	Negative	na	na		
	WB311		Office	na	no acm	na	na	na		
	WB311A		Office	na	no acm	na	na	na		
	WB312A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive		
	WB312B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive		
	WB312C		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive		
	WB312D		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive		
	WB313		Storage	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive		
	WB314		Office	na	no acm	na	na	na		
	WB314S		Office	WB351cc-WB357cc-C	Red/Orange Vinyl Floor Tile	Positive	Chrysotile	Positive		
	WB315A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive		
	WB315B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive		
	WB315C		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive		
	WB315D		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive		
	WB316		Storage	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive		
	WB317		Office	na	no acm	na	na	na		
	WB318		Men's Washroom	na	no acm	na	na	na		
	WB319		Classroom	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive		
	WB320		classroom	12	ceiling tile	Negative	na	na		
						13	ceiling tile	Negative	na	na
						14	ceiling tile	Negative	na	na
						15	ceiling tile	Negative	na	na
						16	ceiling tile	Negative	na	na
						17	floor tile	Negative	na	na
						18	floor tile	Negative	na	na
						19	floor tile	Negative	na	na
						20	Grey Vinyl Floor Tile	Positive	Chrysotile	
						21	floor tile	Positive	Chrysotile	na
						22	floor tile	Positive	Chrysotile	na
						23	floor tile	Positive	Chrysotile	na
			24	floor tile	Positive	Chrysotile	na			
	WB321		(blank)	96	ceiling tile	Negative	na	na		
						97	ceiling tile	Negative	na	na
						98	ceiling tile	Negative	na	na
	WB322A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive		
	WB322B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive		
	WB322C		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive		
	WB322D		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive		
	WB323		Storage	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive		
	WB324		Office	na	no acm	na	na	na		
	WB324S			WB351cc-WB357cc-C	Red/Orange Vinyl Floor Tile	Positive	Chrysotile	Positive		
						WB351cc-WB357cc-C	Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
	WB325A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive		
	WB325B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive		
	WB325C		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive		
	WB325D		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive		
	WB326		Storage	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive		
	WB327		Classroom	WB253-004a	White/Grey Floor Tile	Positive	Chrysotile	Positive		
						WB253-004c	White/Grey Floor Tile	Positive Stop	Chrysotile	Positive Stop
	WB330		Classroom	WB327-001a	Silver Pipe Elbow	Positive	Chrysotile	Positive		
	WB331		(blank)	na	no acm	na	na	na		
	WB332		(blank)	WB327-001a	Silver Pipe Elbow	Positive	Chrysotile	Positive		

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WB333		(blank)	WB327-001a	Silver Pipe Elbow	Positive	Chrysotile	Positive
	WB334A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB334B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB334C		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB334D		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB335		Storage	na	no acm	na	na	na
	WB336		Office	na	no acm	na	na	na
	WB337A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB337B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB337C		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB337D		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB338		Storage	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB339		(blank)	108	ceiling tile	Negative	na	na
109				ceiling tile	Negative	na	na	
110				ceiling tile	Negative	na	na	
111				ceiling tile	Negative	na	na	
112				ceiling tile	Negative	na	na	
WB253-004a				White/Grey Floor Tile	Positive	Chrysotile	Positive	
WB253-004c	White/Grey Floor Tile	Positive Stop	Chrysotile	Positive Stop				
	WB340		(blank)	na	no acm	na	na	na
	WB341		(blank)	WB457-001a	black/yellow tar on duct insulatio	Positive	Chrysotile	Positive
WB457-001b				black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop	
WB457-001c				black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop	
	WB342		(blank)	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB343		(blank)	99	ceiling tile	Negative	na	na
100				ceiling tile	Negative	na	na	
101				ceiling tile	Negative	na	na	
WB253-004a				White/Grey Floor Tile	Positive	Chrysotile	Positive	
WB253-004c				White/Grey Floor Tile	Positive Stop	Chrysotile	Positive Stop	
	WB344A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB344B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB344C		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB344D		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB345			60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB346		Office	na	no acm	na	na	na
	WB346S		Office	WB351cc-WB357cc-	Red/Orange Vinyl Floor Tile	Positive	Chrysotile	Positive
WB351cc-WB357cc-				Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop	
	WB347A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB347B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB347C		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB347D		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB348		(blank)	na	no acm	na	na	na
	WB349		Classroom	B349-26	ceiling tile	Negative	na	na
B349-27				ceiling tile	Negative	na	na	
B349-28				ceiling tile	Negative	na	na	
B349-29				Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
				mastic	Negative	na	na	
B349-30				floor tile	Negative	na	na	
B349-31				floor tile	Negative	na	na	
C302-32				ceiling tile	Negative	na	na	
C302-33				ceiling tile	Negative	na	na	
C302-34	ceiling tile	Negative	na	na				
	WB350		(blank)	na	no acm	na	na	na
	WB351		(blank)	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB351A		(blank)	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WB353	(blank)		60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB353A	(blank)		60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB457-001a	black/yellow tar on duct insulatio	Positive	Chrysotile	Positive
				WB457-001b	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
				WB457-001c	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
	WB355	(blank)		60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB357	(blank)		60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB457-001a	black/yellow tar on duct insulatio	Positive	Chrysotile	Positive
				WB457-001b	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
				WB457-001c	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
	WB357A	(blank)		60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB457-001a	black/yellow tar on duct insulatio	Positive	Chrysotile	Positive
				WB457-001b	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
				WB457-001c	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
	WB357B	(blank)		60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB457-001a	black/yellow tar on duct insulatio	Positive	Chrysotile	Positive
				WB457-001b	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
				WB457-001c	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
	WB360	(blank)		na	no acm	na	na	na
	WB361	(blank)		na	no acm	na	na	na
	WB362		Electrical Room	WB253-004a	White/Grey Floor Tile	Positive	Chrysotile	Positive
				WB253-004c	White/Grey Floor Tile	Positive Stop	Chrysotile	Positive Stop
				Hall 437D-2a	Black/yellow tar on Duct Insulatio	Positive	Chrysotile	Positive
	WB364	(blank)		7	ceiling tile	Negative	na	na
				8	ceiling tile	Negative	na	na
				9	ceiling tile	Negative	na	na
				10	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
					mastic	Negative	na	na
				11	mastic	Negative	na	na
				12	mastic	Negative	na	na
				13	mastic	Negative	na	na
				14	mastic	Negative	na	na
	WB365		Computer Lab	WB253-004a	White/Grey Floor Tile	Positive	Chrysotile	Positive
				WB253-004c	White/Grey Floor Tile	Positive Stop	Chrysotile	Positive Stop
	WB366		Computer Lab	WB253-004a	White/Grey Floor Tile	Positive	Chrysotile	Positive
				WB253-004c	White/Grey Floor Tile	Positive Stop	Chrysotile	Positive Stop
	WB367	(blank)		na	no acm	na	na	na
	WB368	(blank)		na	no acm	na	na	na
	WB370	(blank)		na	no acm	na	na	na
	WB370A	(blank)		na	no acm	na	na	na
	WB370B	(blank)		na	no acm	na	na	na
	WB371	(blank)		WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
	WB372	(blank)		WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
	WB373	Computer Lab		WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
				WB457-001a	black/yellow tar on duct insulatio	Positive	Chrysotile	Positive
				WB457-001b	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
				WB457-001c	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
	WB373A	Computer Lab		WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
				WB457-001a	black/yellow tar on duct insulatio	Positive	Chrysotile	Positive
				WB457-001b	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
				WB457-001c	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WB373B		Computer Lab	WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
				WB457-001a	black/yellow tar on duct insulatio	Positive	Chrysotile	Positive
				WB457-001b	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
				WB457-001c	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
	WB374		(blank)	WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB351cc-WB357cc-0	Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
	WB380		(blank)	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB382		(blank)	na	no acm	na	na	na
	WB383		(blank)	na	no acm	na	na	na
	WB384A		(blank)	49	ceiling tile	Negative	na	na
				50	ceiling tile	Negative	na	na
				60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
					mastic	Negative	na	na
				61	mastic	Negative	na	na
				62	mastic	Negative	na	na
				63	mastic	Negative	na	na
				64	mastic	Negative	na	na
				65	ceiling tile	Negative	na	na
	WB384B		(blank)	49	ceiling tile	Negative	na	na
				50	ceiling tile	Negative	na	na
				60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
					mastic	Negative	na	na
				61	mastic	Negative	na	na
				62	mastic	Negative	na	na
				63	mastic	Negative	na	na
				64	mastic	Negative	na	na
	65	ceiling tile	Negative	na	na			
	WB385		Storage	na	no acm	na	na	na
	WB386		Electrical	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB387		Storage	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB400CC1		Hallway	WB460-001c	Cream/White Ceiling Stipple	Positive	Chrysotile	Positive
	WB400CC2		Hallway	WB460-001c	Cream/White Ceiling Stipple	Positive	Chrysotile	Positive
				WB462Acc-WB453cc	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB400CC3		Hallway	na	no acm	na	na	na
	WB400CC4		Hallway	WB460-001c	Cream/White Ceiling Stipple	Positive	Chrysotile	Positive
				WB462Acc-WB453cc	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
WB400CC5		Hallway	na	no acm	na	na	na	
WB400CC6		Hallway	WB460-001c	Cream/White Ceiling Stipple	Positive	Chrysotile	Positive	
			WB457-001a	black/yellow tar on duct insulatio	Positive	Chrysotile	Positive	
			WB457-001b	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop	
			WB457-001c	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop	
WB400CC7		Hallway	WB460-001c	Cream/White Ceiling Stipple	Positive	Chrysotile	Positive	
			WB457-001a	black/yellow tar on duct insulatio	Positive	Chrysotile	Positive	
			WB457-001b	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop	
			WB457-001c	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop	
WB400CC8		Hallway	WB462Acc-WB453cc	Green Vinyl Floor Tile	Positive	Chrysotile	Positive	
WB400CC9		Hallway	WB460-001c	Cream/White Ceiling Stipple	Positive	Chrysotile	Positive	
			WB462Acc-WB453cc	Green Vinyl Floor Tile	Positive	Chrysotile	Positive	
WB400CC10		Hallway	WB460-001c	Cream/White Ceiling Stipple	Positive	Chrysotile	Positive	
			WB462Acc-WB453cc	Green Vinyl Floor Tile	Positive	Chrysotile	Positive	
WB400SS1		Stairwell	na	no acm	na	na	na	
WB400SS2		Stairwell	na	no acm	na	na	na	
WB400SS3		Stairwell	na	no acm	na	na	na	
WB400SS4		Stairwell	na	no acm	na	na	na	

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WB400SS5		Stairwell	na	no acm	na	na	na
	WB400SS6		Stairwell	na	no acm	na	na	na
	WB401		Janitor's Closet	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB402		Boardroom	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB410		Classroom	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB411		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB327-001a	Silver Pipe Elbow	Positive	Chrysotile	Positive
	WB412A		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB412B		B412B office & halls	26-07-06-21a	ceiling stucco	Negative	na	na
			(blank)	26-07-06-21b	ceiling stucco	Negative	na	na
				26-07-06-21c	ceiling stucco	Negative	na	na
				26-07-06-21d	ceiling stucco	Negative	na	na
				26-07-06-21e	ceiling stucco	Negative	na	na
				26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
					mastic	Negative	na	na
				26-07-06-22b	mastic	Negative	na	na
				26-07-06-22c	mastic	Negative	na	na
	WB412C		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB412D		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB413		Storage	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB414		Office	na	no acm	na	na	na
	WB414S		Office	WB462-WB453cc001	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB457-001a	black/yellow tar on duct insulatio	Positive	Chrysotile	Positive
				WB457-001b	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
				WB457-001c	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
	WB415A		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB415B		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB415C		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB415D		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB416		Storage	na	no acm	na	na	na
	WB417		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB327-001a	Silver Pipe Elbow	Positive	Chrysotile	Positive
	WB418		Men's Washroom	na	no acm	na	na	na
	WB419		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB327-001a	Silver Pipe Elbow	Positive	Chrysotile	Positive
	WB420A		Meeting Room	WB457-001a	black/yellow tar on duct insulatio	Positive	Chrysotile	Positive
				WB457-001b	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
				WB457-001c	black/yellow tar on duct insulatio	Positive Stop	Chrysotile	Positive Stop
	WB420B		Meeting Room	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB420C		(blank)	WB420C-001a	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB420C-001b	Green Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
	WB421		Classroom	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB422		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB423A		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB423B		Office	26-07-06-21a	ceiling stucco	Negative	na	na
				26-07-06-21b	ceiling stucco	Negative	na	na
				26-07-06-21c	ceiling stucco	Negative	na	na
				26-07-06-21d	ceiling stucco	Negative	na	na
				26-07-06-21e	ceiling stucco	Negative	na	na
				26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
					mastic	Negative	na	na
				26-07-06-22b	mastic	Negative	na	na
				26-07-06-22c	mastic	Negative	na	na
	WB423C		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB423D		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WB424		Storage	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB425		Office	na	no acm	na	na	na
	WB425S		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB426A		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB426B		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB426C		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB426D		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB427		Storage	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB428		Office	na	no acm	na	na	na
	WB430		Classroom	WB327-001a	Silver Pipe Elbow	Positive	Chrysotile	Positive
	WB431		Women's Washroom	na	no acm	na	na	na
	WB432		Classroom	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB433		(blank)	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB434A		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB434B		Office	26-07-06-21a	ceiling stucco	Negative	na	na
26-07-06-21b				ceiling stucco	Negative	na	na	
26-07-06-21c				ceiling stucco	Negative	na	na	
26-07-06-21d				ceiling stucco	Negative	na	na	
26-07-06-21e				ceiling stucco	Negative	na	na	
26-07-06-22a				Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
				mastic	Negative	na	na	
26-07-06-22b	mastic	Negative	na	na				
26-07-06-22c	mastic	Negative	na	na				
	WB434C		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB434D		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB435		IT Room	26-07-06-23a	floor tile	Positive	Chrysotile	Positive
				mastic	Negative	na	na	
26-07-06-23b				floor tile	Negative	na	na	
26-07-06-23c				floor tile	Negative	na	na	
	WB436		Storage	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB436S		(blank)	26-07-06-21a	ceiling stucco	Negative	na	na
26-07-06-21b				ceiling stucco	Negative	na	na	
26-07-06-21c				ceiling stucco	Negative	na	na	
26-07-06-21d				ceiling stucco	Negative	na	na	
26-07-06-21e				ceiling stucco	Negative	na	na	
26-07-06-24a				Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
				mastic	Negative	na	na	
26-07-06-24b	floor tile	Negative	na	na				
26-07-06-24c	floor tile	Negative	na	na				
	WB437A		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB437B		Office	26-07-06-21a	ceiling stucco	Negative	na	na
26-07-06-21b				ceiling stucco	Negative	na	na	
26-07-06-21c				ceiling stucco	Negative	na	na	
26-07-06-21d				ceiling stucco	Negative	na	na	
26-07-06-21e				ceiling stucco	Negative	na	na	
26-07-06-22a				Grey Vinyl Floor Tile	Positive	Chrysotile	Positive	
				mastic	Negative	na	na	
26-07-06-22b	mastic	Negative	na	na				
26-07-06-22c	mastic	Negative	na	na				
	WB437C		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB437D		Office	26-07-06-22a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB438		Storage	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB439		Classroom	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB327-001a	Silver Pipe Elbow	Positive	Chrysotile	Positive
	WB439X		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
				WB460-001c	cream/white ceiling stipple	Positive	Chrysotile	Positive
				WB462Acc-WB453cc	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB440		Classroom	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB441		Men's Washroom	WB460-001c	cream/white ceiling stipple	Positive	Chrysotile	Positive
	WB442		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB443		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB443B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB444A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB444B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB444C		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB444D		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB445		Storage	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB446		Office	WB460-001c	cream/white ceiling stipple	Positive	Chrysotile	Positive
	WB446S		Office	WB462Acc-WB453cc	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB447A		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB447B		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB447C		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB447D		Office	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB448		Storage	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB449		(blank)	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB449A		(blank)	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB450		Janitor's Closet	na	no acm	na	na	na
	WB453		(blank)	15	ceiling tile	Negative	na	na
				16	ceiling tile	Negative	na	na
				17	ceiling tile	Negative	na	na
				18	ceiling tile	Negative	na	na
				19	ceiling tile	Negative	na	na
				20	drywall compound	Negative	na	na
				21	drywall compound	Negative	na	na
				22	drywall compound	Negative	na	na
				23	ceiling stipple	Negative	na	na
				24	ceiling stipple	Negative	na	na
				25	ceiling stipple	Negative	na	na
				26	carpet and mastic	Negative	na	na
				27	carpet and mastic	Negative	na	na
	28	carpet and mastic	Negative	na	na			
	29	carpet and mastic	Negative	na	na			
	30	carpet and mastic	Negative	na	na			
	WB453A		Office	na	no acm	na	na	na
	WB453B		Office	na	no acm	na	na	na
	WB453C		Office	na	no acm	na	na	na
	WB453D		Office	na	no acm	na	na	na
	WB453E		Storage	na	no acm	na	na	na
	WB455		Classroom	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB457		Classroom	18	mastic	na	na	na
				19	mastic	na	na	na
				20	mastic	na	na	na
				49	ceiling tile	Negative	na	na
				50	ceiling tile	Negative	na	na
				51	ceiling tile	Negative	na	na
				52	ceiling tile	Negative	na	na
				53	ceiling tile	Negative	na	na
				54	ceiling stipple	Negative	na	na
				55	ceiling stipple	Negative	na	na
	56	ceiling stipple	Negative	na	na			

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
				57	baseboard	Negative	na	na
					mastic	Negative	na	na
				58	baseboard	Negative	na	na
					mastic	Negative	na	na
				59	baseboard	Negative	na	na
					mastic	Negative	na	na
				60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
					mastic	Negative	na	na
				61	mastic	Negative	na	na
				62	mastic	Negative	na	na
				63	mastic	Negative	na	na
				64	mastic	Negative	na	na
				65	floor tile	Negative	na	na
					mastic	Negative	na	na
				66	floor tile	Negative	na	na
					mastic	Negative	na	na
				67	floor tile	Negative	na	na
					mastic	Negative	na	na
	WB457A		Small Transition Room	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB457B		Small Transition Room	60	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WB460		Men's Washroom	na	no acm	na	na	na
	WB461		Women's Washroom	na	no acm	na	na	na
	WB462		Janitor's Closet	na	no acm	na	na	na
	WC000CC1		Hallway	na	no acm	na	na	na
	WC000CC2		Hallway	na	no acm	na	na	na
	WC000CC3		Hallway	na	no acm	na	na	na
	WC000CC4		Hallway	na	no acm	na	na	na
	WC000CC5		Hallway	na	no acm	na	na	na
	WC000CC6		Hallway	na	no acm	na	na	na
	WC000CC7		Hallway	na	no acm	na	na	na
	WC000CC8		Hallway	na	no acm	na	na	na
	WC000CC9		Hallway	na	no acm	na	na	na
	WC000CC10		Hallway	na	no acm	na	na	na
	WC000CC11		Hallway	na	no acm	na	na	na
	WC000CC12		Hallway	na	no acm	na	na	na
	WC000SS1		Stairwell	na	no acm	na	na	na
	WC000SS2		Stairwell	na	no acm	na	na	na
	WC000SS3		Stairwell	na	no acm	na	na	na
	WC000SS4		Stairwell	na	no acm	na	na	na
	WC000EE		Electrical Room	na	no acm	na	na	na
	WC001		Janitor's Closet	na	no acm	na	na	na
	WC002		Electrical Room	na	no acm	na	na	na
	WC003		Storage	WC006-001b	White Drywall Joint Compound	Positive	Chrysotile	Positive
	WC005		Mechanical Equipment	na	no acm	na	na	na
	WC006		Classroom	WC006-001b	White Drywall Joint Compound	Positive	Chrysotile	Positive
				WC006-002a	WHT/GRY vinyl floor tile	Positive	Chrysotile	Positive
	WC007		Main office	na	no acm	na	na	na
	WC008		Women's Washroom	na	no acm	na	na	na
	WC009		Storage	na	no acm	na	na	na
	WC010		C010 - men's washroom	C010-1a	white ceiling drywall joint compound	Negative	na	na
				C010-1c	white ceiling drywall joint compound	Negative	na	na
	WC011		Storage	na	no acm	na	na	na
	WC012		Storage Entrance	na	no acm	na	na	na
	WC012A		Storage	na	no acm	na	na	na
	WC012B		Storage	na	no acm	na	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WC012C		Storage	na	no acm	na	na	na
	WC012D		Storage	na	no acm	na	na	na
	WC012E		Storage	na	no acm	na	na	na
	WC013		Office	na	no acm	na	na	na
	WC013A		Office	na	no acm	na	na	na
	WC013B		Office	na	no acm	na	na	na
	WC013C		Office	na	no acm	na	na	na
	WC013D		Office	na	no acm	na	na	na
	WC013E		Office	na	no acm	na	na	na
	WC013F		Office	na	no acm	na	na	na
	WC013SL		Student Lounge	na	no acm	na	na	na
	WC015		Studio	na	no acm	na	na	na
	WC016		Photo Lab	na	no acm	na	na	na
	WC016A		(blank)	na	no acm	na	na	na
	WC016B		(blank)	na	no acm	na	na	na
	WC016C		(blank)	na	no acm	na	na	na
	WC017		Storage	WC016-002a	WHT/GRY vinyl floor tile	Positive	Chrysotile	Positive
	WC018		Studio	na	no acm	na	na	na
	WC021		(blank)	na	no acm	na	na	na
	WC021SC		Vestebule	na	no acm	na	na	na
	WC022		Classroom	na	no acm	na	na	na
	WC023		Bindery	na	no acm	na	na	na
	WC023A		Storage	WC006-001b	White Drywall Joint Compound	Positive	Chrysotile	Positive
				WC006-002a	WHT/GRY vinyl floor tile	Positive	Chrysotile	Positive
	WC025		Classroom	na	no acm	na	na	na
	WC026		(blank)	C026-1a	ceiling drywall joint compound	Positive	Chrysotile	Removed
				C026-1b	ceiling drywall joint compound	Positive	Chrysotile	Removed
				C026-1c	ceiling drywall joint compound	Positive	Chrysotile	Removed
				C026-2a	mastic	Positive Stop	na	
					vinyl floor tile	Positive	Chrysotile	Removed
				C026-2b	mastic	Negative	na	
					vinyl floor tile	Positive Stop	na	
				C026-2c	mastic	Negative	na	
					vinyl floor tile	Positive Stop	na	
	WC027		Office	na	no acm	na	na	na
	WC028		(blank)	127	ceiling tile	Negative	na	
				128	ceiling tile	Negative	na	
				129	ceiling tile	Negative	na	
				130	drywall compound	Positive	Chrysotile	Removed
				131	drywall compound	Positive	Chrysotile	Removed
				132	drywall compound	Positive	Chrysotile	Removed
	WC029		(blank)	130	drywall compound	Positive	Chrysotile	Removed
				131	drywall compound	Positive	Chrysotile	Removed
				132	drywall compound	Positive	Chrysotile	Removed
				133	baseboard	Negative	na	na
					mastic	Negative	na	na
				134	baseboard	Negative	na	na
					mastic	Negative	na	na
				135	baseboard	Negative	na	na
					mastic	Negative	na	na
	WC029A		(blank)	130	drywall compound	Positive	Chrysotile	Removed
				131	drywall compound	Positive	Chrysotile	Removed
				132	drywall compound	Positive	Chrysotile	Removed
	WC029C		(blank)	133	baseboard	Negative	na	na
					mastic	Negative	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
				134	baseboard	Negative	na	na
					mastic	Negative	na	na
				135	baseboard	Negative	na	na
					mastic	Negative	na	na
	WC029SC		(blank)	na	no acm	na	na	na
	WC032		Office	na	no acm	na	na	na
	WC032A		(blank)	na	no acm	na	na	na
	WC032B		(blank)	na	no acm	na	na	na
	WC032C		(blank)	na	no acm	na	na	na
	WC042		C042 - office; Point B	na	new ceiling tile	no acm	na	na
	WC042A		C042-A - boardroom; Point A	na	new ceiling tile	no acm	na	na
	WC043		Transition Support Center	na	no acm	na	na	na
	WC044		Office	na	no acm	na	na	na
	WC044A		(blank)	na	no acm	na	na	na
	WC044B		(blank)	na	no acm	na	na	na
	WC044C		(blank)	na	no acm	na	na	na
	WC045		Classroom	na	no acm	na	na	na
	WC046		Classroom	WC-CC043-CC050-00	White Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC047		Classroom	na	no acm	na	na	na
	WC048	(blank)	130	drywall compound	Positive	Chrysotile	Removed	
131			drywall compound	Positive	Chrysotile	Removed		
132			drywall compound	Positive	Chrysotile	Removed		
133			baseboard	Negative	na	na		
			mastic	Negative	na	na		
134			baseboard	Negative	na	na		
			mastic	Negative	na	na		
135			baseboard	Negative	na	na		
			mastic	Negative	na	na		
136			ceiling tile	Negative	na	na		
137			ceiling tile	Negative	na	na		
138	ceiling tile	Negative	na	na				
WC048cc	Hallway	136	ceiling tile	Negative	na	na		
		137	ceiling tile	Negative	na	na		
		138	ceiling tile	Negative	na	na		
	WC049		Office	na	no acm	na	na	na
	WC050		Storage	na	no acm	na	na	na
	WC050A		(blank)	na	no acm	na	na	na
	WC050B		(blank)	na	no acm	na	na	na
	WC100LB	C Bldg Main Lobby	C151-1a	joint compound	Negative	na	na	
				stipple	Negative	na	na	
			C151-1b	joint compound	Negative	na	na	
				stipple	Negative	na	na	
			C151-1c	joint compound	Negative	na	na	
				stipple	Negative	na	na	
			4	stipple	Positive	Chrysotile	Positive	
			5	stipple	Positive Stop	Chrysotile	Positive Stop	
			6	stipple	Positive Stop	Chrysotile	Positive Stop	
			21	stipple	Positive Stop	Chrysotile	Positive Stop	
			22	stipple	Positive Stop	Chrysotile	Positive Stop	
	WC100CC1		Hallway	na	no acm	na	na	na
	WC100CC2		Hallway	na	no acm	na	na	na
	WC100CC3		Hallway	na	no acm	na	na	na
	WC100CC4		Hallway	na	no acm	na	na	na
	WC100CC5		Hallway	WC140cc-WC130Fcc	ceiling stipple	Positive	Chrysotile	Positive
	WC100CC6		Hallway	WC130Fcc-WC146c	ceiling stipple	Positive	Chrysotile	Positive

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WC100CC7		Hallway	na	no acm	na	na	na
	WC100CC8		Hallway	na	no acm	na	na	na
	WC100CC9		Hallway	na	no acm	na	na	na
	WC100CC10		Hallway	na	no acm	na	na	na
	WC100CC11		Hallway	na	no acm	na	na	na
	WC100CC12		Hallway	na	no acm	na	na	na
	WC100CC13		Hallway	na	no acm	na	na	na
	WC100CC14		Hallway	na	no acm	na	na	na
	WC100CC15		Hallway	na	no acm	na	na	na
	WC100SS1		Stairwell	na	no acm	na	na	na
	WC100SS2		Stairwell	na	no acm	na	na	na
	WC100SS3		Stairwell	na	no acm	na	na	na
	WC100SS4		Stairwell	na	no acm	na	na	na
	WC100SS5		Stairwell	na	no acm	na	na	na
	WC100SS6		Stairwell	na	no acm	na	na	na
	WC100SS7		Stairwell	na	no acm	na	na	na
	WC100SS8		Stairwell	na	no acm	na	na	na
	WC100VS1		Vestebule	na	no acm	na	na	na
	WC100VS2		Vestebule	na	no acm	na	na	na
	WC100VS3		Vestebule	na	no acm	na	na	na
	WC100VS4		Vestebule	na	no acm	na	na	na
	WC101		Computer Lab	na	no acm	na	na	na
	WC101A		Office	na	no acm	na	na	na
	WC101B		Office	na	no acm	na	na	na
	WC101C		Storage	na	no acm	na	na	na
	WC102		Office	na	no acm	na	na	na
	WC102A		Office	na	no acm	na	na	na
	WC102C		Office	na	no acm	na	na	na
	WC102D		Office	na	no acm	na	na	na
	WC102F		Office	na	no acm	na	na	na
	WC102G		Office	na	no acm	na	na	na
	WC102EE		Electrical Room	na	no acm	na	na	na
	WC102LS1		Light Study Area	na	no acm	na	na	na
	WC102LS2		Light Study Area	na	no acm	na	na	na
	WC102LS3		Light Study Area	na	no acm	na	na	na
	WC104		Women's Washroom	na	no acm	na	na	na
	WC105		Men's Washroom	na	no acm	na	na	na
	WC109		Lan Room	na	no acm	na	na	na
	WC109SC		(blank)	na	no acm	na	na	na
	WC111		Storage	WC-111-002a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC112A		Storage	WC-111-002a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC112B		Storage	WC-111-002a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC112SC		Storage	WC-111-002a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC113		Women's Washroom	na	no acm	na	na	na
	WC114		Storage	WC-114-001a	Red Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC115		Men's Washroom	na	no acm	na	na	na
	WC116		Storage	na	no acm	na	na	na
	WC122		Studio	na	no acm	na	na	na
	WC124		Photo Lab	na	no acm	na	na	na
	WC124A		Office	na	no acm	na	na	na
	WC125		(blank)	25-07-06-6a	drywall compound	Negative	na	na
				25-07-06-6b	drywall compound	Negative	na	na
				25-07-06-6c	drywall compound	Negative	na	na
				25-07-06-7a	floor tile	Negative	na	na
					mastic	Negative	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
				25-07-06-7b	floor tile	Negative	na	na
					mastic	Negative	na	na
				25-07-06-7c	floor tile	Negative	na	na
					mastic	Negative	na	na
				25-07-06-8a	floor tile	Negative	na	na
					mastic	Negative	na	na
				25-07-06-8b	floor tile	Negative	na	na
					mastic	Negative	na	na
				25-07-06-8c	floor tile	Negative	na	na
					mastic	Negative	na	na
	WC126		Production Room	WC-111-002a	grey - floor vinyl tile	Positive	Chrysotile	Positive
	WC127		(blank)	C127-1a	black mastic	Negative	na	na
					grey - floor vinyl tile	Positive	Chrysotile	Positive
				C127-1b	black mastic	Negative	na	na
				C127-1c	black mastic	Negative	na	na
	WC128A - WC128B		Main Security Office	C128-8a	wall plaster - grey	Negative	na	na
					wall plaster - white	Negative	na	na
				C128-8b	wall plaster - grey	Negative	na	na
					wall plaster - white	Negative	na	na
				C128-8c	wall plaster - grey	Negative	na	na
					wall plaster - white	Negative	na	na
				C128-9a	baseboard	Negative	na	na
					mastic	Negative	na	na
				C128-9b	baseboard	Negative	na	na
					mastic	Negative	na	na
				C128-9c	baseboard	Negative	na	na
					mastic	Negative	na	na
				na	ceiling tile	no acm	na	na
					drywall	no acm	na	na
					floor vinyl tile	no acm	na	na
	WC129		Storage	na	no acm	na	na	na
	WC130		Office	na	no acm	na	na	na
	WC130A		Office	na	no acm	na	na	na
	WC130B		Office	na	no acm	na	na	na
	WC130C		Office	na	no acm	na	na	na
	WC130F		Storage	na	no acm	na	na	na
	WC131		Classroom	na	no acm	na	na	na
	WC132		(blank)	na	no acm	na	na	na
	WC132A		(blank)	na	no acm	na	na	na
	WC132B		(blank)	na	no acm	na	na	na
	WC133		(blank)	na	no acm	na	na	na
	WC133SC		(blank)	na	no acm	na	na	na
	WC134A		Storage	WC-111-002a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC134B		Storage	WC-111-002a	Grey Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC135		Learning and Development Center	na	no acm	na	na	na
	WC135A		Office	na	no acm	na	na	na
	WC135B		Storage	na	no acm	na	na	na
	WC135C		Office	na	no acm	na	na	na
	WC135D		Conference Room	na	no acm	na	na	na
	WC135E		Office	na	no acm	na	na	na
	WC135F		Office	na	no acm	na	na	na
	WC137		Office	na	no acm	na	na	na
	WC137A		Office	na	no acm	na	na	na
	WC137B		Office	na	no acm	na	na	na
	WC137C		Office	na	no acm	na	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WC137D		Storage	na	no acm	na	na	na
	WC140		Women's Washroom	na	no acm	na	na	na
	WC141		(blank)	1	floor tile	Negative	na	na
					mastic	Negative	na	na
				2	floor tile	Negative	na	na
					mastic	Negative	na	na
				3	floor tile	Negative	na	na
					mastic	Negative	na	na
				4	ceiling tile	Negative	na	na
				5	ceiling tile	Negative	na	na
				6	ceiling tile	Negative	na	na
				7	baseboard	Negative	na	na
					mastic	Negative	na	na
				8	baseboard	Negative	na	na
					mastic	Negative	na	na
				9	baseboard	Negative	na	na
		mastic	Negative	na	na			
	WC141		C141 - health services	na	new ceiling tile	no acm	na	na
	WC141A		(blank)	7	ceiling tile	Negative	na	na
				8	ceiling tile	Negative	na	na
				9	ceiling tile	Negative	na	na
				10	floor tile	Negative	na	na
					mastic	Negative	na	na
				11	floor tile	Negative	na	na
					mastic	Negative	na	na
	12	floor tile	Negative	na	na			
					mastic	Negative	na	na
	WC141B		(blank)	na	no acm	na	na	na
	WC141C		(blank)	na	no acm	na	na	na
	WC141D		(blank)	na	no acm	na	na	na
	WC141E		(blank)	na	no acm	na	na	na
	WC141F		(blank)	na	no acm	na	na	na
	WC141G		(blank)	na	no acm	na	na	na
	WC141H		(blank)	na	no acm	na	na	na
	WC141I		(blank)	na	no acm	na	na	na
	WC141J		(blank)	na	no acm	na	na	na
	WC141K		(blank)	na	no acm	na	na	na
	WC141L		(blank)	na	no acm	na	na	na
	WC141M		(blank)	na	no acm	na	na	na
	WC141N		(blank)	na	no acm	na	na	na
	WC141O		(blank)	na	no acm	na	na	na
	WC141P		(blank)	na	no acm	na	na	na
	WC141Q		(blank)	na	no acm	na	na	na
	WC141R		(blank)	na	no acm	na	na	na
	WC141S		(blank)	na	no acm	na	na	na
	WC141T		(blank)	na	no acm	na	na	na
	WC141SC1		Health Service Office Hallway	na	no acm	na	na	na
	WC141SC2		(blank)	na	no acm	na	na	na
	WC141OA		(blank)	na	no acm	na	na	na
	WC143		Kitchen	na	no acm	na	na	na
	WC144		Theatre Classroom	26-07-06-10a	carpet mastic	Negative	na	na
				26-07-06-10b	carpet mastic	Negative	na	na
				26-07-06-10c	carpet mastic	Negative	na	na
				26-07-06-10d	carpet mastic	Negative	na	na
				26-07-06-10e	carpet mastic	Negative	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
				26-07-06-11a	carpet mastic	Negative	na	na
				26-07-06-11b	carpet mastic	Negative	na	na
				26-07-06-11c	carpet mastic	Negative	na	na
				26-07-06-9a	ceiling stucco	Negative	na	na
				26-07-06-9b	ceiling stucco	Negative	na	na
				26-07-06-9c	ceiling stucco	Negative	na	na
				26-07-06-9d	ceiling stucco	Negative	na	na
				26-07-06-9e	ceiling stucco	Negative	na	na
	WC145		Office	na	no acm	na	na	na
	WC145A		Office	na	no acm	na	na	na
	WC145B		(blank)	na	no acm	na	na	na
	WC148		(blank)	16	floor tile	Positive	Chrysotile	Removed
					mastic	Negative	na	na
				17	mastic	Negative	na	na
				18	mastic	Negative	na	na
	WC149		(blank)	13	drywall compound	Negative	na	na
				14	drywall compound	Negative	na	na
				15	drywall compound	Negative	na	na
	WC150		Office	26-07-06-12a	ceiling tile	Negative	na	na
				26-07-06-12b	ceiling tile	Negative	na	na
				26-07-06-12c	ceiling tile	Negative	na	na
				26-07-06-12d	ceiling tile	Negative	na	na
				26-07-06-12e	ceiling tile	Negative	na	na
				26-07-06-12f	ceiling tile	Negative	na	na
				26-07-06-12g	ceiling tile	Negative	na	na
	WC150A		Storage	na	no acm	na	na	na
	WC150B		Office	na	no acm	na	na	na
	WC150C		Office	na	no acm	na	na	na
	WC150D		Office	na	no acm	na	na	na
	WC150E		Office	na	no acm	na	na	na
	WC150F		Office	na	no acm	na	na	na
	WC150G		Office	26-07-06-13b	ceiling tile	Negative	na	na
				26-07-06-13c	ceiling tile	Negative	na	na
				26-07-06-13a	ceiling tile	Negative	na	na
	WC150H		Office	na	no acm	na	na	na
	WC151		Office	C151-1a	joint compound	Negative	na	na
					stipple	Negative	na	na
				C151-1b	joint compound	Negative	na	na
					stipple	Negative	na	na
				C151-1c	joint compound	Negative	na	na
					stipple	Negative	na	na
				C151-2a	floor tile	Negative	na	na
					mastic	Negative	na	na
				C151-2b	floor tile	Negative	na	na
					mastic	Negative	na	na
				C151-2c	floor tile	Negative	na	na
					mastic	Negative	na	na
				C151-3a	baseboard	Negative	na	na
					mastic	Negative	na	na
				C151-3b	baseboard	Negative	na	na
					mastic	Negative	na	na
				C151-3c	baseboard	Negative	na	na
					mastic	Negative	na	na
				C151-4a	carpet mastic	Negative	na	na
				C151-4b	carpet mastic	Negative	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
				C151-4c	carpet mastic	Negative	na	na
	WC151A		(blank)	na	no acm	na	na	na
	WC151B		(blank)	na	no acm	na	na	na
	WC151C		(blank)	na	no acm	na	na	na
	WC151D		(blank)	na	no acm	na	na	na
	WC151E		(blank)	na	no acm	na	na	na
	WC152		Office	na	no acm	na	na	na
	WC152A		(blank)	na	no acm	na	na	na
	WC152B		(blank)	na	no acm	na	na	na
	WC152C		(blank)	na	no acm	na	na	na
	WC200CC1		Hallway	na	no acm	na	na	na
	WC200CC2		Hallway	CC238-CC205-002a	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC200CC3		Hallway	CC238-CC205-002a	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC200CC4		Hallway	CC238-CC205-002a	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC200CC5		Hallway	CC238-CC205-002a	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC200CC6		Hallway	CC238-CC205-002a	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC200CC7		Hallway	CC238-CC205-002a	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC200CC8		Hallway	CC238-CC205-002a	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC200CC9		Hallway	na	no acm	na	na	na
	WC200CC10		Hallway	na	no acm	na	na	na
	WC200SS1		Stairwell	na	no acm	na	na	na
	WC200SS2		Stairwell	na	no acm	na	na	na
	WC200SS3		Stairwell	na	no acm	na	na	na
	WC200SS4		Stairwell	na	no acm	na	na	na
	WC200SS5		Stairwell	na	no acm	na	na	na
	WC200CL2		Electrical Closet	CC238-CC205-002a	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC200JCLINK		Skywalk to J building	na	no acm	na	na	na
	WC201		Janitor's Closet	WC201-001a	vinyl floor tile	Positive	Chrysotile	Positive
				WC201-001b	vinyl floor tile	Positive Stop	Chrysotile	Positive Stop
				WC201-001c	vinyl floor tile	Positive Stop	Chrysotile	Positive Stop
	WC201A		(blank)	na	no acm	na	na	na
	WC202		Women's Washroom	na	no acm	na	na	na
	WC203		Men's Washroom	na	no acm	na	na	na
	WC204		Washroom	na	no acm	na	na	na
	WC204A		Storage	na	no acm	na	na	na
	WC204B		Wireless Server Room	na	no acm	na	na	na
	WC205A		Office	na	no acm	na	na	na
	WC205B		Office	na	no acm	na	na	na
	WC205C		Office	na	no acm	na	na	na
	WC205D		Office	na	no acm	na	na	na
	WC205E		Office	na	no acm	na	na	na
	WC205H		Office	na	no acm	na	na	na
	WC206		(blank)	na	no acm	na	na	na
	WC208		Storage	na	no acm	na	na	na
				na	no acm	na	na	na
				na	no acm	na	na	na
				na	no acm	na	na	na
				na	no acm	na	na	na
				na	no acm	na	na	na
				na	no acm	na	na	na
	WC209		Office	na	no acm	na	na	na
	WC210		(blank)	31	floor tile	Negative	na	na
					mastic	Negative	na	na
				32	floor tile	Negative	na	na
					mastic	Negative	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
				33	floor tile	Negative	na	na
					mastic	Negative	na	na
	WC211		Office	na	no acm	na	na	na
	WC211A		Office	na	no acm	na	na	na
	WC211B		Office	na	no acm	na	na	na
	WC211C		Office	na	no acm	na	na	na
	WC212		(blank)	na	baseboard	new	na	na
					ceiling tile	new	na	na
					drywall	new	na	na
					floor vinyl tile	new	na	na
	WC212A		Office	na	no acm	na	na	na
	WC212B		Office	na	no acm	na	na	na
	WC212C		Office	na	no acm	na	na	na
	WC213		Boardroom	na	no acm	na	na	na
	WC214		Office	na	no acm	na	na	na
	WC214A		Office	na	no acm	na	na	na
	WC214B		Office	na	no acm	na	na	na
	WC214C		Office	na	no acm	na	na	na
	WC214D		Office	na	no acm	na	na	na
	WC215B		Office	C215b-5a	ceiling stipple	Negative	na	na
					drywall compound	Positive	Chrysotile	Positive 2016
				C215b-5b	ceiling stipple	Negative	na	na
					drywall compound	Positive	Chrysotile	Positive 2016
				C215b-5c	ceiling stipple	Negative	na	na
					drywall compound	Positive Stop	na	Positive 2016
				C215b-6a	floor tile	Positive	Chrysotile	Removed
					mastic	Negative	na	Removed
				C215b-6b	floor tile	Positive Stop	na	na
					mastic	Negative	na	na
				C215b-6c	floor tile	Positive Stop	na	na
					mastic	Negative	na	na
	WC215C		Office	na	no acm	na	na	na
	WC215D		Office	na	no acm	na	na	na
	WC215G		Office	na	no acm	na	na	na
	WC215H		Storage	na	no acm	na	na	na
	WC216		Office	na	no acm	na	na	na
	WC216A		Office	na	no acm	na	na	na
	WC216B		Office	na	no acm	na	na	na
	WC216C		Office	na	no acm	na	na	na
	WC216D		Storage	na	no acm	na	na	na
	WC217		Men's Washroom	na	no acm	na	na	na
	WC218		Storage	CC238-CC205-002a	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC219		Women's Washroom	na	no acm	na	na	na
	WC220		Janitor's Closet	na	no acm	na	na	na
	WC221		Office	na	no acm	na	na	na
	WC221A		Office	na	no acm	na	na	na
	WC221B		Office	na	no acm	na	na	na
	WC221C		Office	na	no acm	na	na	na
	WC221D		Office	na	no acm	na	na	na
	WC222		Office	na	no acm	na	na	na
	WC222A		Office	na	no acm	na	na	na
	WC222B		Office	na	no acm	na	na	na
	WC223		Office	na	no acm	na	na	na
	WC223B		Office	na	no acm	na	na	na
	WC224		Office	na	no acm	na	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WC224A		Entrance to WC224D	na	no acm	na	na	na
	WC224B		Classroom	na	no acm	na	na	na
	WC224C		Classroom	na	no acm	na	na	na
	WC224D		Classroom	na	no acm	na	na	na
	WC225		Office	na	no acm	na	na	na
	WC225A		Office	na	no acm	na	na	na
	WC225B		Office	na	no acm	na	na	na
	WC225C		Office	na	no acm	na	na	na
	WC225D		Office	na	no acm	na	na	na
	WC225E		Office	na	no acm	na	na	na
	WC225F		Office	na	no acm	na	na	na
	WC225G		Office	na	no acm	na	na	na
	WC225H		Office	na	no acm	na	na	na
	WC225I		Office	na	no acm	na	na	na
	WC226		Office	na	no acm	na	na	na
	WC226B		Office	na	no acm	na	na	na
	WC226C		Office	na	no acm	na	na	na
	WC226D		Office	na	no acm	na	na	na
	WC226E		Office	na	no acm	na	na	na
	WC226F		Office	na	no acm	na	na	na
	WC226G		Office	na	no acm	na	na	na
	WC226H		Office	na	no acm	na	na	na
	WC226J		Office	na	no acm	na	na	na
	WC226K		Office	na	no acm	na	na	na
	WC226L		Office	na	no acm	na	na	na
	WC226M		Office	na	no acm	na	na	na
	WC226N		Office	na	no acm	na	na	na
	WC226O		Office	na	no acm	na	na	na
	WC226P		Office	na	no acm	na	na	na
	WC226Q		Office	na	no acm	na	na	na
	WC226R		Office	na	no acm	na	na	na
	WC226T		Office	na	no acm	na	na	na
	WC230		Office	na	no acm	na	na	na
	WC230E		Office	na	no acm	na	na	na
	WC230F		Office	na	no acm	na	na	na
	WC230G		Office	na	no acm	na	na	na
	WC230H		Office	na	no acm	na	na	na
	WC230K		Office	na	no acm	na	na	na
	WC230L		Office	na	no acm	na	na	na
	WC230M		Office	na	no acm	na	na	na
	WC230N		Office	na	no acm	na	na	na
	WC230P		Office	na	no acm	na	na	na
	WC231		Men's Washroom	WC230-001a	Cream Drywall Joint Compound	Positive	Chrysotile	Positive
				WC230-001b	Cream Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
				WC230-001c	Cream Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC232		Janitor's Closet	CC238-CC205-002a	Green Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC233		Women's Washroom	WC230-001a	Cream Drywall Joint Compound	Positive	Chrysotile	Positive
				WC230-001b	Cream Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
				WC230-001c	Cream Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC234		Mechanical Room	na	no acm	na	na	na
	WC235		Storage	na	no acm	na	na	na
	WC236		Storage	na	no acm	na	na	na
	WC237		Storage	AC-C2-ASB-01A	drywall compound	Negative	na	na
				AC-C2-ASB-01B	drywall compound	Negative	na	na
				AC-C2-ASB-01C	drywall compound	Negative	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WC238		Storage	na	no acm	na	na	na
	WC300CC1		Hallway	na	no acm	na	na	na
	WC300CC2		Hallway	na	no acm	na	na	na
	WC300CC3	Previously WC346cc	Ramp at the side of the class	6	stipple	Negative	na	na
				7	stipple	Positive	Chrysotile	Positive
				8	stipple	Positive	Chrysotile	Positive
				9	floor tile	Positive	Chrysotile	Positive
					mastic	Negative	na	na
				10	mastic	Negative	na	na
	WC300SS1		Stairwell	na	no acm	na	na	na
	WC300SS2		Stairwell	na	no acm	na	na	na
	WC300SS3		Stairwell	na	no acm	na	na	na
	WC300SS4		Stairwell	na	no acm	na	na	na
	WC300LS1		Light Study Area	na	no acm	na	na	na
	WC300EE1		Electrical	na	no acm	na	na	na
	WC300DS		(blank)	na	no acm	na	na	na
	WC301MM		Mechanical Room	na	no acm	na	na	na
	WC302		Server Room	na	no acm	na	na	na
	WC302A		(blank)	na	no acm	na	na	na
	WC308		Boardroom	na	no acm	na	na	na
	WC311		Storage	WC311-001a	Brown Vinyl Floor Tile	Positive	Chrysotile	Positive
				WC311-001b	Brown Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
				WC311-001c	Brown Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
	WC316-7 office		Office	C316-7a	ceiling tile	Negative	na	na
				C316-7b	ceiling tile	Negative	na	na
				C316-7c	ceiling tile	Negative	na	na
				C316-7d	ceiling tile	Negative	na	na
				C316-7e	ceiling tile	Negative	na	na
	WC316A		Office	na	no acm	na	na	na
	WC316B		Storage	na	no acm	na	na	na
	WC316C		Office	na	no acm	na	na	na
	WC316D		Office	na	no acm	na	na	na
	WC316E		Office	na	no acm	na	na	na
	WC316F		Office	na	no acm	na	na	na
	WC316G		Office	na	no acm	na	na	na
	WC316H		(blank)	na	no acm	na	na	na
	WC317		(blank)	na	no acm	na	na	na
	WC318		Men's Washroom	na	no acm	na	na	na
	WC319		Break Room	WC316-001c	White Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC320SC		Storage Hallway	WC316-001c	White Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC320A		Storage	WC316-001c	White Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC320B		Storage	WC316-001c	White Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC320C		Storage	WC316-001c	White Vinyl Floor Tile	Positive	Chrysotile	Positive
	WC321		Women's Washroom	na	no acm	na	na	na
	WC327			na	no acm	na	na	na
	WC327A			na	no acm	na	na	na
	WC328			na	no acm	na	na	na
	WC335		Office	WC335-001a	grey vinyl floor tile	Positive	Chrysotile	Positive
				WC335-001b	grey vinyl floor tile	Positive Stop	Chrysotile	Positive Stop
				WC335-001c	grey vinyl floor tile	Positive Stop	Chrysotile	Positive Stop
	WC335A		Office	WC335-001a	grey vinyl floor tile	Positive	Chrysotile	Positive
				WC335-001b	grey vinyl floor tile	Positive Stop	Chrysotile	Positive Stop
				WC335-001c	grey vinyl floor tile	Positive Stop	Chrysotile	Positive Stop
	WC336		(blank)	na	no acm	na	na	na
	WC336A		(blank)	na	no acm	na	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WC336B		(blank)	na	no acm	na	na	na
	WC336C		(blank)	na	no acm	na	na	na
	WC336D		(blank)	na	no acm	na	na	na
	WC336E		(blank)	na	no acm	na	na	na
	WC339		Office	na	no acm	na	na	na
	WC339A		Office	na	no acm	na	na	na
	WC339B		Office	na	no acm	na	na	na
	WC340		Storage	WC335-001a	grey vinyl floor tile	Positive	Chrysotile	Positive
				WC335-001b	grey vinyl floor tile	Positive Stop	Chrysotile	Positive Stop
				WC335-001c	grey vinyl floor tile	Positive Stop	Chrysotile	Positive Stop
	WC341		(blank)	C041-3a	ceiling stipple	Negative	na	na
				C041-3b	ceiling stipple	Negative	na	na
				C041-3c	ceiling stipple	Negative	na	na
				na	baseboard	no acm	na	na
					floor vinyl tile	no acm	na	na
					walls	no acm	na	na
	WC341A		Office	na	no acm	na	na	na
	WC342		Women's Washroom	na	no acm	na	na	na
	WC343		Janitor's Closet	na	no acm	na	na	na
	WC344		Men's Washroom	na	no acm	na	na	na
	WC345MM		Mechanical	na	no acm	na	na	na
	WC346		(blank)	1	carpet mastic	Negative	na	na
				2	carpet mastic	Negative	na	na
				3	carpet mastic	Negative	na	na
				4	carpet mastic	Negative	na	na
				5	carpet mastic	Negative	na	na
				22	stipple	Positive	Chrysotile	Positive
				23	stipple	Positive Stop	Chrysotile	Positive Stop
				24	stipple	Positive Stop	Chrysotile	Positive Stop
				25	stipple	Positive Stop	Chrysotile	Positive Stop
				26	stipple	Positive Stop	Chrysotile	Positive Stop
	WC346A		(blank)	na	no acm	na	na	na
	WC348		(blank)	na	no acm	na	na	na
	WC348A		(blank)	na	no acm	na	na	na
	WC349		(blank)	na	no acm	na	na	na
	WC349A		(blank)	na	no acm	na	na	na
	WC400CC1		Corridor	25	floor tile	Positive	Chrysotile	Positive
	WC400CC2		Corridor	25	floor tile	Positive	Chrysotile	Positive
	WC400CC3		Corridor	25	floor tile	Positive	Chrysotile	Positive
	WC400CC4		Corridor	25	floor tile	Positive	Chrysotile	Positive
	WC400SS1		Stairwell	na	no acm	na	na	na
	WC400SS2		Stairwell	na	no acm	na	na	na
	WC400EE1		(blank)	na	no acm	na	na	na
	WC401		(blank)	196	stipple	Negative	na	na
				197	stipple	Negative	na	na
				198	stipple	Negative	na	na
				199	drywall compound	Negative	na	na
				200	drywall compound	Negative	na	na
				201	drywall compound	Negative	na	na
				202	carpet and mastic	Negative	na	na
				203	carpet and mastic	Negative	na	na
				204	carpet and mastic	Negative	na	na
	WC402		(blank)	196	stipple	Negative	na	na
				197	stipple	Negative	na	na
				198	stipple	Negative	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
				199	drywall compound	Negative	na	na
				200	drywall compound	Negative	na	na
				201	drywall compound	Negative	na	na
				202	carpet and mastic	Negative	na	na
				203	carpet and mastic	Negative	na	na
				204	carpet and mastic	Negative	na	na
	WC403		(blank)	196	stipple	Negative	na	na
				197	stipple	Negative	na	na
				198	stipple	Negative	na	na
				199	drywall compound	Negative	na	na
				200	drywall compound	Negative	na	na
				201	drywall compound	Negative	na	na
				202	carpet and mastic	Negative	na	na
				203	carpet and mastic	Negative	na	na
				204	carpet and mastic	Negative	na	na
	WC405		Men's Washroom	7	drywall compound	Positive	Chrysotile	Positive <0.5%
				8	drywall compound	Positive Stop	Chrysotile	Positive Stop
				9	drywall compound	Positive Stop	Chrysotile	Positive Stop
	WC406		Women's Washroom	7	drywall compound	Positive	Chrysotile	Positive <0.5%
				8	drywall compound	Positive Stop	Chrysotile	Positive Stop
				9	drywall compound	Positive Stop	Chrysotile	Positive Stop
				10	ceiling tile	Negative	na	na
				11	ceiling tile	Negative	na	na
				12	ceiling tile	Negative	na	na
	WC407		(blank)	20	floor tile	Negative	na	na
					mastic	Negative	na	na
				21	mastic	Negative	na	na
				22	mastic	Negative	na	na
				23	mastic	Negative	na	na
				24	mastic	Negative	na	na
	WC408		Storage	na	no acm	na	na	na
	WC420		Office	na	no acm	na	na	na
	WC420A		Office	na	no acm	na	na	na
	WC420B		Office	na	no acm	na	na	na
	WC420C		Office	na	no acm	na	na	na
	WC420D		Office	na	no acm	na	na	na
	WC420E		Office	na	no acm	na	na	na
	WC422		(blank)	13	stipple	Negative	na	na
				14	stipple	Negative	na	na
				15	stipple	Negative	na	na
				16	stipple	Negative	na	na
				17	stipple	Negative	na	na
				18	stipple	Negative	na	na
				19	stipple	Negative	na	na
				208	drywall compound	Negative	na	na
				209	drywall compound	Negative	na	na
				210	drywall compound	Negative	na	na
				211	baseboard	Negative	na	na
					mastic	Negative	na	na
				212	baseboard	Negative	na	na
					mastic	Negative	na	na
				213	baseboard	Negative	na	na
					mastic	Negative	na	na
	WC423		Common Office Area	na	no acm	na	na	na
	WC423A		(blank)	na	no acm	na	na	na

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments	
	WC424		(blank)	1	carpet and mastic	Negative	na	na	
				2	carpet and mastic	Negative	na	na	
				3	carpet and mastic	Negative	na	na	
				208	drywall compound	Negative	na	na	
				209	drywall compound	Negative	na	na	
				210	drywall compound	Negative	na	na	
	WC425		(blank)	(blank)	1	carpet and mastic	Negative	na	na
					2	carpet and mastic	Negative	na	na
					3	carpet and mastic	Negative	na	na
					208	drywall compound	Negative	na	na
					209	drywall compound	Negative	na	na
					210	drywall compound	Negative	na	na
	WC425A		(blank)	na	no acm	na	na	na	
	WC426		(blank)	(blank)	1	carpet and mastic	Negative	na	na
					2	carpet and mastic	Negative	na	na
					3	carpet and mastic	Negative	na	na
					13	stipple	Negative	na	na
					14	stipple	Negative	na	na
					15	stipple	Negative	na	na
					16	stipple	Negative	na	na
					17	stipple	Negative	na	na
18					stipple	Negative	na	na	
19					stipple	Negative	na	na	
WC426A		(blank)	(blank)	1	carpet and mastic	Negative	na	na	
				2	carpet and mastic	Negative	na	na	
				3	carpet and mastic	Negative	na	na	
WC426B		(blank)	(blank)	1	carpet and mastic	Negative	na	na	
				2	carpet and mastic	Negative	na	na	
				3	carpet and mastic	Negative	na	na	
				13	stipple	Negative	na	na	
				14	stipple	Negative	na	na	
				15	stipple	Negative	na	na	
				16	stipple	Negative	na	na	
				17	stipple	Negative	na	na	
				18	stipple	Negative	na	na	
19	stipple	Negative	na	na					
WC426C		(blank)	(blank)	1	carpet and mastic	Negative	na	na	
				2	carpet and mastic	Negative	na	na	
				3	carpet and mastic	Negative	na	na	
WC426D		(blank)	(blank)	1	carpet and mastic	Negative	na	na	
				2	carpet and mastic	Negative	na	na	
				3	carpet and mastic	Negative	na	na	
WC426E		(blank)	(blank)	1	carpet and mastic	Negative	na	na	
				2	carpet and mastic	Negative	na	na	
				3	carpet and mastic	Negative	na	na	
				28	ceiling tile	Negative	na	na	
				29	ceiling tile	Negative	na	na	
				30	ceiling tile	Negative	na	na	
WC426F		(blank)	(blank)	1	carpet and mastic	Negative	na	na	
				2	carpet and mastic	Negative	na	na	
				3	carpet and mastic	Negative	na	na	
				28	ceiling tile	Negative	na	na	
				29	ceiling tile	Negative	na	na	
				30	ceiling tile	Negative	na	na	
WC426G		(blank)	(blank)	1	carpet and mastic	Negative	na	na	

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
				2	carpet and mastic	Negative	na	na
				3	carpet and mastic	Negative	na	na
	WC429		(blank)	13	stipple	Negative	na	na
				14	stipple	Negative	na	na
				15	stipple	Negative	na	na
				16	stipple	Negative	na	na
				17	stipple	Negative	na	na
				18	stipple	Negative	na	na
				19	stipple	Negative	na	na
				211	baseboard	Negative	na	na
					mastic	Negative	na	na
				212	baseboard	Negative	na	na
					mastic	Negative	na	na
				213	baseboard	Negative	na	na
					mastic	Negative	na	na
	WC430A		(blank)	na	no acm	na	na	na
	WC430B		(blank)	na	no acm	na	na	na
	WC430C		Meeting Room	13	stipple	Negative	na	na
				14	stipple	Negative	na	na
				15	stipple	Negative	na	na
				16	stipple	Negative	na	na
				17	stipple	Negative	na	na
				18	stipple	Negative	na	na
				19	stipple	Negative	na	na
	WC430SC		(blank)	na	no acm	na	na	na
	WC431		Meeting Room	na	no acm	na	na	na
	WC432		Meeting Room	na	no acm	na	na	na
	WC433		Boardroom	na	no acm	na	na	na
	WC434		Office	na	no acm	na	na	na
	WC435		Office	na	no acm	na	na	na
	WC436A		Office	na	no acm	na	na	na
	WC436B		Office	na	no acm	na	na	na
	WC436C		Office	na	no acm	na	na	na
	WC437		(blank)	na	no acm	na	na	na
	WC500CC1		Hallway	na	no acm	na	na	na
	WC500CC2		Hallway	na	no acm	na	na	na
	WC500CC3		Hallway	na	no acm	na	na	na
	WC500CC4		Hallway	WC-cc514-cc520-002	drywall joint compound	Positive	Chrysotile	Positive
	WC500CC5		Hallway	na	no acm	na	na	na
	WC500SS1		Stairwell	na	no acm	na	na	na
	WC500SS2		Stairwell	na	no acm	na	na	na
	WC502		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC503		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC504		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC505		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC505A		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC505B		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC507		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC507B		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC507C		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC513		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC514A		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC514B		Storage	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC514C		(blank)	na	no acm	na	na	na
	WC514D		IT Closet	WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC515		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC516		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC517		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC518		President's Office	na	no acm	na	na	na
	WC521		Office	C521-4a	ceiling drywall joint compound	Positive	Chrysotile	Positive
					wall drywall joint compound	Positive	Chrysotile	Positive
				C521-4b	ceiling drywall joint compound	Positive	Chrysotile	Positive
					wall drywall joint compound	Positive	Chrysotile	Positive
				C521-4c	ceiling drywall joint compound	Positive	Chrysotile	Positive
					wall drywall joint compound	Positive	Chrysotile	Positive
				C521-5a	ceiling stipple	Negative	na	na
				C521-5b	ceiling stipple	Positive	Chrysotile	Positive
				C521-5c	ceiling stipple	Negative	na	na
				C521-6a	baseboard	Negative	na	na
					mastic	Negative	na	na
				C521-6b	baseboard	Negative	na	na
					mastic	Negative	na	na
				C521-6c	baseboard	Negative	na	na
					mastic	Negative	na	na
				C521-7a	carpet	Negative	na	na
				C521-7b	carpet	Negative	na	na
				C521-7c	carpet	Negative	na	na
	WC520		(blank)	na	no acm	na	na	na
	WC522		(blank)	WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC524		(blank)	na	no acm	na	na	na
	WC525		Men's Washroom	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
WC-547-001b				Drywall Joint Compound	Positive	Chrysotile	Positive	
WC-547-001c				Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop	
	WC526		Women's Washroom	na	no acm	na	na	na
	WC527		Janitor Closet	na	no acm	na	na	na
	WC530		(blank)	WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC531		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC532		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC533		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC534		Boardroom	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC535		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC536		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC537		Lunch Room	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC538		(blank)	WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC539		Boardroom	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC541		Washroom	na	no acm	na	na	na
	WC542		Copy Room	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC543		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC544		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC545		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC545A		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC546		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop
	WC547		Office	WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments			
WC548			Office	WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive			
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop			
				WC-547-001a	Drywall Joint Compound	Positive	Chrysotile	Positive			
				WC-547-001b	Drywall Joint Compound	Positive	Chrysotile	Positive			
				WC-547-001c	Drywall Joint Compound	Positive Stop	Chrysotile	Positive Stop			
				WC550		(blank)	na	no acm	na	na	na
				WC550A		(blank)	na	no acm	na	na	na
WC550B		(blank)	na	no acm	na	na	na				
WD100CC1			Cafeteria Entrance/Offices Link	na	no acm	na	na	na			
WD100CC2			Cafeteria Offices Hallway	na	no acm	na	na	na			
WD100CC3			Cafeteria/Offices Link	na	no acm	na	na	na			
WD100CC4			Cafeteria Entrance	na	no acm	na	na	na			
WD100CC5			Cafeteria Hallway	na	no acm	na	na	na			
WD100SS1			Cafeteria Stairwell Near Caf entrance	na	no acm	na	na	na			
WD100SS2			Stairwell Near Loading Doors	na	no acm	na	na	na			
WD100JDLINK			Link to J building	na	no acm	na	na	na			
WD100ST			Storage	na	no acm	na	na	na			
WD100PA			Patio	na	no acm	na	na	na			
WD101A			Cafeteria Dining Lounge	na	no acm	na	na	na			
WD101B			Cafeteria Dining Lounge	na	no acm	na	na	na			
WD101C			Cafeteria Dining Lounge	na	no acm	na	na	na			
WD101D			Staff Dining Lounge	na	no acm	na	na	na			
WD101E			(Blank)	na	no acm	na	na	na			
WD101F			(Blank)	na	no acm	na	na	na			
WD101G			(Blank)	na	no acm	na	na	na			
WD101H			Storage	na	no acm	na	na	na			
WD101V8			(Blank)	na	no acm	na	na	na			
WD102			Cafeteria	na	no acm	na	na	na			
WD102Mech			Mechanical Room Above Cafeteria	WDmechroom-001a	Silver Pipe Elbows	Positive	Chrysotile	Positive			
				WDmechroom-001b	Silver Pipe Elbows	Positive Stop	Chrysotile	Positive Stop			
				WDmechroom-001c	Silver Pipe Elbows	Positive Stop	Chrysotile	Positive Stop			
WD102A			Dishwasher	AC-D1-ASB-02A	ACT	Negative	na	na			
				AC-D1-ASB-02B	ACT	Negative	na	na			
				AC-D1-ASB-02C	ACT	Negative	na	na			
WD102B			Kitchen	na	no acm	na	na	na			
WD102C			Kitchen	na	no acm	na	na	na			
WD102D			(blank)	na	no acm	na	na	na			
WD102E			(blank)	na	no acm	na	na	na			
WD102F			(blank)	na	no acm	na	na	na			
WD103				na	no acm	na	na	na			
WD104				na	no acm	na	na	na			
WD105			Reception	na	no acm	na	na	na			
WD105A			GM's Office	na	no acm	na	na	na			
WD105B			Clothing & Gift Mgr Office	na	no acm	na	na	na			
WD105C			Retail Floor Mgr Office	na	no acm	na	na	na			
WD105D			Bookstore Admin	na	no acm	na	na	na			
WD105E			Textbook mgr Office	na	no acm	na	na	na			
WD105F			Meeting Room	na	no acm	na	na	na			
WD105G			Mail Room	190	drywall compound	Negative	na	na			
				191	drywall compound	Negative	na	na			
				192	drywall compound	Negative	na	na			
WD105H			Locker's & Staff Room	na	no acm	na	na	na			
WD105SC			Office Hallway	na	no acm	na	na	na			
WD106			Women's Changeroom	WB351cc-WB357cc-	Red/Orange Vinyl Floor Tile	Positive	Chrysotile	Positive			
				WB351cc-WB357cc-	Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop			

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
				WB351cc-WB357cc-106-2	Red/Orange Vinyl Floor Tile grey ceiling plaster	Positive Stop Positive	Chrysotile Chrysotile	Positive Stop Positive
	WD106A		Women's Washroom	WB351cc-WB357cc-106-2	Red/Orange Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB351cc-WB357cc-106-2	Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
				WB351cc-WB357cc-106-2	Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
	WD106B		Mechanical Room	AC-D1-ASB-01A	Spray Foam Insulation	Negative	na	na
				AC-D1-ASB-01B	Spray Foam Insulation	Negative	na	na
				AC-D1-ASB-01C	Spray Foam Insulation	Negative	na	na
	WD108		Staff Room	WB351cc-WB357cc-106-2	Red/Orange Vinyl Floor Tile	Positive	Chrysotile	Positive
				WB351cc-WB357cc-106-2	Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
				WB351cc-WB357cc-106-2	Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
	WD108A		Washroom	WD108A-001a	Red/Orange Vinyl Floor Tile	Positive	Chrysotile	Positive
				WD108A-001b	Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
				WD108A-001c	Red/Orange Vinyl Floor Tile	Positive Stop	Chrysotile	Positive Stop
				WD108A-002a	Brown Mastic	Positive	Chrysotile	Positive
	WD108B		Showers	na	no acm	na	na	na
	WD109		(blank)	na	no acm	na	na	na
	WD111		Office	na	no acm	na	na	na
	WD111A		Office	na	no acm	na	na	na
	WD111B		Office	na	no acm	na	na	na
	WD111C		Office	na	no acm	na	na	na
	WD111D		Office	na	no acm	na	na	na
	WD112		Kitchen	na	no acm	na	na	na
	WD113		(blank)	na	no acm	na	na	na
	WD113A		(blank)	na	no acm	na	na	na
	WD113B		(blank)	na	no acm	na	na	na
	WD113C		(blank)	na	no acm	na	na	na
	WD114		OH Door	na	no acm	na	na	na
	WD114A		Storage	na	no acm	na	na	na
	WD114B		OH Door	na	no acm	na	na	na
	WD115		(blank)	D115-1	ceiling drywall compound wall drywall compound	Negative Negative	na na	na na
				D115-2	ceiling drywall compound wall drywall compound	Positive Positive	Chrysotile Chrysotile	Positive <0.5% Positive <0.5%
				D115-3	ceiling drywall compound wall drywall compound	Positive Positive	Chrysotile Chrysotile	Positive <0.5% Positive <0.5%
				D115-4	floor tile mastic	Negative Negative	na na	na na
				D115-5	floor tile mastic	Negative Negative	na na	na na
				D115-6	floor tile mastic	Negative Negative	na na	na na
	WD116		Janitor Closet	D115-1	ceiling drywall compound wall drywall compound	Negative Negative	na na	na na
				D115-2	ceiling drywall compound wall drywall compound	Positive Positive	Chrysotile Chrysotile	Positive <0.5% Positive <0.5%
				D115-3	ceiling drywall compound wall drywall compound	Positive Positive	Chrysotile Chrysotile	Positive <0.5% Positive <0.5%
	WD117		(blank)	D115-1	ceiling drywall compound wall drywall compound	Negative Negative	na na	na na
				D115-2	ceiling drywall compound wall drywall compound	Positive Positive	Chrysotile Chrysotile	Positive <0.5% Positive <0.5%
				D115-3	ceiling drywall compound wall drywall compound	Positive Positive	Chrysotile Chrysotile	Positive <0.5% Positive <0.5%
				D117-10	floor tile	Positive	Chrysotile	Positive

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
					mastic	Negative	na	na
				D117-11	floor tile	Positive Stop	Chrysotile	Positive Stop
				D117-12	floor tile	Positive Stop	Chrysotile	Positive Stop
				D117-13	baseboard	Negative	na	na
					mastic	Negative	na	na
				D117-14	baseboard	Negative	na	na
					mastic	Negative	na	na
				D117-15	baseboard	Negative	na	na
					mastic	Negative	na	na
				D117-7	ceiling pipe insulation	Positive	Chrysotile	Positive
				D117-8	ceiling pipe insulation	Positive Stop	Chrysotile	Positive Stop
				D117-9	ceiling pipe insulation	Positive Stop	Chrysotile	Positive Stop
	WD118		Storage	193	drywall compound	Negative	na	na
				194	drywall compound	Negative	na	na
				195	drywall compound	Negative	na	na
	WD118A		(blank)	193	drywall compound	Negative	na	na
				194	drywall compound	Negative	na	na
				195	drywall compound	Negative	na	na
	WD119		Refridgerator	na	no acm	na	na	na
	WG101		(blank)	G114-1	ceiling tile	Negative	na	
				G114-2	ceiling tile	Negative	na	
				G114-3	ceiling tile	Negative	na	
				G114-4	ceiling tile	Negative	na	
				G114-5	ceiling tile	Negative	na	
				G114-6	ceiling tile	Negative	na	
				G114-7	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WG102		(blank)	G114-1	ceiling tile	Negative	na	
				G114-2	ceiling tile	Negative	na	
				G114-3	ceiling tile	Negative	na	
				G114-4	ceiling tile	Negative	na	
				G114-5	ceiling tile	Negative	na	
				G114-6	ceiling tile	Negative	na	
				G114-7	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WG103		(blank)	G114-1	ceiling tile	Negative	na	
				G114-2	ceiling tile	Negative	na	
				G114-3	ceiling tile	Negative	na	
				G114-4	ceiling tile	Negative	na	
				G114-5	ceiling tile	Negative	na	
				G114-6	ceiling tile	Negative	na	
				G114-7	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WG104		(blank)	na	ceiling space	no acm	na	
	WG105		(blank)	G114-1	ceiling tile	Negative	na	
				G114-2	ceiling tile	Negative	na	
				G114-3	ceiling tile	Negative	na	
				G114-4	ceiling tile	Negative	na	
				G114-5	ceiling tile	Negative	na	
				G114-6	ceiling tile	Negative	na	
				G114-7	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WG106		(blank)	G114-1	ceiling tile	Negative	na	
				G114-2	ceiling tile	Negative	na	
				G114-3	ceiling tile	Negative	na	

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
				G114-4	ceiling tile	Negative	na	
				G114-5	ceiling tile	Negative	na	
				G114-6	ceiling tile	Negative	na	
				G114-7	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WG107		(blank)	G114-1	ceiling tile	Negative	na	
				G114-2	ceiling tile	Negative	na	
				G114-3	ceiling tile	Negative	na	
				G114-4	ceiling tile	Negative	na	
				G114-5	ceiling tile	Negative	na	
				G114-6	ceiling tile	Negative	na	
				G114-7	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WG108		(blank)	G114-1	ceiling tile	Negative	na	
				G114-2	ceiling tile	Negative	na	
				G114-3	ceiling tile	Negative	na	
				G114-4	ceiling tile	Negative	na	
				G114-5	ceiling tile	Negative	na	
				G114-6	ceiling tile	Negative	na	
				G114-7	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WG108B		(blank)	G114-1	ceiling tile	Negative	na	
				G114-2	ceiling tile	Negative	na	
				G114-3	ceiling tile	Negative	na	
				G114-4	ceiling tile	Negative	na	
				G114-5	ceiling tile	Negative	na	
				G114-6	ceiling tile	Negative	na	
				G114-7	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WG109		(blank)	G114-1	ceiling tile	Negative	na	
				G114-2	ceiling tile	Negative	na	
				G114-3	ceiling tile	Negative	na	
				G114-4	ceiling tile	Negative	na	
				G114-5	ceiling tile	Negative	na	
				G114-6	ceiling tile	Negative	na	
				G114-7	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WG110		(blank)	G114-1	ceiling tile	Negative	na	
				G114-2	ceiling tile	Negative	na	
				G114-3	ceiling tile	Negative	na	
				G114-4	ceiling tile	Negative	na	
				G114-5	ceiling tile	Negative	na	
				G114-6	ceiling tile	Negative	na	
				G114-7	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WG111		(blank)	G114-1	ceiling tile	Negative	na	
				G114-2	ceiling tile	Negative	na	
				G114-3	ceiling tile	Negative	na	
				G114-4	ceiling tile	Negative	na	
				G114-5	ceiling tile	Negative	na	
				G114-6	ceiling tile	Negative	na	
				G114-7	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WG112		(blank)	G114-1	ceiling tile	Negative	na	
				G114-2	ceiling tile	Negative	na	

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
				G114-3	ceiling tile	Negative	na	
				G114-4	ceiling tile	Negative	na	
				G114-5	ceiling tile	Negative	na	
				G114-6	ceiling tile	Negative	na	
				G114-7	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WG113		(blank)	G114-1	ceiling tile	Negative	na	
				G114-2	ceiling tile	Negative	na	
				G114-3	ceiling tile	Negative	na	
				G114-4	ceiling tile	Negative	na	
				G114-5	ceiling tile	Negative	na	
				G114-6	ceiling tile	Negative	na	
				G114-7	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WG114		(blank)	G114-1	ceiling tile	Negative	na	
				G114-2	ceiling tile	Negative	na	
				G114-3	ceiling tile	Negative	na	
				G114-4	ceiling tile	Negative	na	
				G114-5	ceiling tile	Negative	na	
				G114-6	ceiling tile	Negative	na	
				G114-7	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WG114cc		corridor between G114 & G116	G114-1	ceiling tile	Negative	na	
				G114-2	ceiling tile	Negative	na	
				G114-3	ceiling tile	Negative	na	
				G114-4	ceiling tile	Negative	na	
				G114-5	ceiling tile	Negative	na	
				G114-6	ceiling tile	Negative	na	
				G114-7	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WG115		(blank)	G114-1	ceiling tile	Negative	na	
				G114-2	ceiling tile	Negative	na	
				G114-3	ceiling tile	Negative	na	
				G114-4	ceiling tile	Negative	na	
				G114-5	ceiling tile	Negative	na	
				G114-6	ceiling tile	Negative	na	
				G114-7	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WG115		Closet	G115-1	ceiling drywall joint compound	Negative	na	
				G115-2	ceiling drywall joint compound	Negative	na	
				G115-3	ceiling drywall joint compound	Negative	na	
	WG115A		(blank)	G114-1	ceiling tile	Negative	na	
				G114-2	ceiling tile	Negative	na	
				G114-3	ceiling tile	Negative	na	
				G114-4	ceiling tile	Negative	na	
				G114-5	ceiling tile	Negative	na	
				G114-6	ceiling tile	Negative	na	
				G114-7	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WG115B		(blank)	G114-1	ceiling tile	Negative	na	
				G114-2	ceiling tile	Negative	na	
				G114-3	ceiling tile	Negative	na	
				G114-4	ceiling tile	Negative	na	
				G114-5	ceiling tile	Negative	na	
				G114-6	ceiling tile	Negative	na	

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
				G114-7	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WG115Bcc		corridor between G115B & G114	G114-1	ceiling tile	Negative	na	
				G114-2	ceiling tile	Negative	na	
				G114-3	ceiling tile	Negative	na	
				G114-4	ceiling tile	Negative	na	
				G114-5	ceiling tile	Negative	na	
				G114-6	ceiling tile	Negative	na	
				G114-7	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WG116		(blank)	na	ceiling	no acm	na	
	WG117		(blank)	G117-1	ceiling drywall joint compound	Negative	na	
				G117-2	ceiling drywall joint compound	Negative	na	
				G117-3	ceiling drywall joint compound	Negative	na	
	WG118		(blank)	G117-1	ceiling drywall joint compound	Negative	na	
				G117-2	ceiling drywall joint compound	Negative	na	
				G117-3	ceiling drywall joint compound	Negative	na	
	WG120		(blank)	na	ceiling space	no acm	na	
	WG200cc		Corridor	na	all new	no acm	na	
	WG201		(blank)	G114-1	ceiling tile	Negative	na	
				G114-2	ceiling tile	Negative	na	
				G114-3	ceiling tile	Negative	na	
				G114-4	ceiling tile	Negative	na	
				G114-5	ceiling tile	Negative	na	
				G114-6	ceiling tile	Negative	na	
				G114-7	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WG201A		(blank)	G114-1	ceiling tile	Negative	na	
				G114-2	ceiling tile	Negative	na	
				G114-3	ceiling tile	Negative	na	
				G114-4	ceiling tile	Negative	na	
				G114-5	ceiling tile	Negative	na	
				G114-6	ceiling tile	Negative	na	
				G114-7	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WG204		(blank)	na	ceiling space	no acm	na	
	WG220		(blank)	na	ceiling space	no acm	na	
	WG-closet		Closet	G114-1	ceiling tile	Negative	na	
				G114-2	ceiling tile	Negative	na	
				G114-3	ceiling tile	Negative	na	
				G114-4	ceiling tile	Negative	na	
				G114-5	ceiling tile	Negative	na	
				G114-6	ceiling tile	Negative	na	
				G114-7	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WWH204cc		Hallway	na	baseboard	no acm	na	
					drywall joint compound	no acm	na	
					floor vinyl tiles	no acm	na	
					new ceiling tile	no acm	na	
	WH217cc		Corridor between H217 and H213	139	ceiling tile	Negative	na	
				140	ceiling tile	Negative	na	
				141	ceiling tile	Negative	na	
				142	ceiling tile	Negative	na	
				143	ceiling tile	Negative	na	
				147	baseboard	Negative	na	

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
					mastic	Negative	na	
				148	baseboard	Negative	na	
					mastic	Negative	na	
				149	baseboard	Negative	na	
					mastic	Negative	na	
	WH217F		(blank)	139	ceiling tile	Negative	na	
				140	ceiling tile	Negative	na	
				141	ceiling tile	Negative	na	
				142	ceiling tile	Negative	na	
				143	ceiling tile	Negative	na	
				144	baseboard	Negative	na	
					mastic	Negative	na	
				145	baseboard	Negative	na	
					mastic	Negative	na	
				146	baseboard	Negative	na	
					mastic	Negative	na	
	WL101		(blank)	na	ceiling space	no acm	na	
					new ceiling tile	no acm	na	
	WL102		(blank)	na	ceiling space	no acm	na	
					new ceiling tile	no acm	na	
	WL103		(blank)	L103-1	ceiling tile	Negative	na	
				L103-2	ceiling tile	Negative	na	
				L103-3	ceiling tile	Negative	na	
				L103-4	ceiling tile	Negative	na	
				L103-5	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WL105		(blank)	L103-1	ceiling tile	Negative	na	
				L103-2	ceiling tile	Negative	na	
				L103-3	ceiling tile	Negative	na	
				L103-4	ceiling tile	Negative	na	
				L103-5	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WL105A		(blank)	L103-1	ceiling tile	Negative	na	
				L103-2	ceiling tile	Negative	na	
				L103-3	ceiling tile	Negative	na	
				L103-4	ceiling tile	Negative	na	
				L103-5	ceiling tile	Negative	na	
				na	ceiling space	no acm	na	
	WL108		(blank)	L108-1	ceiling drywall joint compound	Negative	na	
				L108-2	ceiling drywall joint compound	Negative	na	
				L108-3	ceiling drywall joint compound	Negative	na	
	WL109		(blank)	L108-1	ceiling drywall joint compound	Negative	na	
				L108-2	ceiling drywall joint compound	Negative	na	
				L108-3	ceiling drywall joint compound	Negative	na	
	WL109A		(blank)	L108-1	ceiling drywall joint compound	Negative	na	
				L108-2	ceiling drywall joint compound	Negative	na	
				L108-3	ceiling drywall joint compound	Negative	na	
	WL109B		(blank)	na	ceiling space	no acm	na	
					new ceiling tile	no acm	na	
	WL110		(blank)	L108-1	ceiling drywall joint compound	Negative	na	
				L108-2	ceiling drywall joint compound	Negative	na	
				L108-3	ceiling drywall joint compound	Negative	na	
	WL110A		(blank)	L108-1	ceiling drywall joint compound	Negative	na	
				L108-2	ceiling drywall joint compound	Negative	na	
				L108-3	ceiling drywall joint compound	Negative	na	

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments		
	WM100A		(blank)	na	ceiling space & ceiling	no acm	na			
	WM100B		(blank)	na	ceiling space & ceiling	no acm	na			
	WM101		(blank)	na	ceiling space & ceiling	no acm	na			
	WM102		(blank)	na	ceiling space & ceiling	no acm	na			
	WM103		(blank)	na	ceiling space & ceiling	no acm	na			
	WM104		(blank)	na	ceiling space & ceiling	no acm	na			
	WM104A - WM104D		(blank)	na	ceiling space & ceiling	no acm	na			
	WM105		(blank)	na	ceiling space & ceiling	no acm	na			
	WM107		(blank)	na	ceiling space & ceiling	no acm	na			
	WM109		(blank)	na	ceiling space & ceiling	no acm	na			
	WM110		(blank)	na	ceiling space & ceiling	no acm	na			
	WM111		(blank)	na	ceiling space & ceiling	no acm	na			
	WM112		(blank)	na	ceiling space & ceiling	no acm	na			
	WM112B		(blank)	na	ceiling space & ceiling	no acm	na			
	WM200		(blank)	na	ceiling space & ceiling	no acm	na			
	WM201		(blank)	na	ceiling space & ceiling	no acm	na			
	WM202		(blank)	na	ceiling space & ceiling	no acm	na			
	WM203		(blank)	na	ceiling space & ceiling	no acm	na			
	W - M Building - Main area		(blank)	13	stipple	Negative	na			
						14	stipple	Negative	na	
						15	stipple	Negative	na	
						18	stipple	Negative	na	
						20	floor tile	Negative	na	
							mastic	Negative	na	
						21	mastic	Negative	na	
						22	mastic	Negative	na	
						23	mastic	Negative	na	
						24	mastic	Negative	na	
							mastic	Negative	na	
						26	mastic	Negative	na	
						27	mastic	Negative	na	
	W - North stairs		(blank)	208	drywall compound	Negative	na			
						209	drywall compound	Negative	na	
						210	drywall compound	Negative	na	
	W - M-corridor		Centre corridor	na	ceiling space & ceiling	no acm	na			
	WZ100		(blank)	na	ceiling space & ceiling	no acm	na			
	WZ101		(blank)	na	ceiling space & ceiling	no acm	na			
	WZ102		(blank)	na	ceiling space & ceiling	no acm	na			
	WZ103		(blank)	na	ceiling space & ceiling	no acm	na			
	WZ104		(blank)	na	ceiling space & ceiling	no acm	na			
	WZ105		(blank)	na	ceiling space & ceiling	no acm	na			
	WZ106		(blank)	na	ceiling space & ceiling	no acm	na			
	WZ107		(blank)	na	ceiling space & ceiling	no acm	na			
	WZ108		(blank)	na	ceiling space & ceiling	no acm	na			
	WZ109		(blank)	na	ceiling space & ceiling	no acm	na			
	WZ110		(blank)	na	ceiling space & ceiling	no acm	na			
	WZ111		(blank)	na	ceiling space & ceiling	no acm	na			
	WZ112		(blank)	na	ceiling space & ceiling	no acm	na			
	WZ1127		(blank)	na	ceiling space & ceiling	no acm	na			
	WZ113		(blank)	na	ceiling space & ceiling	no acm	na			
	WZ114		(blank)	na	ceiling space & ceiling	no acm	na			
	WZ115		(blank)	na	ceiling space & ceiling	no acm	na			
	WZ116		(blank)	na	ceiling space & ceiling	no acm	na			
	WZ117		(blank)	na	ceiling space & ceiling	no acm	na			
	WZ119		(blank)	na	ceiling space & ceiling	no acm	na			

Asbestos Lab Results - Posted on Physical Resources Website on October 2017

Campus	Location ID	OLD Location ID	Location Description	Sample ID	Material Sampled	Lab Result	Asbestos Type	Comments
	WZ120		(blank)	na	ceiling space & ceiling	no acm	na	
	WZ121		(blank)	na	ceiling space & ceiling	no acm	na	
	WZ122		(blank)	na	ceiling space & ceiling	no acm	na	
	WZ123		(blank)	na	ceiling space & ceiling	no acm	na	
	WZ124		(blank)	na	ceiling space & ceiling	no acm	na	
	WZ125		(blank)	na	ceiling space & ceiling	no acm	na	
	WZ126		(blank)	na	ceiling space & ceiling	no acm	na	
	WZ128		(blank)	na	ceiling space & ceiling	no acm	na	
	WZ129		(blank)	na	ceiling space & ceiling	no acm	na	

	REMOVED
	POSITIVE STOP
	POSITIVE